


State of Wisconsin
 Department of Natural Resources
 Bureau of Community Financial Assistance – CF/2
 101 S. Webster St., P.O. Box 7921
 Madison, WI 53707-7921
 Phone No. (608) 266-7555, FAX (608) 267-0496

Environmental Improvement Fund (EIF)
 Green Project Reserve (GPR)
 Addendum to Financial Assistance Application
 Page 1 of 5 - August 2010

Applicants must complete and submit this form for each Clean Water Fund Program (CWFP) and Safe Drinking Water Loan Program (SDWLP) project for which they submit a Financial Assistance Application.

Municipality Village of Mount Hope	<input type="checkbox"/> CWFP <input checked="" type="checkbox"/> SDWLP	EIF Project No. 5160-04
Does this project include any "green" elements as described below? <input checked="" type="checkbox"/> YES (If yes, complete and return page 1 <u>and</u> appropriate page(s) with green category information) <input type="checkbox"/> NO (If no, complete and return only page 1)		
Name and Title of Person Completing This Form (Type or Print) Mr. Bart Nies, P.E.	Phone No. (608) 348-5355	Email Address bart@delta3eng.biz
Signature of Person Completing This Form 		Date Signed 6/27/13

Green projects fall into four separate categories: green infrastructure, water efficiency, energy efficiency, and environmentally innovative projects. Please read the definitions below and refer to the guidance document *Green Project Reserve: Guidance for Determining Project Eligibility*, dated April 21, 2010, (available on the web at <http://dnr.wi.gov/org/caer/cfa/EL/Section/news.html>). This document explains the types of projects eligible for funding under the Green Project Reserve and details which types of projects are considered categorically eligible and which types of projects require a business case. **Applicants must submit all required business cases prior to loan closing.** DNR is required to post the business cases on the web.

When completing this form, include only those costs you intend to request from the Environmental Improvement Fund.

SUMMARY OF GREEN PROJECT RESERVE COSTS

GREEN CATEGORY	EIF-FUNDED GREEN PROJECT COSTS
Green Infrastructure	\$
Water Efficiency	\$ 462,047.00
Energy Efficiency	\$
Environmentally Innovative	\$
TOTAL	\$ 462,047.00

FOR DNR USE ONLY	
Signature of GPR Specialist 	Date Review Completed 8/5/14

Water Efficiency definition: Water Efficiency projects include the use of improved technologies and practices to deliver equal or better services with less water. Water Efficiency encompasses conservation and reuse efforts, as well as water loss reduction and prevention, to protect water resources for the future.

This project is categorically a Water Efficiency project ____

Indicate Categorical Project number from *GPR: Guidance for Determining Project Eligibility* and estimated cost (i.e. 2.2-2 for \$35,000):

Categorical Project Number: _____ Estimated Cost: \$ _____

Categorical Project Number: _____ Estimated Cost: \$ _____

Other: _____ Estimated Cost: \$ _____

Or

This project requires a business case X

Indicate Business Case Project number from *GPR: Guidance for Determining Project Eligibility* and estimated cost (i.e. 2.5-3 for \$50,000):

Business Case Project Number: 2.5-2 Estimated Cost: \$ 462,047.00

Business Case Project Number: _____ Estimated Cost: \$ _____

Other: _____ Estimated Cost: \$ _____

The **TOTAL** estimated cost of this Water Efficiency project or project components \$ 462,047.00

Please provide a **detailed** description of your Water Efficiency project or project components below. Please include any pertinent calculations of water savings in both gallons and percentage of overall water usage. Attach a separate sheet if necessary.

The existing six-inch (6") water main on Main Street (County Trunk Highway 'JJ') from Taylor Street to Whiteside Street and on Aarlocker Street from Main Street (C.T.H. 'JJ') to 80' N. of Main Street (C.T.H. 'JJ') will be replaced with proposed six-inch (6") and eight-inch (8") DR 18 PVC Water Main Pipe. The existing substandard hydrants, water valves, and associated water services will also be replaced within the right-of-way of Main Street (C.T.H. 'JJ') and Aarlocker Street. The proposed water distribution system improvements will eliminate water main breaks and water main leaks, resulting in less water loss for the Village's water system.

With these proposed improvements, the Village anticipates to reduce its water loss by 10%. (or by 110,600 gal.)