

900 Long Lake Road, Suite 200  
St. Paul, Minnesota 55112  
United States  
www.ghd.com



Our ref: 11222418-LTR-49

June 10, 2022

Mr. Chu Y. Wu  
11101 Kumquat Street NW  
Coon Rapids, Minnesota 55448

**April 2022 Private Well Sampling Results**  
8452 West Doctor lake Road, RW6 and RW6 Shop  
Penta Wood Products Superfund Site  
Siren, Wisconsin

Dear Mr. Wu:

Water well samples were collected from select private properties near the Penta Wood Products Superfund Site on April 14, 2022 as part of routine monitoring. These samples were collected by GHD Services Inc. (GHD), on behalf of the Wisconsin Department of Natural Resources (WDNR). Samples were analyzed by an independent laboratory, Eurofins of University Park, Illinois. Individual sampling results are being provided to each individual property owner having consented to sampling.

This sampling event included the analysis of pentachlorophenol (PCP), benzene, ethylbenzene, toluene, xylene (BTEX), and naphthalene.

Results of the laboratory analysis indicate that the water from your wells has no detections of the compounds listed above. This means that the compounds listed above are not present at concentrations equal to or greater than laboratory detection limits. Laboratory detection limits are less than enforcement standards (ES) as found in Wisconsin Administrative Code Chapter NR 140 and the maximum contaminant levels (MCL) as found in Wisconsin Administrative Code Chapter NR 809. Therefore, the water from your wells currently meets State drinking water standards for the compounds tested.

If you have any questions, please contact our office at (612) 524-6866 or Phil Richard (WDNR project manager) at (715) 661-0125.

Regards,

A handwritten signature in blue ink, appearing to read "Tim Ree", is written over a light blue circular stamp.

**Tim Ree**  
Project Manager / Project Engineer

+1 612 524-6866  
tim.ree@ghd.com

TR/kg/LTR-49

Copy to: Phil Richard, WDNR Park Falls (via email)  
Celine Wysgalla, USEPA (via email)  
Jacob Sedivy, WDNR Spooner (via email)

# Client Sample Results

Client: GHD Services Inc.  
Project/Site: Penta Wood 11222418

Job ID: 500-215168-1

**Client Sample ID: W-220414-RA-100**

**Lab Sample ID: 500-215168-1**

**Date Collected: 04/14/22 10:45**

**Matrix: Water**

**Date Received: 04/15/22 09:30**

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			04/26/22 15:49	1
Toluene	<0.15		0.50	0.15	ug/L			04/26/22 15:49	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			04/26/22 15:49	1
Xylenes, Total	<0.22		1.0	0.22	ug/L			04/26/22 15:49	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	79		75 - 126		04/26/22 15:49	1
Toluene-d8 (Surr)	100		75 - 120		04/26/22 15:49	1
4-Bromofluorobenzene (Surr)	80		72 - 124		04/26/22 15:49	1
Dibromofluoromethane	93		75 - 120		04/26/22 15:49	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<0.24		0.78	0.24	ug/L		04/21/22 07:23	04/22/22 22:32	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5 (Surr)	70		36 - 120	04/21/22 07:23	04/22/22 22:32	1
2-Fluorobiphenyl (Surr)	72		34 - 110	04/21/22 07:23	04/22/22 22:32	1
Terphenyl-d14 (Surr)	172	X	40 - 145	04/21/22 07:23	04/22/22 22:32	1

## Method: 8151A - Herbicides (GC)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	<0.14	*	0.098	0.14	ug/L		04/21/22 10:40	04/25/22 14:28	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
DCAA	136	X	25 - 130	04/21/22 10:40	04/25/22 14:28	1

# Client Sample Results

Client: GHD Services Inc.  
Project/Site: Penta Wood 11222418

Job ID: 500-215168-1

**Client Sample ID: W-220414-RA-102**

**Lab Sample ID: 500-215168-3**

**Date Collected: 04/14/22 10:53**

**Matrix: Water**

**Date Received: 04/15/22 09:30**

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			04/26/22 16:37	1
Toluene	<0.15		0.50	0.15	ug/L			04/26/22 16:37	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			04/26/22 16:37	1
Xylenes, Total	<0.22		1.0	0.22	ug/L			04/26/22 16:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	80		75 - 126		04/26/22 16:37	1
Toluene-d8 (Surr)	94		75 - 120		04/26/22 16:37	1
4-Bromofluorobenzene (Surr)	83		72 - 124		04/26/22 16:37	1
Dibromofluoromethane	94		75 - 120		04/26/22 16:37	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<0.24		0.78	0.24	ug/L		04/21/22 07:23	04/22/22 23:15	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5 (Surr)	75		36 - 120	04/21/22 07:23	04/22/22 23:15	1
2-Fluorobiphenyl (Surr)	80		34 - 110	04/21/22 07:23	04/22/22 23:15	1
Terphenyl-d14 (Surr)	171	X	40 - 145	04/21/22 07:23	04/22/22 23:15	1

## Method: 8151A - Herbicides (GC)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	<0.15	*	0.10	0.15	ug/L		04/21/22 10:40	04/25/22 15:07	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
DCAA	129		25 - 130	04/21/22 10:40	04/25/22 15:07	1

900 Long Lake Road, Suite 200  
St. Paul, Minnesota 55112  
United States  
www.ghd.com



Our ref: 11222418-LTR-50

June 10, 2022

Mr. and Mrs. Ken and Sheri Nelson  
8454 Daniels 70  
Siren, Wisconsin 54872

April 2022 Private Well Sampling Results  
8454 Daniels 70, RW3  
Penta Wood Products Superfund Site  
Siren, Wisconsin

Dear Mr. and Mrs. Nelson:

Water well samples were collected from select private properties near the Penta Wood Products Superfund Site on April 14, 2022 as part of routine monitoring. These samples were collected by GHD Services Inc. (GHD), on behalf of the Wisconsin Department of Natural Resources (WDNR). Samples were analyzed by an independent laboratory, Eurofins of University Park, Illinois. Individual sampling results are being provided to each individual property owner having consented to sampling.

This sampling event included the analysis of pentachlorophenol (PCP), benzene, ethylbenzene, toluene, xylene (BTEX), and naphthalene.

Results of the laboratory analysis indicate that the water from your well has no detections of the compounds listed above. This means that the compounds listed above are not present at concentrations equal to or greater than laboratory detection limits. Laboratory detection limits are less than enforcement standards (ES) as found in Wisconsin Administrative Code Chapter NR 140 and the maximum contaminant levels (MCL) as found in Wisconsin Administrative Code Chapter NR 809. Therefore, the water from your well currently meets State drinking water standards for the compounds tested.

If you have any questions, please contact our office at (612) 524-6866 or Phil Richard (WDNR project manager) at (715) 661-0125.

Regards,

A handwritten signature in blue ink, appearing to read "Tim Ree", is written over a light blue circular stamp.

**Tim Ree**  
Project Manager / Project Engineer

+1 612 524-6866  
tim.ree@ghd.com

TR/kg/LTR-50

Copy to: Phil Richard, WDNR Park Falls (via email)  
Celine Wysgalla, USEPA (via email)  
Jacob Sedivy, WDNR Spooner (via email)

# Client Sample Results

Client: GHD Services Inc.  
Project/Site: Penta Wood 11222418

Job ID: 500-215168-1

**Client Sample ID: W-220414-RA-106**

**Lab Sample ID: 500-215168-7**

Date Collected: 04/14/22 13:55

Matrix: Water

Date Received: 04/15/22 09:30

**Method: 8260B - Volatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			04/26/22 18:57	1
Toluene	<0.15		0.50	0.15	ug/L			04/26/22 18:57	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			04/26/22 18:57	1
Xylenes, Total	<0.22		1.0	0.22	ug/L			04/26/22 18:57	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	81		75 - 126		04/26/22 18:57	1
Toluene-d8 (Surr)	95		75 - 120		04/26/22 18:57	1
4-Bromofluorobenzene (Surr)	84		72 - 124		04/26/22 18:57	1
Dibromofluoromethane	94		75 - 120		04/26/22 18:57	1

**Method: 8270D - Semivolatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<0.24		0.77	0.24	ug/L		04/21/22 07:23	04/24/22 10:56	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5 (Surr)	60		36 - 120	04/21/22 07:23	04/24/22 10:56	1
2-Fluorobiphenyl (Surr)	55		34 - 110	04/21/22 07:23	04/24/22 10:56	1
Terphenyl-d14 (Surr)	97		40 - 145	04/21/22 07:23	04/24/22 10:56	1

**Method: 8151A - Herbicides (GC)**

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	<0.14	*	0.097	0.14	ug/L		04/21/22 10:41	04/25/22 17:24	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
DCAA	99		25 - 130	04/21/22 10:41	04/25/22 17:24	1

900 Long Lake Road, Suite 200  
St. Paul, Minnesota 55112  
United States  
www.ghd.com



Our ref: 11222418-LTR-51

June 10, 2022

Mr. Vayne Engstrom  
8526 Daniels 70  
Siren, Wisconsin 54872

**April 2022 Private Well Sampling Results**  
**8526 Daniels 70, RW4**  
**Penta Wood Products Superfund Site**  
**Siren, Wisconsin**

Dear Mr. Engstrom:

Water well samples were collected from select private properties near the Penta Wood Products Superfund Site on April 14, 2022 as part of routine monitoring. These samples were collected by GHD Services Inc. (GHD), on behalf of the Wisconsin Department of Natural Resources (WDNR). Samples were analyzed by an independent laboratory, Eurofins of University Park, Illinois. Individual sampling results are being provided to each individual property owner having consented to sampling.

This sampling event included the analysis of pentachlorophenol (PCP), benzene, ethylbenzene, toluene, xylene (BTEX), and naphthalene.

Results of the laboratory analysis indicate that the water from your well has no detections of the compounds listed above. This means that the compounds listed above are not present at concentrations equal to or greater than laboratory detection limits. Laboratory detection limits are less than enforcement standards (ES) as found in Wisconsin Administrative Code Chapter NR 140 and the maximum contaminant levels (MCL) as found in Wisconsin Administrative Code Chapter NR 809. Therefore, the water from your well currently meets State drinking water standards for the compounds tested.

If you have any questions, please contact our office at (612) 524-6866 or Phil Richard (WDNR project manager) at (715) 661-0125.

Regards,

A handwritten signature in blue ink, appearing to read "Tim Ree", is written over a light blue circular stamp.

**Tim Ree**  
Project Manager / Project Engineer

+1 612 524-6866  
tim.ree@ghd.com

TR/kg/LTR-51

Copy to: Phil Richard, WDNR Park Falls (via email)  
Celine Wysgalla, USEPA (via email)  
Jacob Sedivy, WDNR Spooner (via email)

# Client Sample Results

Client: GHD Services Inc.  
Project/Site: Penta Wood 11222418

Job ID: 500-215168-1

**Client Sample ID: W-220414-RA-107**

**Lab Sample ID: 500-215168-8**

**Date Collected: 04/14/22 13:50**

**Matrix: Water**

**Date Received: 04/15/22 09:30**

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			04/26/22 19:20	1
Toluene	<0.15		0.50	0.15	ug/L			04/26/22 19:20	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			04/26/22 19:20	1
Xylenes, Total	<0.22		1.0	0.22	ug/L			04/26/22 19:20	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	79		75 - 126		04/26/22 19:20	1
Toluene-d8 (Surr)	95		75 - 120		04/26/22 19:20	1
4-Bromofluorobenzene (Surr)	88		72 - 124		04/26/22 19:20	1
Dibromofluoromethane	93		75 - 120		04/26/22 19:20	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<0.24		0.76	0.24	ug/L		04/21/22 07:23	04/24/22 11:20	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5 (Surr)	58		36 - 120	04/21/22 07:23	04/24/22 11:20	1
2-Fluorobiphenyl (Surr)	52		34 - 110	04/21/22 07:23	04/24/22 11:20	1
Terphenyl-d14 (Surr)	101		40 - 145	04/21/22 07:23	04/24/22 11:20	1

## Method: 8151A - Herbicides (GC)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	<0.15	*	0.11	0.15	ug/L		04/21/22 10:41	04/25/22 17:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
DCAA	123		25 - 130	04/21/22 10:41	04/25/22 17:44	1

900 Long Lake Road, Suite 200  
St. Paul, Minnesota 55112  
United States  
www.ghd.com



Our ref: 11222418-LTR-52

June 10, 2022

Ms. Rita Edaburn  
Box 717  
Grantsburg, Wisconsin 54840

**April 2022 Private Well Sampling Results**  
**8627 Daniels 70, RW2**  
**Penta Wood Products Superfund Site**  
**Siren, Wisconsin**

Dear Ms. Edaburn:

Water well samples were collected from select private properties near the Penta Wood Products Superfund Site on April 14, 2022 as part of routine monitoring. These samples were collected by GHD Services Inc. (GHD), on behalf of the Wisconsin Department of Natural Resources (WDNR). Samples were analyzed by an independent laboratory, Eurofins of University Park, Illinois. Individual sampling results are being provided to each individual property owner having consented to sampling.

This sampling event included the analysis of pentachlorophenol (PCP), benzene, ethylbenzene, toluene, xylene (BTEX), and naphthalene.

PCP was the only compound detected in the water sample collected from your private well. The PCP concentration is below the enforcement standard (ES) as found in Wisconsin Administrative Code Chapter NR 140 and the maximum contaminant level (MCL) as found in Wisconsin Administrative Code Chapter NR 809.

Compound	Sample Concentration (µg/L)	ES/MCL (µg/L)
Pentachlorophenol (PCP)	0.31	1/1

Therefore, the water from your well currently meets State drinking water standards for the compounds tested.

Due to this detected concentration, we plan to collect another sample from your well during the week of June 20, 2022. Sampling will occur in the same manner as previous events, and a copy of the analytical results will be mailed to you.



If you have any questions, please contact our office at (612) 524-6866 or Phil Richard (WDNR project manager) at (715) 661-0125.

Regards,

A handwritten signature in blue ink, appearing to read "Tim Ree", with a stylized flourish at the end.

**Tim Ree**  
Project Manager / Project Engineer

+1 612 524-6866  
tim.ree@ghd.com

TR/kg/LTR-52

Copy to:       Phil Richard, WDNR Park Falls (via email)  
                  Celine Wysgalla, USEPA (via email)  
                  Jacob Sedivy, WDNR Spooner (via email)

# Client Sample Results

Client: GHD Services Inc.  
Project/Site: Penta Wood 11222418

Job ID: 500-215168-1

**Client Sample ID: W-220414-RA-104**

**Lab Sample ID: 500-215168-5**

Date Collected: 04/14/22 13:20

Matrix: Water

Date Received: 04/15/22 09:30

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			04/26/22 17:24	1
Toluene	<0.15		0.50	0.15	ug/L			04/26/22 17:24	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			04/26/22 17:24	1
Xylenes, Total	<0.22		1.0	0.22	ug/L			04/26/22 17:24	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	83		75 - 126		04/26/22 17:24	1
Toluene-d8 (Surr)	93		75 - 120		04/26/22 17:24	1
4-Bromofluorobenzene (Surr)	89		72 - 124		04/26/22 17:24	1
Dibromofluoromethane	92		75 - 120		04/26/22 17:24	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<0.23		0.75	0.23	ug/L		04/21/22 07:23	04/22/22 23:59	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5 (Surr)	66		36 - 120	04/21/22 07:23	04/22/22 23:59	1
2-Fluorobiphenyl (Surr)	72		34 - 110	04/21/22 07:23	04/22/22 23:59	1
Terphenyl-d14 (Surr)	160	X	40 - 145	04/21/22 07:23	04/22/22 23:59	1

## Method: 8151A - Herbicides (GC)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	0.31	*	0.097	0.14	ug/L		04/21/22 10:40	05/03/22 10:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
DCAA	80		25 - 130	04/21/22 10:40	05/03/22 10:44	1

900 Long Lake Road, Suite 200  
St. Paul, Minnesota 55112  
United States  
www.ghd.com



Our ref: 11222418-LTR-53

June 10, 2022

Mr. Timothy Tjader  
8783 Daniels 70  
Siren, Wisconsin 54872

**April 2022 Private Well Sampling Results**  
**8783 Daniels 70, RW5**  
**Penta Wood Products Superfund Site**  
**Siren, Wisconsin**

Dear Mr. Tjader:

Water well samples were collected from select private properties near the Penta Wood Products Superfund Site on April 14, 2022 as part of routine monitoring. These samples were collected by GHD Services Inc. (GHD), on behalf of the Wisconsin Department of Natural Resources (WDNR). Samples were analyzed by an independent laboratory, Eurofins of University Park, Illinois. Individual sampling results are being provided to each individual property owner having consented to sampling.

This sampling event included the analysis of pentachlorophenol (PCP), benzene, ethylbenzene, toluene, xylene (BTEX), and naphthalene.

PCP was the only compound detected in the water sample collected from your private well. The PCP concentration is below the enforcement standard (ES) as found in Wisconsin Administrative Code Chapter NR 140 and the maximum contaminant level (MCL) as found in Wisconsin Administrative Code Chapter NR 809.

Compound	Sample Concentration (µg/L)	ES/MCL (µg/L)
Pentachlorophenol (PCP)	0.19	1/1

Therefore, the water from your well currently meets State drinking water standards for the compounds tested.

Due to this detected concentration, we plan to collect another sample from your well during the week of June 20, 2022. Sampling will occur in the same manner as previous events, and a copy of the analytical results will be mailed to you.

If you have any questions, please contact our office at (612) 524-6866 or Phil Richard (WDNR project manager) at (715) 661-0125.

Regards,

A handwritten signature in blue ink, appearing to read "Tim Ree", with a stylized flourish at the end.

**Tim Ree**  
Project Manager / Project Engineer

+1 612 524-6866  
tim.ree@ghd.com

TR/kg/LTR-53

Copy to:       Phil Richard, WDNR Park Falls (via email)  
                  Celine Wysgalla, USEPA (via email)  
                  Jacob Sedivy, WDNR Spooner (via email)

# Client Sample Results

Client: GHD Services Inc.  
Project/Site: Penta Wood 11222418

Job ID: 500-215168-1

**Client Sample ID: W-220414-RA-105**

**Lab Sample ID: 500-215168-6**

**Date Collected: 04/14/22 13:10**

**Matrix: Water**

**Date Received: 04/15/22 09:30**

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			04/26/22 18:33	1
Toluene	<0.15		0.50	0.15	ug/L			04/26/22 18:33	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			04/26/22 18:33	1
Xylenes, Total	<0.22		1.0	0.22	ug/L			04/26/22 18:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	78		75 - 126		04/26/22 18:33	1
Toluene-d8 (Surr)	96		75 - 120		04/26/22 18:33	1
4-Bromofluorobenzene (Surr)	87		72 - 124		04/26/22 18:33	1
Dibromofluoromethane	92		75 - 120		04/26/22 18:33	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<0.24		0.78	0.24	ug/L		04/21/22 07:23	04/23/22 01:05	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5 (Surr)	76		36 - 120	04/21/22 07:23	04/23/22 01:05	1
2-Fluorobiphenyl (Surr)	77		34 - 110	04/21/22 07:23	04/23/22 01:05	1
Terphenyl-d14 (Surr)	163	X	40 - 145	04/21/22 07:23	04/23/22 01:05	1

## Method: 8151A - Herbicides (GC)

Analyte	Result	Qualifier	LOQ	LOD	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	0.19	*	0.095	0.14	ug/L		04/21/22 10:40	04/25/22 16:46	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
DCAA	128		25 - 130	04/21/22 10:40	04/25/22 16:46	1