

Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : MADISON KIPP CORPORATION
 Contact Address : 708 Heartland Trail, Suite 3000
 Madison, WI 53717
 Facility Contact : Andrew Stehn, Project Engineer
 Phone Number : 608-826-3665
 Reporting Period : 07/01/2019 - 09/30/2019
 Form Due Date : 10/21/2019
 Permit Number : **0046566**

Date Received:	
DOC:	426646
FIN:	7960
FID:	113125320
Region:	South Central Region
Permit Drafter:	Trevor J Moen
Reviewer:	Christopher A Dietrich
Office:	Milwaukee

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
001	40	Benzene	09/06/2019	GRAB	<0.15	ug/L	Monthly Avg	50(0)	0.15	0.50	N	999580010
001	54	BETX, Total	09/06/2019	GRAB	<0.40	ug/L	Monthly Avg	750(0)			N	999580010
001	393	PAHs	09/06/2019	GRAB	0.00012	ug/L	Monthly Avg	0.10(0)			N	998020430
001	44	Benzo(a)pyrene	09/06/2019	GRAB	<0.023	ug/L	Monthly Avg	0.10(0)	0.023	0.047	N	998020430
001	307	Naphthalene	09/06/2019	GRAB	<0.047	ug/L	Monthly Avg	70(0)	0.047	0.094	N	998020430
001	80	Bromoform	09/06/2019	GRAB	<0.45	ug/L	Monthly Avg	120(0)	0.45	1.0	N	999580010
001	93	Carbon tetrachloride	09/06/2019	GRAB	<0.38	ug/L		*****	0.38	1.0	N	999580010
001	118	Chloroform	09/06/2019	GRAB	<0.37	ug/L	Monthly Avg	120(0)	0.37	2.0	N	999580010
001	174	Dichlorobromo- methane (bromo-	09/06/2019	GRAB	<0.37	ug/L	Monthly Avg	120(0)	0.37	1.0	N	999580010
001	570	1,2-Dichloro- ethane	09/06/2019	GRAB	<0.39	ug/L	Monthly Avg	180(0)	0.39	1.0	N	999580010
001	558	1,1-Dichloro- ethylene	09/06/2019	GRAB	<0.39	ug/L	Monthly Avg	50(0)	0.39	1.0	N	999580010
001	82	Methyl bromide	09/06/2019	GRAB	<0.65	ug/L	Monthly Avg	120(0)	0.65	3.0	N	999580010
001	120	Chloromethane	09/06/2019	GRAB	<0.32	ug/L	Monthly Avg	120(0)	0.32	1.0	N	999580010
001	565	1,1,2,2-Tetrachloro- ethane	09/06/2019	GRAB	<0.40	ug/L	Monthly Avg	50(0)	0.40	1.0	N	999580010
001	490	Tetrachloroethylene	09/06/2019	GRAB	11	ug/L	Monthly Avg	50(0)	0.37	1.0	N	999580010
001	563	1,1,2-Trichloro- ethane	09/06/2019	GRAB	<0.35	ug/L	Monthly Avg	50(0)	0.35	1.0	N	999580010
001	561	1,1,1-Trichloro- ethane	09/06/2019	GRAB	<0.38	ug/L	Monthly Avg	50(0)	0.38	1.0	N	999580010
001	508	Trichloro- ethylene	09/06/2019	GRAB	2.5	ug/L	Monthly Avg	50(0)	0.16	0.50	N	999580010
001	517	Vinyl chloride	09/06/2019	GRAB	<0.20	ug/L	Monthly Avg	10(0)	0.20	1.0	N	999580010

Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

Potassium Permanganate: Absent (Parameter visually monitored by TRC for neutralization and photo documentation can be provided upon request).

Phenanthrene was the only reported Group 10 PAH parameter and the noted concentration was calculated using the Toxicity Equivalent Factor as outlined in Appendix C of the WPDES permit. The laboratory analytical report also reported Phenanthrene in the method blank.

Laboratory Quality Control Comments

The laboratory analytical report also reported Phenanthrene in the method blank.

Submitted by astehn on 10/21/2019 7:28:04 PM