

# Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : MADISON KIPP CORPORATION  
 Contact Address : 708 Heartland Trail, Suite 3000  
 Madison, WI 53717  
 Facility Contact : Andrew Stehn, Project Engineer  
 Phone Number : 608-826-3665  
 Reporting Period : 10/01/2019 - 12/31/2019  
 Form Due Date : 01/21/2020  
 Permit Number : **0046566**

Date Received:	
DOC:	431536
FIN:	7960
FID:	113125320
Region:	South Central Region
Permit Drafter:	Trevor J Moen
Reviewer:	Christopher A Dietrich
Office:	Milwaukee

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
001	40	Benzene	12/09/2019	GRAB	<0.25	ug/L	Monthly Avg	50(0)	0.25	1.0	N	405132750
001	54	BETX, Total	12/09/2019	GRAB	<1.5	ug/L	Monthly Avg	750(0)			N	405132750
001	393	PAHs	12/09/2019	GRAB	<0.016	ug/L	Monthly Avg	0.10(0)			N	405132750
001	44	Benzo(a)pyrene	12/09/2019	GRAB	<0.0095	ug/L	Monthly Avg	0.10(0)	0.0095	0.047	N	405132750
001	307	Naphthalene	12/09/2019	GRAB	<0.017	ug/L	Monthly Avg	70(0)	0.017	0.083	N	405132750
001	80	Bromoform	12/09/2019	GRAB	<4.0	ug/L	Monthly Avg	120(0)	4.0	13.2	N	405132750
001	93	Carbon tetrachloride	12/09/2019	GRAB	<0.17	ug/L		*****	0.17	1.0	N	405132750
001	118	Chloroform	12/09/2019	GRAB	<1.3	ug/L	Monthly Avg	120(0)	0.5	1.3	N	405132750
001	174	Dichlorobromo- methane (bromo-	12/09/2019	GRAB	<0.36	ug/L	Monthly Avg	120(0)	0.36	1.2	N	405132750
001	570	1,2-Dichloro- ethane	12/09/2019	GRAB	<0.28	ug/L	Monthly Avg	180(0)	0.28	1.0	N	405132750
001	558	1,1-Dichloro- ethylene	12/09/2019	GRAB	<0.24	ug/L	Monthly Avg	50(0)	0.24	1.0	N	405132750
001	82	Methyl bromide	12/09/2019	GRAB	<0.97	ug/L	Monthly Avg	120(0)	0.97	5.0	N	405132750
001	120	Chloromethane	12/09/2019	GRAB	<2.2	ug/L	Monthly Avg	120(0)	2.2	7.3	N	405132750
001	565	1,1,2,2-Tetrachloro- ethane	12/09/2019	GRAB	<0.28	ug/L	Monthly Avg	50(0)	0.28	1.0	N	405132750
001	490	Tetrachloroethylene	12/09/2019	GRAB	13.1	ug/L	Monthly Avg	50(0)	0.33	1.1	N	405132750
001	563	1,1,2-Trichloro- ethane	12/09/2019	GRAB	<0.55	ug/L	Monthly Avg	50(0)	0.55	5.0	N	405132750
001	561	1,1,1-Trichloro- ethane	12/09/2019	GRAB	<0.24	ug/L	Monthly Avg	50(0)	0.24	1.0	N	405132750
001	508	Trichloro- ethylene	12/09/2019	GRAB	2.6	ug/L	Monthly Avg	50(0)	0.26	1.0	N	405132750
001	517	Vinyl chloride	12/09/2019	GRAB	<0.17	ug/L	Monthly Avg	10(0)	0.17	1.0	N	405132750

## Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

### General Remarks

Potassium Permanganate: Absent (Parameter visually monitored by TRC for neutralization and photo documentation can be provided upon request).

### Laboratory Quality Control Comments

Submitted by astehn on 01/20/2020 2:59:28 PM