


City: Minneapolis/Citrix D:\Group: IMDVC Created By: Last Saved By: msmiller  
 TYCO Marinette, WI  
 Z:\GIS\Projects\_ENVTYCO\_Marinette\_WI\IMXD\2019-05\WaterWells\_Highest.mxd 5/15/2019 11:53:39 AM



**LEGEND:**

- PFOA AND/OR PFOS BELOW REPORTING LIMIT
- PFOA AND/OR PFOS DETECTION ABOVE HAL
- PFOA AND/OR PFOS DETECTION BELOW HAL
- APPROXIMATE SITE PROPERTY BOUNDARY
- APPROXIMATE MARINETTE CITY BOUNDARY
- ROAD
- DITCH/STREAM
- WATERBODY

WS-049 - LOCATION NAME  
24 - WELL DEPTH

**YELLOW SHADOWING** PFOA DETECTION ABOVE HAL

**BLUE SHADOWING** PFOA DETECTION BELOW HAL

**GREEN SHADOWING** PFOA NOT DETECTED

VAP-08 - LOCATION NAME  
42.3 - PFOA CONCENTRATION IN ng/L  
(8-12) - VAP SAMPLE DEPTH INTERVAL IN FEET

**5/15/2019**  
**CONTAINS PERSONALLY IDENTIFIABLE INFORMATION**


**NOTES:**

1. THE DATA REFLECTED IS THE HIGHEST VALUE DETECTED FROM THE VARIOUS ANALYSES.
2. WELL LOCATIONS ARE APPROXIMATE.

TYCO FIRE PRODUCTS LP  
MARINETTE, WISCONSIN

**DRINKING WATER WELL LOCATIONS  
WINTER 2019**

**ARCADIS** | **FIGURE 2**



TOWN OF PESHTIGO FINAL WINTER 2019 WATER SAMPLE RESULTS - JANUARY 1 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	Type of Sample	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDoA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	General Well Depth	Detailed Well Depth	Source
WS-005	2/26/2019	Winter	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Shallow	30	-
WS-008	1/22/2019	POET	<b>470 D</b>	<b>23</b>	<b>5.4</b>	<b>140</b>	<b>160</b>	<b>24</b>	<b>1.8 J</b>	< 0.84	<b>190</b>	< 0.91	< 0.66	< 0.61	< 0.52	<b>1.5 J</b>	Shallow	23	-
WS-008	2/18/2019	POET	<b>480 D</b>	<b>20</b>	<b>4.9</b>	<b>140</b>	<b>150</b>	<b>24</b>	<b>1.4 J</b>	< 0.81	<b>190</b>	< 0.88	< 0.65	< 0.60	< 0.51	< 1.1	Shallow	23	-
WS-008	3/28/2019	POET	<b>420 D</b>	<b>21</b>	<b>4.6</b>	<b>110</b>	<b>130</b>	<b>24</b>	<b>2.4</b>	< 0.72	<b>150</b>	< 0.78	< 0.57	< 0.52	<b>0.60 J</b>	< 0.96	Shallow	23	-
WS-009	2/28/2019	POET	<b>17</b>	<b>1.0 J</b>	< 0.79	<b>5.3</b>	<b>1.9 J</b>	<b>1.5 J</b>	< 0.53	< 0.81	<b>7.8</b>	< 0.88	< 0.64	< 0.60	< 0.51	< 1.1	Shallow	62	+, -
WS-009	3/21/2019	POET	<b>18</b>	<b>1.0 J</b>	< 0.76	<b>5.8</b>	<b>1.8 J</b>	<b>1.7 J</b>	< 0.50	< 0.78	<b>8.4</b>	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	Shallow	62	+, -
WS-013	3/8/2019	POET	<b>3.4 J</b>	<b>1.0 J</b>	<b>2.1</b>	< 1.2	<b>0.71 J</b>	< 0.43	< 0.49	< 0.76	<b>2.0</b>	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Shallow	15	-
WS-013	3/18/2019	POET	<b>5.4 J</b>	< 0.92	<b>9.7</b>	<b>2.1 J</b>	<b>0.69 J</b>	< 0.45	< 0.51	< 0.79	<b>4.9</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	15	-
WS-014	2/26/2019	Winter	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.72	< 0.25	< 0.78	< 0.57	< 0.52	< 0.45	< 0.96	Deep	264	+, -
WS-019	1/7/2019	POET	<b>110</b>	<b>16</b>	<b>1.8 J</b>	<b>40</b>	<b>16</b>	<b>13</b>	<b>1.2 J</b>	< 0.75	<b>57 J</b>	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	Shallow	20	-
WS-019	1/15/2019	POET	<b>100</b>	<b>17</b>	<b>2.2</b>	<b>41</b>	<b>16</b>	<b>13</b>	<b>1.1 J</b>	< 0.83	<b>55</b>	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	Shallow	20	-
WS-019	2/4/2019	POET	<b>110</b>	<b>17</b>	<b>1.9</b>	<b>42</b>	<b>17</b>	<b>13</b>	<b>1.1 J</b>	< 0.77	<b>57</b>	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	20	-
WS-019	3/5/2019	POET	<b>110</b>	<b>17</b>	<b>2.0</b>	<b>45</b>	<b>18</b>	<b>14</b>	<b>1.3 J</b>	< 0.74	<b>59</b>	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Shallow	20	-
WS-019	3/29/2019	POET	<b>100</b>	<b>18</b>	<b>2.1</b>	<b>40</b>	<b>16</b>	<b>15</b>	<b>1.2 J</b>	< 0.70	<b>51</b>	< 0.76	< 0.56	< 0.52	< 0.44	< 0.94	Shallow	20	-
WS-022	3/20/2019	Winter	< 2.4	< 0.85	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA	NA	NA
WS-022 DUP	3/20/2019	Winter	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA	NA	NA
WS-023	1/15/2019	POET	<b>5.2 J</b>	< 0.91	< 0.77	<b>1.4 J</b>	<b>0.65 J</b>	<b>0.46 J</b>	< 0.51	< 0.78	<b>3.7</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Deep	100	-
WS-024	3/14/2019	POET	<b>18</b>	<b>2.0</b>	<b>15</b>	<b>5.4</b>	<b>2.8</b>	<b>0.68 J</b>	< 0.54	< 0.83	<b>19</b>	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	Shallow	<20	-
WS-024	3/28/2019	POET	<b>14</b>	<b>1.3 J</b>	<b>19</b>	<b>5.5</b>	<b>2.0</b>	<b>0.45 J</b>	< 0.45	< 0.70	<b>18</b>	< 0.76	< 0.55	< 0.51	< 0.43	< 0.93	Shallow	<20	-
WS-025	1/21/2019	POET	<b>28</b>	< 0.92	< 0.78	<b>11</b>	<b>1.9</b>	< 0.46	< 0.52	< 0.80	<b>19</b>	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	Shallow	30-40	-
WS-025	2/25/2019	POET	<b>26</b>	< 0.88	< 0.74	<b>10</b>	<b>1.6 J</b>	< 0.44	< 0.49	< 0.76	<b>16</b>	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	30-40	-
WS-026	2/28/2019	Winter	< 2.7	< 0.96	< 0.81	< 1.3	< 0.64	< 0.47	< 0.53	< 0.83	< 0.29	< 0.90	< 0.65	< 0.60	< 0.51	< 1.1	NA	NA	NA
WS-027	2/28/2019	Winter	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Deep	110	+
WS-030	1/14/2019	POET	<b>44</b>	< 0.92	< 0.77	<b>10</b>	<b>0.72 J</b>	< 0.45	< 0.51	< 0.79	<b>9.7</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	28	+, -
WS-030	3/19/2019	POET	<b>74</b>	< 0.85	< 0.71	<b>8.7</b>	<b>0.66 J</b>	< 0.42	< 0.47	< 0.73	<b>10</b>	< 0.79	< 0.58	< 0.54	< 0.45	< 0.98	Shallow	28	+, -
WS-031	3/4/2019	Winter	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA	NA	NA
WS-031 DUP	3/4/2019	Winter	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	NA	NA	NA
WS-032	2/28/2019	POET	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA	NA	NA
WS-033	3/4/2019	Winter	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	Deep	125	+
WS-034	2/27/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Shallow	NA	NA
WS-036	1/3/2019	POET	<b>72</b>	<b>14</b>	<b>1.1 J</b>	<b>14</b>	<b>6.8</b>	<b>6.6</b>	< 0.49	< 0.76	<b>25</b>	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	<30	-
WS-036	3/20/2019	POET	<b>53</b>	<b>12</b>	<b>1.3 J</b>	<b>10</b>	<b>4.9</b>	<b>5.5</b>	< 0.49	< 0.76	<b>18</b>	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	<30	-
WS-037	2/13/2019	POET	<b>19</b>	<b>2.2</b>	< 0.77	<b>41</b>	<b>1.3 J</b>	< 0.46	< 0.51	< 0.79	<b>120</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	23	-

TOWN OF PESHTIGO FINAL WINTER 2019 WATER SAMPLE RESULTS - JANUARY 1 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	Type of Sample	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	General Well Depth	Detailed Well Depth	Source
WS-037	3/19/2019	POET	19	1.1 J	< 0.71	43	0.89 J	< 0.42	< 0.47	< 0.73	110	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	Shallow	23	-
WS-038	1/14/2019	POET	28	< 0.91	1.8 J	3.4	0.65 J	< 0.45	< 0.51	< 0.78	6.1	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Shallow	28	+ , -
WS-038	2/5/2019	POET	32	1.1 J	1.5 J	3.7	0.78 J	< 0.45	< 0.51	< 0.78	7.2	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Shallow	28	+ , -
WS-038	2/19/2019	POET	32	0.99 J	1.7 J	3.8	0.66 J	< 0.47	< 0.53	< 0.81	7.4	< 0.88	< 0.64	< 0.60	< 0.51	< 1.1	Shallow	28	+ , -
WS-038	3/14/2019	POET	33	1.0 J	1.5 J	3.5	0.78 J	< 0.45	< 0.51	< 0.78	6.5	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Shallow	28	+ , -
WS-038	3/27/2019	POET	35	0.84 J	1.4 J	3.3	0.62 J	< 0.41	< 0.46	< 0.72	5.9	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	Shallow	28	+ , -
WS-040	2/27/2019	Winter	< 2.3	< 0.82	< 0.69	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	Deep	124	+
WS-043	2/26/2019	Winter	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA	NA	NA
WS-044	3/5/2019	Winter	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.80	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	28	-
WS-044 DUP	3/5/2019	Winter	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	28	-
WS-045	3/4/2019	Winter	< 2.4	< 0.84	< 0.71	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	Deep	180	-
WS-049	1/7/2019	POET	5.4	2.3	1.5 J	2.2 J	1.8	< 0.42	< 0.47	< 0.73	3.9	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Shallow	24	+
WS-049	1/21/2019	POET	5.8	3.2	1.9	2.4 J	1.8 J	< 0.44	< 0.50	< 0.77	5.2	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	24	+
WS-050	3/5/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Deep	90	-
WS-051	2/26/2019	Winter	< 2.8	< 0.97	< 0.82	< 1.3	< 0.66	< 0.48	< 0.54	< 0.84	< 0.30	< 0.91	< 0.67	< 0.61	< 0.52	< 1.1	Deep	107	+ , -
WS-052	1/8/2019	POET	190	17	4.0	59	43	20	< 0.49	< 0.76	110	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	22	-
WS-052	2/12/2019	POET	250	23	5.1	80	55	29	< 0.51	< 0.79	160	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Shallow	22	-
WS-052	3/7/2019	POET	330	33	6.9	110	86	45	< 0.51	< 0.79	200	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Shallow	22	-
WS-053	2/4/2019	POET	3.8 J	< 0.87	0.93 J	< 1.2	1.6 J	< 0.43	< 0.48	< 0.75	1.6 J	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	Shallow	30	+ , -
WS-054	1/14/2019	POET	130	< 0.91	< 0.77	4.7	1.8 J	1.1 J	< 0.51	< 0.79	19	< 0.86	< 0.62	< 0.58	< 0.49	< 1.1	NA	NA	NA
WS-054	2/18/2019	POET	120	< 0.89	< 0.75	4.5	1.8 J	1.0 J	< 0.49	< 0.77	18	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA	NA	NA
WS-054	3/12/2019	POET	120	< 0.97	< 0.82	4.7	1.8 J	0.92 J	< 0.54	< 0.84	18	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA	NA	NA
WS-057	1/3/2019	POET	53	21	2.1	17	10	3.3	< 0.46	< 0.71	27	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	Shallow	NA	NA
WS-057	2/6/2019	POET	54	24	1.9	19	9.5	4.1	< 0.49	< 0.76	28	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	NA	NA
WS-058	2/6/2019	POET	350	20	3.3	190	54	24	< 0.50	< 0.77	320	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	NA	NA
WS-058	3/4/2019	POET	350	51	3.1	180	60	21	1.8	< 0.73	300	< 0.79	< 0.58	< 0.53	< 0.45	< 0.97	Shallow	NA	NA
WS-058	3/19/2019	POET	370	53	3.8	190	58	22	2.0	< 0.84	310	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	Shallow	NA	NA
WS-061B	1/2/2019	POET	27	1.6 J	1.2 J	10	4.4	1.1 J	< 0.52	< 0.80	18	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	Shallow	NA	NA
WS-061B	2/4/2019	POET	31	2.0	1.5 J	14	5.6	1.5 J	< 0.49	< 0.76	21	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	NA	NA
WS-063	2/27/2019	Winter	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	Deep	124	+ , -
WS-065	3/19/2019	Winter	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	Deep	95	+ , -
WS-066	2/27/2019	Winter	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	Deep	77	+ , -
WS-066 DUP	2/27/2019	Winter	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	Deep	77	+ , -

TOWN OF PESHTIGO FINAL WINTER 2019 WATER SAMPLE RESULTS - JANUARY 1 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	Type of Sample	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDoA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	General Well Depth	Detailed Well Depth	Source
WS-067	3/7/2019	Winter	3.6 J	2.7	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA	NA	NA
WS-068	1/15/2019	POET	67	< 0.93	0.99 J	20	12	< 0.46	< 0.52	< 0.80	38	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	Shallow	30	-
WS-068	2/25/2019	POET	67	< 0.90	1.0 J	22	12	< 0.44	< 0.50	< 0.78	40	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	Shallow	30	-
WS-071	3/6/2019	Winter	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	Shallow	40	-
WS-072	2/26/2019	Winter	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA	NA	NA
WS-073	2/26/2019	Winter	< 2.6	0.95 J	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.62	< 0.58	< 0.49	< 1.1	Deep	110	+, -
WS-075	3/5/2019	Winter	< 2.4	< 0.84	< 0.71	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	Deep	80	-
WS-078	2/28/2019	Winter	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	Deep	129	+, -
WS-079	2/28/2019	Winter	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	Deep	97	+, -
WS-083	3/18/2019	Winter	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.72	< 0.25	< 0.78	< 0.57	< 0.52	< 0.45	< 0.96	Deep	400	-
WS-084	2/27/2019	Winter	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	Deep	122	+, -
WS-086	3/19/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA	NA	NA
WS-087	3/4/2019	Winter	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	15-20	-
WS-088	3/4/2019	Winter	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	Shallow	25	-
WS-090	1/8/2019	POET	19	< 0.86	< 0.73	2.5 J	1.7 J	< 0.43	< 0.48	< 0.74	4.1	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	Shallow	31	+, -
WS-090	1/21/2019	POET	41	< 0.91	< 0.77	4.5	3.0	0.52 J	< 0.51	< 0.79	9.2	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	31	+, -
WS-090	2/13/2019	POET	130	< 0.91	< 0.77	14	9.6	0.95 J	< 0.51	< 0.79	26	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	Shallow	31	+, -
WS-090	2/26/2019	POET	170	< 0.90	< 0.76	16	13	1.3 J	< 0.50	< 0.78	30	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	Shallow	31	+, -
WS-090	3/13/2019	POET	190	1.2 J	0.77 J	18	16	1.8 J	< 0.49	< 0.76	30	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	31	+, -
WS-094	3/8/2019	Winter	2.6 J	< 0.90	< 0.76	3.0	< 0.61	< 0.45	< 0.50	< 0.78	2.6	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	Shallow	NA	NA
WS-096	1/3/2019	POET	62	3.2	0.76 J	8.4	5.9	1.5 J	< 0.48	< 0.74	14	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Shallow	27	-
WS-096	2/5/2019	POET	65	4.0	< 0.74	9.3	5.9	1.8 J	< 0.49	< 0.76	16	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	27	-
WS-096	2/26/2019	POET	61	3.1	< 0.72	8.9	5.7	1.5 J	< 0.48	< 0.74	15	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Shallow	27	-
WS-097	1/15/2019	POET	3.0 J	< 0.88	0.87 J	1.3 J	0.61 J	< 0.44	< 0.49	< 0.76	2.1	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	NA	NA
WS-097	2/25/2019	POET	3.0 J	< 0.90	0.99 J	1.5 J	0.66 J	< 0.45	< 0.50	< 0.78	2.5	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	Shallow	NA	NA
WS-099	1/22/2019	POET	5.3 J	2.8	0.92 J	1.5 J	1.1 J	< 0.45	< 0.51	< 0.79	3.8	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	18	-
WS-099	3/25/2019	POET	5.3 J	2.7	1.7 J	1.9 J	0.81 J	< 0.42	< 0.48	< 0.74	5.3	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	Shallow	18	-
WS-100	2/26/2019	POET	2.9 J	< 0.87	< 0.73	1.2 J	0.60 J	< 0.43	< 0.49	< 0.75	3.2	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Shallow	NA	NA
WS-100	3/28/2019	POET	< 2.3	< 0.80	< 0.67	< 1.1	< 0.54	< 0.40	< 0.45	< 0.69	1.4 J	< 0.75	< 0.55	< 0.51	< 0.43	< 0.93	Shallow	NA	NA
WS-102	3/4/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Shallow	NA	NA
WS-104	3/27/2019	Winter	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Deep	>100	-
WS-106	1/30/2019	POET	2.7 J	< 0.83	< 0.69	< 1.1	0.57 J	< 0.41	< 0.46	< 0.71	0.75 J	< 0.77	< 0.56	< 0.52	< 0.44	< 0.96	Shallow	18	-
WS-106	2/25/2019	POET	< 1.8	< 0.64	< 0.54	< 0.88	< 0.43	< 0.32	< 0.36	< 0.55	< 0.20	< 0.60	< 0.44	< 0.41	< 0.34	< 0.74	Shallow	18	-

TOWN OF PESHTIGO FINAL WINTER 2019 WATER SAMPLE RESULTS - JANUARY 1 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	Type of Sample	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDoA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	General Well Depth	Detailed Well Depth	Source
WS-108	2/27/2019	Winter	< 2.3	< 0.81	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA	NA	NA
WS-108 DUP	2/27/2019	Winter	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA	NA	NA
WS-109	2/11/2019	POET	<b>13</b>	<b>5.0</b>	<b>2.0</b>	<b>3.6</b>	<b>1.4 J</b>	<b>0.68 J</b>	< 0.50	< 0.77	<b>3.9</b>	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	NA	NA
WS-109	3/29/2019	POET	<b>12</b>	<b>6.4</b>	<b>1.3 J</b>	<b>3.3</b>	<b>1.4 J</b>	<b>0.87 J</b>	< 0.46	< 0.71	<b>2.7</b>	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	Shallow	NA	NA
WS-110A	3/5/2019	Winter	< 2.5	<b>1.1 J</b>	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	Deep	88	+, -
WS-111	1/30/2019	POET	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	<b>0.57 J</b>	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	Shallow	17	-
WS-113	2/27/2019	Winter	< 2.3	< 0.81	< 0.68	< 1.1	< 0.54	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.43	< 0.94	Deep	100	+, -
WS-115	1/30/2019	POET	< 2.7	< 0.94	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.88	< 0.65	< 0.60	< 0.51	< 1.1	Shallow	NA	NA
WS-116	3/19/2019	Winter	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA	NA	NA
WS-116 DUP	3/19/2019	Winter	< 2.8	< 0.98	< 0.82	< 1.3	< 0.66	< 0.48	< 0.55	< 0.84	< 0.30	< 0.92	< 0.67	< 0.62	< 0.53	< 1.1	NA	NA	NA
WS-119	3/5/2019	Winter	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.80	< 0.28	< 0.86	< 0.63	< 0.58	< 0.50	< 1.1	NA	NA	NA
WS-120	3/25/2019	Winter	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.48	< 0.75	< 0.27	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	Deep	127	-
WS-120 DUP	3/25/2019	Winter	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Deep	127	-
WS-121A	2/12/2019	POET	<b>7.1</b>	<b>3.0</b>	<b>1.4 J</b>	<b>2.3 J</b>	<b>1.2 J</b>	< 0.44	< 0.50	< 0.77	<b>2.6</b>	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	Shallow	NA	NA
WS-121B	1/2/2019	POET	<b>2.8 J</b>	<b>1.7</b>	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	<b>2.1</b>	< 0.78	< 0.57	< 0.52	< 0.44	< 0.96	Shallow	NA	NA
WS-121B	2/12/2019	POET	<b>3.0 J</b>	<b>1.6 J</b>	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	<b>2.4</b>	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	Shallow	NA	NA
WS-122	3/11/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	<b>1.1 J</b>	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	Shallow	20	-
WS-123	3/11/2019	Winter	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	Deep	98	+, -
WS-126	2/25/2019	POET	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	Shallow	32	+
WS-130	3/13/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Deep	465	+, -
WS-130 DUP	3/13/2019	Winter	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.27	< 0.84	< 0.62	< 0.57	<b>0.55 J</b>	< 1.0	Deep	465	+, -
WS-131	1/30/2019	Winter	< 2.7	< 0.95	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	<b>1.3 J</b>	< 0.89 UJ	< 0.65 UJ	< 0.60	< 0.51	< 1.1	Shallow	28-30	-
WS-131 DUP	1/30/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	<b>1.1 J</b>	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	28-30	-
WS-132	3/6/2019	Winter	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	Shallow	21	-
WS-133	3/26/2019	POET	<b>5.8</b>	<b>1.0 J</b>	<b>0.97 J</b>	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	<b>1.0 J</b>	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA	NA	NA
WS-138	3/6/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	Deep	116	+, -
WS-139	3/4/2019	Winter	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	Deep	112	-
WS-142	3/11/2019	Winter	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	Deep	122	+
WS-142 DUP	3/11/2019	Winter	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	Deep	122	+
WS-150	3/4/2019	Winter	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA	NA	NA
WS-152	2/26/2019	Winter	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Shallow	28	+, -
WS-153	3/19/2019	Winter	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	Shallow	25	-
WS-156	2/26/2019	Winter	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	Deep	550	+, -

**TOWN OF PESHTIGO FINAL WINTER 2019 WATER SAMPLE RESULTS - JANUARY 1 THROUGH MARCH 31, 2019**

**NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.**

Location	Sample Date	Type of Sample	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDoA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	General Well Depth	Detailed Well Depth	Source
WS-158	1/8/2019	Winter	<b>130</b>	<b>9.2</b>	< 0.72	<b>110</b>	<b>5.4</b>	<b>3.2</b>	< 0.48	< 0.74	<b>190</b>	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	Shallow	15-18	-
WS-159	1/8/2019	Winter	<b>25</b>	<b>1.1 J</b>	<b>0.81 J</b>	<b>5.6</b>	<b>0.82 J</b>	< 0.42	< 0.47	< 0.73	<b>7.2</b>	< 0.79	< 0.58	< 0.53	< 0.45	< 0.97	Shallow	NA	NA
WS-159 DUP	1/8/2019	Winter	<b>23</b>	< 0.86	<b>0.82 J</b>	<b>4.6</b>	<b>0.80 J</b>	< 0.43	< 0.48	< 0.75	<b>6.7</b>	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	Shallow	NA	NA
WS-160	2/25/2019	Winter	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	Shallow	NA	NA
WS-160 DUP	2/25/2019	Winter	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.46	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	Shallow	NA	NA
WS-161	3/6/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	Shallow	NA	NA
WS-162	3/26/2019	Winter	< 2.5	< 0.87	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA	NA	NA
WS-162 DUP	3/26/2019	Winter	< 2.5	< 0.88	< 0.74	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.61	< 0.56	< 0.47	< 1.0	NA	NA	NA

**Notes:**

- = Information gathered from sampling log according to homeowners

+ = Information gathered from well construction form

+, - = Information gathered from well construction form, but information also available from sampling log

Detailed well depth in feet

Detections are boldfaced

POET (Point of Entry Treatment) = Sample collected as part of the POET system monitoring program

Winter = Sample collected as part of the Winter 2019 sampling event

< = Compound not detected at method detection limit

D = Dilution required for sample analysis

J = The compound was positively identified; however, the associated numerical value is an estimated concentration only

UB = Compound considered non-detect at the listed value due to associated blank contamination

UJ = The compound was not detected above the reported sample method detection limit; however, the reported limit is approximate and may or may not represent the actual method detection limit

DUP = Duplicate sample result

NA = Not available

PFOA = Perfluorooctanoic acid (C8)

PFOS = Perfluorooctanesulfonic acid (C8)

PFBS = Perfluorobutanesulfonic acid (C4)

PFHpA = Perfluoroheptanoic acid (C7)

PFHxS = Perfluorohexanesulfonic acid (C6)

PFNA = Perfluorononanoic acid (C9)

PFDA = Perfluorodecanoic acid (C10)

PFDoA = Perfluorododecanoic acid (C12)

PFHxA = Perfluorohexanoic acid (C6)

PFTeA = Perfluorotetradecanoic acid (C14)

PFTriA = Perfluorotridecanoic acid (C13)

PFUnA = Perfluoroundecanoic acid (C11)

EtFOSAA = Ethylperfluorooctane sulfonamido acetate (C10)

MeFOSAA = Methylperfluorooctane sulfonamido acetate (C9)

Units are in ng/L (nanogram per liter)

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-058	11/9/2018	320	48	3.7	160	55	19	2.0	< 0.83	300	< 0.90	< 0.66	< 0.60	< 0.51	1.3 J	NA
WS-058	2/6/2019	350	20	3.3	190	54	24	< 0.50	< 0.77	320	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-058	3/4/2019	350	51	3.1	180	60	21	1.8	< 0.73	300	< 0.79	< 0.58	< 0.53	< 0.45	< 0.97	0.24 J
WS-058	3/19/2019	370	53	3.8	190	58	22	2.0	< 0.84	310	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	0.39 J
POET-1-MID	11/9/2018	< 2.6	< 0.91	< 0.77	< 1.2	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.62	< 0.58	< 0.49	< 1.1	NA
POET-1-MID	2/6/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	0.34 J	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-1-MID	3/4/2019	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.72	< 0.25	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	< 0.15
POET-1-MID DUP	3/4/2019	< 2.5	< 0.90	< 0.76	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-1-MID	3/19/2019	< 2.9	< 1.0	< 0.85	< 1.4	< 0.68	< 0.50	< 0.56	< 0.87	< 0.31	< 0.95	< 0.69	< 0.64	< 0.54	< 1.2	< 0.15
POET-1-MID DUP	3/19/2019	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-1-POST	11/9/2018	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-1-POST	2/6/2019	11	< 0.86	< 0.73	7.3	1.8	< 0.43	< 0.48	< 0.74	14	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-1-POST	3/4/2019	3.8 J	< 0.88	< 0.74	1.8 J	0.59 J	< 0.44	< 0.49	< 0.76	2.8	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	2.4
POET-1-POST	3/19/2019	< 2.4	< 0.85	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	0.52 J
WS-052	11/9/2018	210	16	4.5	64	51	23	< 0.49	< 0.76	130	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-052	1/8/2019	190	17	4.0	59	43	20	< 0.49	< 0.76	110	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-052	2/12/2019	250	23	5.1	80	55	29	< 0.51	< 0.79	160	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	0.62 J
WS-052	3/7/2019	330	33	6.9	110	86	45	< 0.51	< 0.79	200	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	< 0.15
POET-2-MID	11/9/2018	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	2.2	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-2-MID	1/8/2019	4.3 J	< 0.86	< 0.73	1.4 J	0.67 J	< 0.43	< 0.48	< 0.74	4.7	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-2-MID	2/12/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	< 0.15
POET-2-MID	3/7/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.81	< 0.60	< 0.55	0.58 J	< 1.0	NA
POET-2-MID	3/7/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	< 0.15
POET-2-POST	11/9/2018	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.80	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-2-POST	1/8/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-2-POST	2/12/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.27	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	2.2
POET-2-POST	3/7/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	< 0.15
WS-036	10/10/2018	120	24	1.5 J	25	11	14 J	0.76 J	< 0.83	46	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	0.39 J
WS-036	10/24/2018	99	21 J	1.1 J	19 J	9.5 J	11 J	0.56 J	< 0.75	34 J	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDoA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-036	11/19/2018	76 D	23	1.2 J	18	8	9.8	0.7 J	< 0.47	30	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	NA
WS-036	1/3/2019	72	14	1.1 J	14	6.8	6.6	< 0.49	< 0.76	25	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-036	3/20/2019	53	12	1.3 J	10	4.9	5.5	< 0.49	< 0.76	18	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-3-MID	10/10/2018	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	< 0.15
POET-3-MID	10/24/2018	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-3-MID	11/19/2018	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	NA
POET-3-MID	1/3/2019	< 2.7	< 0.94	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.88	< 0.65	< 0.60	< 0.51	< 1.1	NA
POET-3-MID	3/20/2019	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-3-POST	10/10/2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.32 J
POET-3-POST	11/19/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-3-POST	1/3/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-3-POST	3/20/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POST-3-POST	10/24/2018	< 2.2	< 0.76	< 0.64	< 1.0	< 0.51	< 0.38	< 0.43	< 0.66	< 0.23	< 0.72	< 0.52	< 0.48	< 0.41	< 0.88	NA
WS-090	10/17/2018	4.1 J	< 0.97	< 0.82	< 1.3	< 0.66	< 0.48	< 0.54	< 0.84	< 0.30	< 0.91	< 0.67	< 0.62	< 0.52	< 1.1	NA
WS-090	11/19/2018	15	< 0.5	< 0.5	1.2 J	1 J	< 0.5	< 0.5	< 0.5	2.3	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	NA
WS-090	1/8/2019	19	< 0.86	< 0.73	2.5 J	1.7 J	< 0.43	< 0.48	< 0.74	4.1	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	0.27 J
WS-090	1/21/2019	41	< 0.91	< 0.77	4.5	3.0	0.52 J	< 0.51	< 0.79	9.2	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	0.30 J
WS-090	2/13/2019	130	< 0.91	< 0.77	14	9.6	0.95 J	< 0.51	< 0.79	26	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	0.15 J
WS-090	2/26/2019	170	< 0.90	< 0.76	16	13	1.3 J	< 0.50	< 0.78	30	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	NA
WS-090	3/13/2019	190	1.2 J	0.77 J	18	16	1.8 J	< 0.49	< 0.76	30	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	0.24 J
POET-4-MID	10/17/2018	< 2.8	< 0.97	< 0.82	< 1.3	< 0.66	< 0.48	< 0.54	< 0.84	< 0.30	< 0.91	< 0.67	< 0.62	< 0.52	< 1.1	NA
POET-4-MID	11/19/2018	5.8	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	0.87 J	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-4-MID DUP	11/19/2018	6.5	< 0.46	< 0.46	0.53 J	< 0.46	< 0.46	< 0.46	< 0.46	1.1 J	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-4-MID	1/8/2019	3.1 J	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	0.64 J	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	< 0.15
POET-4-MID	1/21/2019	22	< 0.92	< 0.77	2.5 J	1.7 J	< 0.45	< 0.51	< 0.79	4.4	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	0.19 J
POET-4-MID	2/13/2019	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	0.85 J
POET-4-MID	2/26/2019	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-4-MID DUP	2/26/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-4-MID	3/13/2019	< 2.6	< 0.91	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	< 0.15



TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-4-POST	10/17/2018	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-4-POST	11/19/2018	<b>2</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	<b>0.51 J</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-4-POST	1/8/2019	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	<b>3.0</b>
POET-4-POST	1/21/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	< 0.15
POET-4-POST	2/13/2019	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	<b>1.9</b>
POET-4-POST	2/26/2019	< 2.8	< 0.98	< 0.83	< 1.3	< 0.66	< 0.49	< 0.55	< 0.85	< 0.30	< 0.92	< 0.67	< 0.62	< 0.53	< 1.1	NA
POET-4-POST	3/13/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	<b>0.19 J</b>
WS-019	10/17/2018	<b>94</b>	<b>15</b>	<b>3.3</b>	<b>43</b>	<b>18</b>	<b>12</b>	< 0.57	< 0.88	<b>62</b>	< 0.95	< 0.69	< 0.64	< 0.55	< 1.2	NA
WS-019	11/20/2018	<b>87 D</b>	<b>15</b>	<b>2.3</b>	<b>43</b>	<b>17</b>	<b>13</b>	<b>1.1 J</b>	< 0.45	<b>53</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	<b>0.98 J</b>
WS-019	12/10/2018	<b>65 D</b>	<b>15</b>	<b>2.5</b>	<b>38</b>	<b>18</b>	<b>13</b>	<b>0.91 J</b>	< 0.44	<b>48</b>	< 0.44 UJ	< 0.44	< 0.44	< 0.44	< 0.44	<b>0.92 J</b>
WS-019	1/7/2019	<b>110</b>	<b>16</b>	<b>1.8 J</b>	<b>40</b>	<b>16</b>	<b>13</b>	<b>1.2 J</b>	< 0.75	<b>57 J</b>	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA
WS-019	1/15/2019	<b>100</b>	<b>17</b>	<b>2.2</b>	<b>41</b>	<b>16</b>	<b>13</b>	<b>1.1 J</b>	< 0.83	<b>55</b>	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	<b>0.75 J</b>
WS-019	2/4/2019	<b>110</b>	<b>17</b>	<b>1.9</b>	<b>42</b>	<b>17</b>	<b>13</b>	<b>1.1 J</b>	< 0.77	<b>57</b>	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	<b>0.71 J</b>
WS-019	3/5/2019	<b>110</b>	<b>17</b>	<b>2.0</b>	<b>45</b>	<b>18</b>	<b>14</b>	<b>1.3 J</b>	< 0.74	<b>59</b>	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
WS-019	3/29/2019	<b>100</b>	<b>18</b>	<b>2.1</b>	<b>40</b>	<b>16</b>	<b>15</b>	<b>1.2 J</b>	< 0.70	<b>51</b>	< 0.76	< 0.56	< 0.52	< 0.44	< 0.94	<b>1.5</b>
POET-5-MID	10/17/2018	<b>13</b>	<b>2.2</b>	< 0.85	<b>5.9</b>	<b>2.2</b>	<b>1.4 J</b>	< 0.56	< 0.87	<b>8.2</b>	< 0.94	< 0.69	< 0.63	< 0.54	< 1.2	NA
POET-5-MID	11/20/2018	<b>21</b>	<b>3</b>	< 0.46	<b>9.4</b>	<b>2.9</b>	<b>2.4</b>	< 0.46	< 0.46	<b>12</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	<b>0.21 J</b>
POET-5-MID	12/10/2018	<b>26</b>	<b>4.3</b>	<b>0.58 J</b>	<b>10</b>	<b>4.6</b>	<b>3.3</b>	< 0.44	< 0.44	<b>15</b>	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 1.0 UB
POET-5-MID	1/7/2019	<b>8.4</b>	<b>1.2 J</b>	< 0.69	<b>2.9</b>	<b>1.1 J</b>	<b>1.0 J</b>	< 0.46	< 0.71	<b>4.0</b>	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-5-MID	1/15/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	<b>2.4</b>
POET-5-MID	2/4/2019	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	< 0.15
POET-5-MID	3/5/2019	<b>9.5</b>	<b>1.5 J</b>	< 0.72	<b>3.8</b>	<b>1.3 J</b>	<b>1.1 J</b>	< 0.48	< 0.74	<b>5.3</b>	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-5-MID	3/29/2019	<b>17</b>	<b>2.8</b>	< 0.70	<b>6.5</b>	<b>2.6</b>	<b>2.2</b>	< 0.46	< 0.72	<b>8.4</b>	< 0.78	< 0.57	< 0.52	< 0.44	< 0.96	<b>0.94 J</b>
POET-5-POST	10/17/2018	< 2.7	< 0.96	< 0.81	< 1.3	< 0.65	< 0.47	< 0.54	< 0.83	< 0.29	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	NA
POET-5-POST	11/20/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	<b>4.5</b>
POET-5-POST	12/10/2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	< 1.0 UB
POET-5-POST	1/7/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.98	NA
POET-5-POST	1/15/2019	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	<b>1.1</b>
POET-5-POST	2/4/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.40	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	<b>0.16 J</b>

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-5-POST	3/5/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-5-POST	3/29/2019	< 2.3	< 0.81	< 0.68	< 1.1	< 0.54	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.43	< 0.93	4.6
WS-096	10/24/2018	87	2.8	0.78 J	11	6.7	< 0.42	< 0.47	< 0.73	17	< 0.80	< 0.58	< 0.54	< 0.46	< 0.98	NA
WS-096	12/4/2018	60	2.6 J	0.61 J	7.1	5	1.1 J	< 0.45	< 0.45	12 J	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-096	1/3/2019	62	3.2	0.76 J	8.4	5.9	1.5 J	< 0.48	< 0.74	14	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	0.67 J
WS-096	2/5/2019	65	4.0	< 0.74	9.3	5.9	1.8 J	< 0.49	< 0.76	16	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	0.60 J
WS-096	2/26/2019	61	3.1	< 0.72	8.9	5.7	1.5 J	< 0.48	< 0.74	15	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-6-MID	10/24/2018	6.1	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	1.6 J	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-6-MID	12/4/2018	8.1	0.54 J	< 0.44	0.9 J	0.56 J	< 0.44	< 0.44	< 0.44	1.7 J	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-6-MID	1/3/2019	< 2.4	< 0.85	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	0.35 J	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	0.19 J
POET-6-MID	2/5/2019	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	< 0.15
POET-6-MID	2/26/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-6-POST	10/24/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-6-POST	12/4/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-6-POST	1/3/2019	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	1.2
POET-6-POST	2/5/2019	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	< 0.15
POET-6-POST	2/26/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
WS-008	12/4/2018	270 D	14	3.9	95 D	97 D	17	1.2 J	< 0.46	130 D	< 0.46	< 0.46	< 0.46	< 0.46	0.77 J	0.23 J
WS-008	1/22/2019	470 D	23	5.4	140	160	24	1.8 J	< 0.84	190	< 0.91	< 0.66	< 0.61	< 0.52	1.5 J	NA
WS-008	2/18/2019	480 D	20	4.9	140	150	24	1.4 J	< 0.81	190	< 0.88	< 0.65	< 0.60	< 0.51	< 1.1	< 1.0 UB
WS-008	3/28/2019	420 D	21	4.6	110	130	24	2.4	< 0.72	150	< 0.78	< 0.57	< 0.52	0.60 J	< 0.96	NA
POET-7-MID	12/4/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.15
POET-7-MID	1/22/2019	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	0.41 J	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
POET-7-MID	2/18/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	3.3
POET-7-MID DUP	2/18/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-7-MID	3/28/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-7-MID DUP	3/28/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-7-POST	12/4/2018	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	1.5
POET-7-POST	1/22/2019	< 2.6	< 0.91	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-7-POST	2/18/2019	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	2.4
POET-7-POST	3/28/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
WS-013	10/10/2018	16	< 0.87	19	10	1.2 J	< 0.43	< 0.48	< 0.75	25	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA
WS-013	12/4/2018	6.9	0.9 J	7.6	3.4	0.61 J	< 0.45	< 0.45	< 0.45	7	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-013	3/8/2019	3.4 J	1.0 J	2.1	< 1.2	0.71 J	< 0.43	< 0.49	< 0.76	2.0	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	1.0
WS-013	3/18/2019	5.4 J	< 0.92	9.7	2.1 J	0.69 J	< 0.45	< 0.51	< 0.79	4.9	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	0.45 J
POET-10-MID	10/10/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.78	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-10-MID DUP	10/10/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
POET-10-MID	12/4/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-10-MID	3/8/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	4.1
POET-10-MID	3/18/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	0.34 J
POET-10-POST	10/10/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-10-POST	12/4/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-10-POST	3/8/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	2.4
POET-10-POST	3/18/2019	< 2.7	< 0.93	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	0.64 J
WS-024	10/3/2018	22	1.5 J	8.8	4.4	2.4	< 0.42	< 0.47	< 0.73	10	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
WS-024	3/14/2019	18	2.0	15	5.4	2.8	0.68 J	< 0.54	< 0.83	19	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	0.18 J
WS-024	3/28/2019	14	1.3 J	19	5.5	2.0	0.45 J	< 0.45	< 0.70	18	< 0.76	< 0.55	< 0.51	< 0.43	< 0.93	NA
POET-11-MID	10/3/2018	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.72	< 0.25	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	NA
POET-11-MID	3/14/2019	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	3.5
POET-11-MID DUP	3/14/2019	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-11-MID	3/28/2019	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.44	< 0.94	NA
POET-11-POST	10/3/2018	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-11-POST	3/14/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	0.48 J	< 1.0	4.6
POET-11-POST	3/28/2019	< 2.3	< 0.80	< 0.67	< 1.1	< 0.54	< 0.39	< 0.44	< 0.69	< 0.24	< 0.75	< 0.54	< 0.50	< 0.43	< 0.92	NA
WS-068	10/15/2018	24	< 0.97	< 0.82	6.5	3.8	< 0.48	< 0.54	< 0.84	14	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA
WS-068	1/15/2019	67	< 0.93	0.99 J	20	12	< 0.46	< 0.52	< 0.80	38	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
WS-068	2/25/2019	67	< 0.90	1.0 J	22	12	< 0.44	< 0.50	< 0.78	40	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-12-MID	10/15/2018	< 2.7	< 0.96	< 0.81	< 1.3	< 0.65	< 0.48	< 0.54	< 0.83	< 0.29	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-12-MID	1/15/2019	< 2.6	< 0.91	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	<b>0.78 J</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-12-MID	2/25/2019	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.47	< 0.53	< 0.81	< 0.29	< 0.88	< 0.64	< 0.60	< 0.51	< 1.1	NA
POET-12-POST	10/15/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-12-POST	1/15/2019	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-12-POST	2/25/2019	< 2.8	< 0.98	< 0.82	< 1.3	< 0.66	< 0.48	< 0.54	< 0.84	< 0.30	< 0.91	< 0.67	< 0.62	< 0.52	< 1.1	NA
WS-097	10/15/2018	<b>4.1 J</b>	< 0.97	<b>1.0 J</b>	<b>1.8 J</b>	<b>0.82 J</b>	< 0.48	< 0.54	< 0.84	<b>3.5</b>	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA
WS-097	11/13/2018	<b>2.9 J</b>	< 0.86	<b>0.93 J</b>	< 1.2	<b>0.67 J</b>	< 0.42	< 0.48	< 0.74	<b>2.2</b>	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
WS-097	1/15/2019	<b>3.0 J</b>	< 0.88	<b>0.87 J</b>	<b>1.3 J</b>	<b>0.61 J</b>	< 0.44	< 0.49	< 0.76	<b>2.1</b>	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
WS-097	2/25/2019	<b>3.0 J</b>	< 0.90	<b>0.99 J</b>	<b>1.5 J</b>	<b>0.66 J</b>	< 0.45	< 0.50	< 0.78	<b>2.5</b>	< 0.85	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-13-MID	10/15/2018	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-13-MID	11/13/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
POET-13-MID	1/15/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	<b>0.81 J</b>	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-13-MID	2/25/2019	< 2.4	< 0.85	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.54	< 0.46	< 0.98	NA
POET-13-POST	10/15/2018	< 2.7	< 0.93	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-13-POST	11/13/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.54	< 0.40	< 0.45	< 0.70	< 0.25	< 0.75	< 0.55	< 0.51	< 0.43	< 0.93	NA
POET-13-POST	1/15/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-13-POST	2/25/2019	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	NA
WS-023	10/10/2018	<b>6.3</b>	< 0.86	< 0.72	<b>2.0 J</b>	<b>0.97 J</b>	< 0.42	< 0.48	< 0.74	<b>4.9</b>	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
WS-023	1/15/2019	<b>5.2 J</b>	< 0.91	< 0.77	<b>1.4 J</b>	<b>0.65 J</b>	<b>0.46 J</b>	< 0.51	< 0.78	<b>3.7</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
POET-14-MID	10/10/2018	< 2.3	< 0.80	< 0.67	< 1.1	< 0.54	< 0.40	< 0.45	< 0.69	< 0.24	< 0.75	< 0.55	< 0.51	< 0.43	< 0.93	NA
POET-14-MID	1/15/2019	< 2.5 UJ	< 0.90 UJ	< 0.75 UJ	< 1.2 UJ	< 0.60 UJ	< 0.44 UJ	< 0.50 UJ	< 0.77 UJ	< 0.27 UJ	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-14-POST	10/10/2018	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-14-POST	1/15/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.59	< 0.50	< 1.1	NA
WS-099	10/15/2018	<b>7.7</b>	<b>2.3</b>	<b>4.1</b>	<b>8.7</b>	<b>1.2 J</b>	< 0.47	< 0.53	< 0.82	<b>44</b>	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA
WS-099	12/4/2018	<b>5.9</b>	<b>1.1 J</b>	<b>1.8 J</b>	<b>2.4</b>	<b>0.99 J</b>	< 0.47	< 0.47	< 0.47	<b>6.6</b>	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	NA
WS-099	1/22/2019	<b>5.3 J</b>	<b>2.8</b>	<b>0.92 J</b>	<b>1.5 J</b>	<b>1.1 J</b>	< 0.45	< 0.51	< 0.79	<b>3.8</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-099	3/25/2019	<b>5.3 J</b>	<b>2.7</b>	<b>1.7 J</b>	<b>1.9 J</b>	<b>0.81 J</b>	< 0.42	< 0.48	< 0.74	<b>5.3</b>	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-15-MID	10/15/2018	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-15-MID DUP	10/15/2018	< 2.7	< 0.95	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-15-MID	12/4/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-15-MID DUP	12/4/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-15-MID	1/22/2019	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-15-MID	3/25/2019	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.72	< 0.25	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	NA
POET-15-POST	10/15/2018	< 2.7	< 0.95	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA
POET-15-POST	12/4/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-15-POST	1/22/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.61	< 0.56	< 0.47	< 1.0	NA
POET-15-POST	3/25/2019	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
WS-121A	10/22/2018	<b>4.6 J</b>	<b>4.0 J</b>	<b>1.0 J</b>	<b>1.3 J</b>	<b>1.0 J</b>	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-121A	2/12/2019	<b>7.1</b>	<b>3.0</b>	<b>1.4 J</b>	<b>2.3 J</b>	<b>1.2 J</b>	< 0.44	< 0.50	< 0.77	<b>2.6</b>	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-16-MID	10/22/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-16-MID DUP	10/22/2018	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.97	NA
POET-16-MID	2/12/2019	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-16-POST	10/22/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-16-POST	2/12/2019	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	<b>0.63 J</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-109	10/15/2018	<b>7.1</b>	<b>1.9 J</b>	<b>1.7 J</b>	<b>5.6</b>	<b>1.1 J</b>	< 0.46	< 0.52	< 0.80	<b>4.7</b>	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
WS-109	2/11/2019	<b>13</b>	<b>5.0</b>	<b>2.0</b>	<b>3.6</b>	<b>1.4 J</b>	<b>0.68 J</b>	< 0.50	< 0.77	<b>3.9</b>	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-109	3/29/2019	<b>12</b>	<b>6.4</b>	<b>1.3 J</b>	<b>3.3</b>	<b>1.4 J</b>	<b>0.87 J</b>	< 0.46	< 0.71	<b>2.7</b>	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	<b>1.6</b>
POET-17-MID	10/15/2018	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-17-MID	2/11/2019	<b>2.8 J</b>	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	<b>1.1 J</b>	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-17-MID DUP	2/11/2019	< 2.4	< 0.84	< 0.70	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	<b>1.1 J</b>	< 0.78	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-17-MID	3/29/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	<b>0.64 J</b>
POET-17-MID DUP	3/29/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-17-POST	10/15/2018	< 2.7	< 0.93	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-17-POST	2/11/2019	< 2.5	< 0.87	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-17-POST	3/29/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	<b>0.71 J</b>
WS-111	10/22/2018	< 2.4	< 0.86	< 0.72	< 1.2	<b>0.95 J</b>	< 0.42	< 0.48	< 0.74	<b>1.8 J</b>	< 0.80	< 0.59	< 0.54	<b>0.79 J</b>	< 0.99	NA
WS-111	1/30/2019	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	<b>0.57 J</b>	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	NA
POET-18-MID	10/22/2018	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.72	< 0.25	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-18-MID	1/30/2019	< 2.7	< 0.93	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-18-POST	10/22/2018	< 2.5	< 0.87	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-18-POST	1/30/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-038	10/4/2018	<b>26</b>	<b>1.6 J</b>	<b>2.5</b>	<b>2.9 J</b>	<b>0.85 J</b>	< 0.47	< 0.53	< 0.82	<b>6.6</b>	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA
WS-038	10/22/2018	<b>23 J</b>	<b>1.3 J</b>	<b>1.1 J</b>	<b>2.4 J</b>	<b>0.65 J</b>	< 0.43	< 0.49	< 0.75	<b>5.2 J</b>	< 0.82	< 0.60	< 0.55	<b>0.50 J</b>	< 1.0	NA
WS-038	11/8/2018	<b>30</b>	<b>0.99 J</b>	<b>1.3 J</b>	<b>2.3 J</b>	< 0.65	< 0.47	< 0.53	< 0.83	<b>5.8</b>	< 0.90	< 0.66	< 0.61	< 0.51	< 1.1	<b>0.51 J</b>
WS-038	12/4/2018	<b>25</b>	<b>0.86 J</b>	<b>0.81 J</b>	<b>1.7 J</b>	< 0.44	< 0.44	< 0.44	< 0.44 UJ	<b>3.9</b>	R	R	< 0.44 UJ	< 0.44 UJ	< 0.44	<b>0.17 J</b>
WS-038	1/14/2019	<b>28</b>	< 0.91	<b>1.8 J</b>	<b>3.4</b>	<b>0.65 J</b>	< 0.45	< 0.51	< 0.78	<b>6.1</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
WS-038	2/5/2019	<b>32</b>	<b>1.1 J</b>	<b>1.5 J</b>	<b>3.7</b>	<b>0.78 J</b>	< 0.45	< 0.51	< 0.78	<b>7.2</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	<b>0.49 J</b>
WS-038	2/19/2019	<b>32</b>	<b>0.99 J</b>	<b>1.7 J</b>	<b>3.8</b>	<b>0.66 J</b>	< 0.47	< 0.53	< 0.81	<b>7.4</b>	< 0.88	< 0.64	< 0.60	< 0.51	< 1.1	< 1.0 UB
WS-038	3/14/2019	<b>33</b>	<b>1.0 J</b>	<b>1.5 J</b>	<b>3.5</b>	<b>0.78 J</b>	< 0.45	< 0.51	< 0.78	<b>6.5</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
WS-038	3/27/2019	<b>35</b>	<b>0.84 J</b>	<b>1.4 J</b>	<b>3.3</b>	<b>0.62 J</b>	< 0.41	< 0.46	< 0.72	<b>5.9</b>	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	<b>0.77 J</b>
POET-19-MID	10/4/2018	<b>17 J</b>	< 0.85	<b>1.5 J</b>	<b>2.5 J</b>	< 0.57	< 0.42	< 0.47	< 0.73	<b>4.5 J</b>	< 0.79	< 0.58	< 0.54	< 0.46	< 0.98	NA
POET-19-MID DUP	10/4/2018	<b>15 J</b>	< 0.85	<b>0.91 J</b>	<b>1.9 J</b>	< 0.57	< 0.42	< 0.48	< 0.74	<b>4.3 J</b>	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-19-MID	10/22/2018	<b>19 J</b>	< 0.83	<b>1.3 J</b>	<b>1.8 J</b>	< 0.56	< 0.41	< 0.46	< 0.71	<b>4.3 J</b>	< 0.77	< 0.57	< 0.52	< 0.44	< 0.96	NA
POET-19-MID	11/8/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	< 0.15
POET-19-MID	12/4/2018	<b>7.4</b>	< 0.44	< 0.44	<b>0.47 J</b>	< 0.44	< 0.44	< 0.44	< 0.44	<b>1.3 J</b>	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.15
POET-19-MID	1/14/2019	<b>17</b>	< 0.93	<b>1.1 J</b>	<b>2.4 J</b>	< 0.63	< 0.46	< 0.52	< 0.80	<b>3.5</b>	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-19-MID	2/5/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	< 0.15
POET-19-MID	2/19/2019	< 2.7	< 0.95	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	< 0.15
POET-19-MID	3/14/2019	<b>9.6</b>	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	<b>1.8 J</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
POET-19-MID	3/27/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.40	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	< 0.15
POET-19-POST	10/4/2018	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-19-POST	10/22/2018	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-19-POST	11/8/2018	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	<b>2.8</b>
POET-19-POST	12/4/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.15
POET-19-POST	1/14/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-19-POST	2/5/2019	<b>4.8 J</b>	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	<b>0.79 J</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	<b>1.9</b>
POET-19-POST	2/19/2019	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	< 0.15

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-19-POST	3/14/2019	< 2.7	< 0.95	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA
POET-19-POST	3/27/2019	< 2.3	< 0.80	< 0.68	< 1.1	< 0.54	< 0.40	< 0.45	< 0.69	< 0.25	< 0.75	< 0.55	< 0.51	< 0.43	< 0.93	3.5
WS-115	10/26/2018	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80 UJ	< 0.59	< 0.54	< 0.46	< 0.99	NA
WS-115	1/30/2019	< 2.7	< 0.94	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.88	< 0.65	< 0.60	< 0.51	< 1.1	NA
POET-20-MID	10/26/2018	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-20-MID DUP	10/26/2018	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-20-MID	1/30/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-20-MID DUP	1/30/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.49	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-20-POST	10/26/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-20-POST	1/30/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.48	< 0.75	< 0.27	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA
WS-053	10/3/2018	4.1 J	< 0.93	0.97 J	< 1.3	1.7 J	< 0.46	< 0.52	< 0.80	1.6 J	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
WS-053	11/5/2018	4.3 J	< 0.92	0.89 J	< 1.3	2.0	< 0.45	< 0.51	< 0.79	1.7 J	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-053	2/4/2019	3.8 J	< 0.87	0.93 J	< 1.2	1.6 J	< 0.43	< 0.48	< 0.75	1.6 J	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-21-MID	10/3/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-21-MID	11/5/2018	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	NA
POET-21-MID	2/4/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-21-POST	10/3/2018	< 2.4	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.57	< 0.52	< 0.44	< 0.96	NA
POET-21-POST	11/5/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.78	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-21-POST	2/4/2019	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
WS-092	10/16/2018	< 2.8	< 0.99	< 0.83	< 1.4	< 0.67	< 0.49	< 0.55	< 0.85	< 0.30	< 0.93	< 0.68	< 0.63	< 0.53	< 1.1	NA
WS-092	11/14/2018	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-22-MID	10/16/2018	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.80	< 0.28	< 0.86	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-22-MID	11/14/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
POET-22-POST	10/16/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.59	< 0.50	< 1.1	NA
POET-22-POST	11/14/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
WS-126	10/16/2018	< 2.8	< 0.99	< 0.84	< 1.4	< 0.67	< 0.49	< 0.55	< 0.86	< 0.30	< 0.93	< 0.68	< 0.63	< 0.53	< 1.2	NA
WS-126	11/14/2018	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
WS-126	2/25/2019	< 2.5	< 0.90	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-23-MID	10/16/2018	< 2.8	< 0.97	< 0.82	< 1.3	< 0.65	< 0.48	< 0.54	< 0.84	< 0.30	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-23-MID	11/14/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-23-MID	2/25/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-23-POST	10/16/2018	< 2.7	< 0.96	< 0.81	< 1.3	< 0.65	< 0.48	< 0.54	< 0.83	< 0.29	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	NA
POET-23-POST	11/14/2018	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-23-POST	2/25/2019	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
WS-100	10/16/2018	< 2.7	< 0.95	< 0.80	< 1.3	<b>0.69 J</b>	< 0.47	< 0.53	< 0.82	< 0.29	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA
WS-100	11/14/2018	<b>2.5 J</b>	< 0.83	< 0.70	<b>1.1 J</b>	< 0.56	< 0.41	< 0.46	< 0.71	<b>2.3</b>	< 0.77	< 0.57	< 0.52	< 0.44	< 0.96	NA
WS-100	2/26/2019	<b>2.9 J</b>	< 0.87	< 0.73	<b>1.2 J</b>	<b>0.60 J</b>	< 0.43	< 0.49	< 0.75	<b>3.2</b>	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
WS-100	3/28/2019	< 2.3	< 0.80	< 0.67	< 1.1	< 0.54	< 0.40	< 0.45	< 0.69	<b>1.4 J</b>	< 0.75	< 0.55	< 0.51	< 0.43	< 0.93	NA
POET-24-MID	10/16/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-24-MID DUP	10/16/2018	< 2.8	< 1.0	< 0.84	< 1.4	< 0.67	< 0.50	< 0.56	< 0.86	< 0.31	< 0.94	< 0.69	< 0.63	< 0.54	< 1.2	NA
POET-24-MID	11/14/2018	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-24-MID	2/26/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	<b>0.93 J</b>	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-24-MID	3/28/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-24-POST	10/16/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-24-POST	11/14/2018	< 2.3	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.57	< 0.52	< 0.44	< 0.96	NA
POET-24-POST	2/26/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.48	< 0.75	< 0.27	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA
POET-24-POST	3/28/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
WS-032	10/25/2018	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
WS-032	11/27/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-032	2/28/2019	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
POET-25-MID	10/25/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-25-MID	11/27/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-25-MID	2/28/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-25-MID DUP	11/27/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-25-POST	10/25/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-25-POST	11/27/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-25-POST	2/28/2019	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.44	< 0.94	NA
WS-009	10/25/2018	<b>16</b>	<b>1.1 J</b>	< 0.71	<b>5.6 J</b>	<b>1.9 J</b>	<b>1.4 J</b>	< 0.47	< 0.72	<b>8.0 J</b>	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA



TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-009	11/20/2018	18	0.91 J	< 0.44	5.8	1.6 J	1.6 J	< 0.44	< 0.44	7.8	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
WS-009	2/28/2019	17	1.0 J	< 0.79	5.3	1.9 J	1.5 J	< 0.53	< 0.81	7.8	< 0.88	< 0.64	< 0.60	< 0.51	< 1.1	NA
WS-009	3/21/2019	18	1.0 J	< 0.76	5.8	1.8 J	1.7 J	< 0.50	< 0.78	8.4	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-26-MID	10/25/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-26-MID DUP	10/25/2018	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-26-MID	11/20/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-26-MID	2/28/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-26-MID	3/21/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-26-MID DUP	3/21/2019	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-26-POST	10/25/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-26-POST	11/20/2018	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	< 0.49	NA
POET-26-POST	2/28/2019	3.3 J	< 0.93	< 0.78	4.2	0.82 J	< 0.46	< 0.52	< 0.80	4.8	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-26-POST	3/21/2019	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
WS-061B	10/3/2018	24 J	< 0.89	1.8 J	11 J	4.5 J	0.93 J	< 0.49	< 0.76	18 J	< 0.83	< 0.61	< 0.56	< 0.48 UJ	< 1.0	NA
WS-061B	10/30/2018	21	< 0.85	1.6 J	8.8	4.1	1.4 J	< 0.47	< 0.73	14	< 0.79	< 0.58	< 0.54	< 0.46	< 0.98	NA
WS-061B	12/4/2018	21	1.4 J	0.99 J	8.3	3.7	0.84 J	< 0.45	< 0.45	13	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-061B	1/2/2019	27	1.6 J	1.2 J	10	4.4	1.1 J	< 0.52	< 0.80	18	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
WS-061B	2/4/2019	31	2.0	1.5 J	14	5.6	1.5 J	< 0.49	< 0.76	21	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-27-MID	10/3/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	0.65 J	< 0.97	NA
POET-27-MID	10/30/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-27-MID	12/4/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-27-MID	1/2/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.96	NA
POET-27-MID	2/4/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.44	< 0.50	< 0.78	< 0.27	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-27-MID DUP	2/4/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-27-POST	10/3/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
POET-27-POST	10/30/2018	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-27-POST	12/4/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
POET-27-POST	1/2/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-27-POST	2/4/2019	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-025	10/1/2018	26	< 0.87	< 0.73	8.9	1.7 J	< 0.43	NA	NA	NA	NA	NA	NA	NA	NA	NA
WS-025	10/8/2018	28	< 0.87	< 0.74	11	2.1	< 0.43	< 0.49	< 0.75	22	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
WS-025	11/14/2018	26	< 0.85	< 0.72	10	1.9	< 0.42	< 0.47	< 0.73	18	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
WS-025	12/10/2018	22	< 0.45	< 0.45	8	1.5 J	< 0.45	< 0.45	< 0.45	16	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-025	1/21/2019	28	< 0.92	< 0.78	11	1.9	< 0.46	< 0.52	< 0.80	19	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
WS-025	2/25/2019	26	< 0.88	< 0.74	10	1.6 J	< 0.44	< 0.49	< 0.76	16	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-28-MID	10/1/2018	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	NA	NA	NA	NA	NA	NA	NA	NA	NA
POET-28-MID	10/8/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA
POET-28-MID	11/14/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-28-MID	12/10/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-28-MID DUP	12/10/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-28-MID	1/21/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.44	< 0.50	< 0.78	< 0.27	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-28-MID DUP	1/21/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.59	< 0.50	< 1.1	NA
POET-28-MID	2/25/2019	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-28-POST	10/8/2018	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-28-POST	11/14/2018	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-28-POST	12/10/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-28-POST	1/21/2019	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.46	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	0.72 J	< 1.1	NA
POET-28-POST	2/25/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
WS-018	10/1/2018	11	< 0.82	1.8	6.0	3.1	0.73 J	NA	NA	NA	NA	NA	NA	NA	NA	NA
WS-018	10/8/2018	15 J	< 0.82	1.9 J	6.7 J	3.6 J	1.2 J	< 0.46	< 0.70	11 J	< 0.76	< 0.56	< 0.52	< 0.44	< 0.95	NA
WS-018	11/8/2018	12	1.1 J	1.6 J	5.9	2.8	1.2 J	< 0.52	< 0.81	9.0	< 0.88	< 0.64	< 0.59	< 0.51	< 1.1	NA
WS-018	12/10/2018	11	1.3 J	1.6 J	5.5	2.4	0.82 J	< 0.45	< 0.45	8.4	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-29-MID	10/1/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	NA	NA	NA	NA	NA	NA	NA	NA	NA
POET-29-MID DUP	10/1/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	NA	NA	NA	NA	NA	NA	NA	NA	NA
POET-29-MID	10/8/2018	< 2.2	< 0.79	< 0.66	< 1.1	< 0.53	< 0.39	< 0.44	< 0.68	< 0.24	< 0.74	< 0.54	< 0.50	< 0.42	< 0.91	NA
POET-29-MID DUP	10/8/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.54	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.43	< 0.94	NA
POET-29-MID	11/8/2018	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.80	< 0.28	< 0.86	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-29-MID	12/10/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-29-POST	10/8/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.54	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.43	< 0.93	NA
POET-29-POST	11/8/2018	< 2.6	< 0.91	< 0.77	< 1.2	< 0.61	< 0.45	< 0.51	< 0.79	< 0.28	< 0.85	< 0.62	< 0.58	< 0.49	< 1.1	NA
POET-29-POST	12/10/2018	< 0.46	<b>0.6 J</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
WS-054	10/3/2018	<b>86</b>	< 0.89	< 0.75	<b>3.6</b>	<b>1.4 J</b>	< 0.44	NA	NA	NA	NA	NA	NA	NA	NA	NA
WS-054	10/9/2018	<b>79</b>	< 0.82	< 0.69	<b>3.3</b>	<b>1.4 J</b>	<b>0.80 J</b>	< 0.46	< 0.70	<b>19</b>	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
WS-054	11/8/2018	<b>100</b>	< 0.94	< 0.79	<b>3.8</b>	<b>1.5 J</b>	<b>0.88 J</b>	< 0.52	< 0.81	<b>18</b>	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	NA
WS-054	12/5/2018	<b>71 D</b>	< 0.45	< 0.45	<b>3.5</b>	<b>1.2 J</b>	<b>0.59 J</b>	< 0.45	< 0.45	<b>14</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-054	1/14/2019	<b>130</b>	< 0.91	< 0.77	<b>4.7</b>	<b>1.8 J</b>	<b>1.1 J</b>	< 0.51	< 0.79	<b>19</b>	< 0.86	< 0.62	< 0.58	< 0.49	< 1.1	NA
WS-054	2/18/2019	<b>120</b>	< 0.89	< 0.75	<b>4.5</b>	<b>1.8 J</b>	<b>1.0 J</b>	< 0.49	< 0.77	<b>18</b>	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-054	3/12/2019	<b>120</b>	< 0.97	< 0.82	<b>4.7</b>	<b>1.8 J</b>	<b>0.92 J</b>	< 0.54	< 0.84	<b>18</b>	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA
POET-30-MID	10/3/2018	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	NA	NA	NA	NA	NA	NA	NA	NA	NA
POET-30-MID	10/9/2018	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.97	NA
POET-30-MID	11/8/2018	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-30-MID DUP	11/8/2018	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-30-MID	12/5/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-30-MID DUP	12/5/2018	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	NA
POET-30-MID	1/14/2019	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.80	< 0.28	< 0.86	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-30-MID	2/18/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	NA
POET-30-MID	3/12/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-30-MID DUP	3/12/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.44	< 0.50	< 0.78	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
POET-30-POST	10/9/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
POET-30-POST	11/8/2018	< 2.8	< 1.0	< 0.84	< 1.4	< 0.67	< 0.49	< 0.56	< 0.86	< 0.31	< 0.94	< 0.68	< 0.63	< 0.54	< 1.2	NA
POET-30-POST	12/5/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-30-POST	1/14/2019	< 2.6	< 0.92	< 0.78	< 1.3	< 0.62	< 0.46	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-30-POST	2/18/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-30-POST	3/12/2019	< 2.8	< 0.97	< 0.82	< 1.3	< 0.65	< 0.48	< 0.54	< 0.84	< 0.30	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA
WS-030	10/4/2018	<b>38 J</b>	< 0.85	<b>0.80 J</b>	<b>6.1 J</b>	<b>0.71 J</b>	< 0.42	NA	NA	NA	NA	NA	NA	NA	NA	NA
WS-030	10/11/2018	<b>35</b>	< 0.91	<b>1.1 J</b>	<b>7.1</b>	< 0.61	< 0.45	< 0.50	< 0.78	<b>12</b>	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	NA
WS-030	10/18/2018	<b>51</b>	< 0.96	<b>1.1 J</b>	<b>7.2</b>	< 0.65	< 0.47	< 0.53	< 0.83	<b>11</b>	< 0.90	< 0.66	< 0.61	< 0.51	< 1.1	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-030	11/13/2018	51	< 0.83	0.84 J	7.0	< 0.56	< 0.41	< 0.46	< 0.72	9.7	< 0.78	< 0.57	< 0.53	< 0.45	< 0.96	NA
WS-030	12/13/2018	55	< 0.44	0.83 J	9.8	0.6 J	< 0.44	< 0.44	< 0.44	12	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
WS-030	1/14/2019	44	< 0.92	< 0.77	10	0.72 J	< 0.45	< 0.51	< 0.79	9.7	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-030	3/19/2019	74	< 0.85	< 0.71	8.7	0.66 J	< 0.42	< 0.47	< 0.73	10	< 0.79	< 0.58	< 0.54	< 0.45	< 0.98	NA
POET-31-MID	10/4/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.54	< 0.40	NA	NA	NA	NA	NA	NA	NA	NA	NA
POET-31-MID	10/11/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-31-MID DUP	10/11/2018	< 2.8	< 0.98	< 0.82	< 1.3	< 0.66	< 0.48	< 0.55	< 0.85	< 0.30	< 0.92	< 0.67	< 0.62	< 0.53	< 1.1	NA
POET-31-MID	10/18/2018	< 2.8	< 0.98	< 0.83	< 1.3	< 0.66	< 0.49	< 0.55	< 0.85	< 0.30	< 0.92	< 0.67	< 0.62	< 0.53	< 1.1	NA
POET-31-MID	11/13/2018	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
POET-31-MID DUP	11/13/2018	< 2.3	< 0.81	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	NA
POET-31-MID	12/13/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-31-MID	1/14/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-31-MID DUP	1/14/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-31-MID	3/19/2019	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-31-POST	10/18/2018	< 2.6	< 0.93	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-31-POST	11/13/2018	< 2.4	< 0.84	< 0.70	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.78	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-31-POST	12/13/2018	0.53 J	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-31-POST	1/14/2019	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
POET-31-POST	3/19/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.57	< 0.48	< 1.0	NA
WS-037	10/17/2018	18	1.5 J	0.83 J	45	1.5 J	< 0.47	< 0.53	< 0.82	130	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	NA
WS-037	11/19/2018	20	1.4 J	< 0.44	49	0.96 J	< 0.44	< 0.44	< 0.44	110 DJ	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
WS-037	12/21/2018	26	1.5 J	< 0.45	58	1.1 J	0.6 J	< 0.45	< 0.45	100 D	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-037	2/13/2019	19	2.2	< 0.77	41	1.3 J	< 0.46	< 0.51	< 0.79	120	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-037	3/19/2019	19	1.1 J	< 0.71	43	0.89 J	< 0.42	< 0.47	< 0.73	110	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-32-MID	10/17/2018	< 2.6	< 0.92	< 0.77	< 1.3	< 0.62	< 0.45	< 0.51	< 0.79	< 0.28	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
POET-32-MID	11/19/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-32-MID	12/21/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-32-MID	2/13/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-32-MID	3/19/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-32-MID DUP	10/17/2018	< 2.7	< 0.96	< 0.81	< 1.3	< 0.65	< 0.48	< 0.54	< 0.83	< 0.29	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	NA
POET-32-POST	10/17/2018	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-32-POST	11/19/2018	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	NA
POET-32-POST	12/21/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-32-POST	2/13/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-32-POST	3/19/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
WS-133	10/3/2018	<b>5.0 J</b>	< 0.87	<b>1.1 J</b>	< 1.2	< 0.59	< 0.43	NA	NA	NA	NA	NA	NA	NA	NA	<b>0.16 J</b>
WS-133	10/23/2018	<b>5.4 J</b>	< 0.91	<b>0.96 J</b>	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.1	NA
WS-133	11/19/2018	<b>5.3 J</b>	<b>1.4 J</b>	<b>1.1 J</b>	<b>0.88 J</b>	<b>0.6 J</b>	< 0.46 UJ	< 0.46 UJ	< 0.46 UJ	<b>1.7 J</b>	< 0.46 UJ	< 0.46 UJ	< 0.46 UJ	< 0.46 UJ	< 0.46 UJ	NA
WS-133	12/21/2018	<b>7.8</b>	<b>1.2 J</b>	<b>1.2 J</b>	<b>1.1 J</b>	<b>0.73 J</b>	< 0.45	< 0.45	< 0.45	<b>2.2</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
WS-133	3/26/2019	<b>5.8</b>	<b>1.0 J</b>	<b>0.97 J</b>	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	<b>1.0 J</b>	< 0.81	< 0.59	< 0.55	< 0.47	< 1.0	NA
POET-33-MID	10/3/2018	< 2.2	< 0.79	< 0.67	< 1.1	< 0.53	< 0.39	NA	NA	NA	NA	NA	NA	NA	NA	<b>0.27 J</b>
POET-33-MID	10/23/2018	< 2.4	< 0.84	< 0.70	< 1.1	< 0.56	< 0.41	< 0.47	< 0.72	< 0.26	< 0.78	< 0.57	< 0.53	< 0.45	< 0.97	NA
POET-33-MID DUP	10/23/2018	< 2.3	< 0.83	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.57	< 0.52	< 0.44	< 0.96	NA
POET-33-MID	11/19/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-33-MID	12/21/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-33-MID DUP	12/21/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-33-MID	3/26/2019	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-33-MID DUP	3/26/2019	< 2.2	< 0.79	< 0.67	< 1.1	< 0.53	< 0.39	< 0.44	< 0.68	< 0.24	< 0.74	< 0.54	< 0.50	< 0.42	< 0.92	NA
POET-33-POST	10/3/2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<b>0.82 J</b>
POET-33-POST	10/23/2018	< 2.4 UJ	< 0.83 UJ	< 0.70 UJ	< 1.1 UJ	< 0.56 UJ	< 0.41 UJ	< 0.46 UJ	< 0.72 UJ	< 0.25 UJ	< 0.78 UJ	< 0.57 UJ	< 0.53 UJ	< 0.45 UJ	< 0.96 UJ	NA
POET-33-POST	11/19/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-33-POST	12/21/2018	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	NA
POET-33-POST	3/26/2019	< 2.3	< 0.82	< 0.69	< 1.1	< 0.55	< 0.41	< 0.46	< 0.71	< 0.25	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
WS-057	10/9/2018	<b>55 J</b>	<b>22 J</b>	<b>2.7 J</b>	<b>15 J</b>	<b>12 J</b>	<b>4.0 J</b>	< 0.46	< 0.70	<b>28 J</b>	< 0.76	< 0.56	< 0.52	< 0.44	< 0.94	<b>0.26 J</b>
WS-057	10/17/2018	<b>52</b>	<b>19</b>	<b>3.6</b>	<b>18</b>	<b>13</b>	<b>3.2</b>	< 0.54	< 0.83	<b>30</b>	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	<b>0.22 J</b>
WS-057	10/24/2018	<b>57</b>	<b>16</b>	<b>3.4</b>	<b>17</b>	<b>12</b>	<b>3.2</b>	< 0.53	< 0.81	<b>31</b>	< 0.88	< 0.65	< 0.60	<b>2.8</b>	<b>2.0 J</b>	NA
WS-057	10/31/2018	<b>47</b>	<b>16</b>	<b>2.3</b>	<b>15</b>	<b>11</b>	<b>3.0</b>	< 0.51	< 0.79	<b>27</b>	< 0.86 UJ	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-057	11/7/2018	<b>56</b>	<b>17</b>	<b>2.5</b>	<b>16</b>	<b>11</b>	<b>3.0</b>	< 0.46	< 0.72	<b>27</b>	< 0.78	< 0.57	< 0.52	< 0.45	< 0.96	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-057	12/5/2018	52	19	2.4	16	11	2.8	< 0.43	< 0.43	27	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
WS-057	1/3/2019	53	21	2.1	17	10	3.3	< 0.46	< 0.71	27	< 0.77	< 0.56	< 0.52	< 0.44	< 0.95	NA
WS-057	2/6/2019	54	24	1.9	19	9.5	4.1	< 0.49	< 0.76	28	< 0.82	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-34-MID	10/9/2018	< 2.3	< 0.81	< 0.69	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.56	< 0.51	< 0.44	< 0.94	3.5
POET-34-MID	10/17/2018	< 2.7	< 0.95	< 0.80	< 1.3	< 0.64	< 0.47	< 0.53	< 0.82	< 0.29	< 0.89	< 0.65	< 0.60	< 0.51	< 1.1	0.52 J
POET-34-MID DUP	10/17/2018	< 2.7	< 0.97	< 0.81	< 1.3	< 0.65	< 0.48	< 0.54	< 0.83	< 0.29	< 0.91	< 0.66	< 0.61	< 0.52	< 1.1	NA
POET-34-MID	10/24/2018	< 2.4	< 0.85	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-34-MID DUP	10/24/2018	< 2.4	< 0.85	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-34-MID	10/31/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-34-MID DUP	10/31/2018	< 2.5	< 0.87	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-34-MID	11/7/2018	< 2.3	< 0.79	< 0.67	< 1.1	< 0.53	< 0.39	< 0.44	< 0.68	< 0.24	< 0.74	< 0.54	< 0.50	< 0.43	< 0.92	NA
POET-34-MID DUP	11/7/2018	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA
POET-34-MID	12/5/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-34-MID	1/3/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-34-MID	2/6/2019	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.75	< 0.26	< 0.81	< 0.59	< 0.55	< 0.46	< 1.0	NA
POET-34-POST	10/9/2018	< 2.4	< 0.84	< 0.71	< 1.1	< 0.57	< 0.42	< 0.47	< 0.72	< 0.26	< 0.79	< 0.57	< 0.53	< 0.45	< 0.97	5.6
POET-34-POST	10/17/2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.1
POET-34-POST	11/7/2018	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.43	< 0.94	NA
POET-34-POST	12/5/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-34-POST	1/3/2019	< 2.5	< 0.87	< 0.73	< 1.2	< 0.59	< 0.43	< 0.49	< 0.75	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-34-POST	2/6/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
WS-049	10/31/2018	5.3 J	2.1	1.4 J	2.4 J	2.0	< 0.47	< 0.53	< 0.83	3.9	< 0.90	< 0.66	< 0.60	< 0.51	< 1.1	< 0.15
WS-049	11/26/2018	5.3	1.2 J	1.4 J	2.1	1.5 J	< 0.45	< 0.45	< 0.45	3.8	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.15
WS-049	1/7/2019	5.4	2.3	1.5 J	2.2 J	1.8	< 0.42	< 0.47	< 0.73	3.9	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
WS-049	1/21/2019	5.8	3.2	1.9	2.4 J	1.8 J	< 0.44	< 0.50	< 0.77	5.2	< 0.83	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-35-MID	10/31/2018	< 2.6	< 0.91	< 0.76	< 1.2	< 0.61	< 0.45	< 0.51	< 0.78	< 0.28	< 0.85	< 0.62	< 0.57	< 0.49	< 1.0	3.3
POET-35-MID DUP	10/31/2018	< 2.4	2.3	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.54	< 0.46	< 0.98	NA
POET-35-MID	11/26/2018	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.15
POET-35-MID	1/7/2019	< 2.4	< 0.86	< 0.72	< 1.2	< 0.58	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.59	< 0.54	< 0.46	< 0.99	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
POET-35-MID DUP	1/7/2019	< 2.5	< 0.86	< 0.73	< 1.2	< 0.58	< 0.43	< 0.48	< 0.74	< 0.26	< 0.81	< 0.59	< 0.54	< 0.46	< 1.0	NA
POET-35-MID	1/21/2019	< 2.6	< 0.93	< 0.78	< 1.3	< 0.62	< 0.46	< 0.52	< 0.80	< 0.28	< 0.87	< 0.63	< 0.58	< 0.50	< 1.1	NA
POET-35-POST	10/31/2018	< 2.7	< 0.94	< 0.79	< 1.3	< 0.63	< 0.46	< 0.52	< 0.81	< 0.29	< 0.88	< 0.64	< 0.59	< 0.50	< 1.1	<b>5.0</b>
POET-35-POST	11/26/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.15
POET-35-POST	1/7/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-35-POST	1/21/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.44	< 0.50	< 0.78	< 0.27	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
WS-121B	10/22/2018	<b>3.0 J</b>	<b>2.1 J</b>	< 0.81	<b>1.3 J</b>	<b>0.70 J</b>	< 0.48	< 0.54	< 0.83	<b>2.1 J</b>	< 0.90	< 0.66	< 0.61	< 0.52	< 1.1	NA
WS-121B	11/28/2018	<b>2.9</b>	<b>2.2</b>	< 0.46	<b>0.86 J</b>	< 0.46	< 0.46	< 0.46	< 0.46	<b>1.8 J</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	<b>0.43 J</b>
WS-121B	12/5/2018	<b>2.7</b>	<b>1.9</b>	< 1.8 UB	<b>0.86 J</b>	<b>0.55 J</b>	< 0.45	< 0.45	< 0.45	<b>1.6 J</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.15
WS-121B	12/12/2018	<b>2.3</b>	<b>1.6 J</b>	< 0.42	<b>0.77 J</b>	<b>0.53 J</b>	< 0.42	< 0.42	< 0.42	<b>1.6 J</b>	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	NA
WS-121B	12/19/2018	<b>5.9</b>	< 0.46	< 0.46	<b>1.2 J</b>	<b>1.1 J</b>	< 0.46	< 0.46	< 0.46	<b>2.6</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	NA
WS-121B	1/2/2019	<b>2.8 J</b>	<b>1.7</b>	< 0.70	< 1.1	< 0.56	< 0.41	< 0.46	< 0.71	<b>2.1</b>	< 0.78	< 0.57	< 0.52	< 0.44	< 0.96	NA
WS-121B	2/12/2019	<b>3.0 J</b>	<b>1.6 J</b>	< 0.78	< 1.3	< 0.63	< 0.46	< 0.52	< 0.80	<b>2.4</b>	< 0.87	< 0.64	< 0.59	< 0.50	< 1.1	NA
POET-36-MID	11/28/2018	< 0.45	<b>12 J</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	<b>1.8</b>
POET-36-MID	12/5/2018	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.15
POET-36-MID	12/12/2018	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	< 0.41	NA
POET-36-MID DUP	12/12/2018	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-36-MID	12/19/2018	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	NA
POET-36-MID	1/2/2019	< 2.3	< 0.81	< 0.68	< 1.1	< 0.55	< 0.40	< 0.45	< 0.70	< 0.25	< 0.76	< 0.55	< 0.51	< 0.43	< 0.94	NA
POET-36-MID DUP	1/2/2019	< 2.4	< 0.84	< 0.71	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.79	< 0.58	< 0.53	< 0.45	< 0.98	NA
POET-36-MID	2/12/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.60	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-36-MID DUP	11/28/2018	<b>0.5 J</b>	<b>0.73 J</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA
POET-36-POST	11/28/2018	< 0.46	<b>3</b>	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	< 0.46	<b>2.6</b>
POET-36-POST	12/5/2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<b>0.37 J</b>
POET-36-POST	1/2/2019	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.44	< 0.49	< 0.76	< 0.27	< 0.83	< 0.60	< 0.56	< 0.47	< 1.0	NA
POET-36-POST	2/12/2019	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	<b>0.68 J</b>	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
WS-106	11/29/2018	<b>14</b>	<b>0.74 J</b>	< 0.45	<b>2.7</b>	<b>2.4</b>	< 0.45	< 0.45	< 0.45	<b>5.6</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	<b>0.15 J</b>
WS-106	12/6/2018	<b>6.7</b>	< 0.47	< 1.9 UB	<b>1.3 J</b>	<b>1.6 J</b>	< 0.47	< 0.47	< 0.47	<b>2.8</b>	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.15
WS-106	12/14/2018	<b>7.4</b>	< 0.45	< 0.45	<b>1.6 J</b>	<b>1.5 J</b>	< 0.45	< 0.45	< 0.45	<b>3.3</b>	< 0.45	< 0.45	< 0.45	< 0.45	< 0.45	NA

TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019

NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.

Location	Sample Date	PFOA	PFOS	PFBS	PFHpA	PFHxS	PFNA	PFDA	PFDaA	PFHxA	PFTeA	PFTriA	PFUnA	EtFOSAA	MeFOSAA	Arsenic
WS-106	12/21/2018	<b>3</b>	<b>1.9</b>	<b>0.52 J</b>	<b>0.96 J</b>	<b>0.58 J</b>	< 0.47	< 0.47	< 0.47	<b>2.1</b>	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	NA
WS-106	12/27/2018	<b>7.8</b>	< 0.92	< 0.77	< 1.3	<b>1.8 J</b>	< 0.46	< 0.51	< 0.79	<b>3.2</b>	< 0.86	< 0.63	< 0.58	< 0.49	< 1.1	NA
WS-106	1/30/2019	<b>2.7 J</b>	< 0.83	< 0.69	< 1.1	<b>0.57 J</b>	< 0.41	< 0.46	< 0.71	<b>0.75 J</b>	< 0.77	< 0.56	< 0.52	< 0.44	< 0.96	NA
WS-106	2/25/2019	< 1.8	< 0.64	< 0.54	< 0.88	< 0.43	< 0.32	< 0.36	< 0.55	< 0.20	< 0.60	< 0.44	< 0.41	< 0.34	< 0.74	NA
POET-37-MID	11/29/2018	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	<b>2.0</b>
POET-37-MID	12/6/2018	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	< 0.42	<b>0.62 J</b>
POET-37-MID DUP	12/6/2018	< 0.44	< 0.44	< 1.8 UB	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	< 0.44	NA
POET-37-MID	12/14/2018	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	< 0.43	NA
POET-37-MID	12/21/2018	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	< 0.48	NA
POET-37-MID	12/27/2018	< 2.6	< 0.90	< 0.76	< 1.2	< 0.61	< 0.45	< 0.50	< 0.78	< 0.27	< 0.84	< 0.62	< 0.57	< 0.48	< 1.0	NA
POET-37-MID	1/30/2019	< 2.8	< 1.0	< 0.84	< 1.4	< 0.67	< 0.49	< 0.56	< 0.86	< 0.30	< 0.94	< 0.68	< 0.63	< 0.54	< 1.2	NA
POET-37-MID	2/25/2019	< 2.5	< 0.89	< 0.75	< 1.2	< 0.60	< 0.44	< 0.50	< 0.77	< 0.27	< 0.84	< 0.61	< 0.56	< 0.48	< 1.0	NA
POET-37-MID DUP	2/25/2019	< 2.5 UJ	< 0.88 UJ	< 0.74 UJ	< 1.2 UJ	< 0.59 UJ	< 0.43 UJ	< 0.49 UJ	< 0.76 UJ	< 0.27 UJ	< 0.82 UJ	< 0.60 UJ	< 0.56 UJ	< 0.47 UJ	< 1.0 UJ	NA
POET-37-POST	11/29/2018	<b>0.62 J</b>	<b>0.52 J</b>	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	< 0.47	<b>2.4</b>
POET-37-POST	12/6/2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<b>0.94 J</b>
POET-37-POST	12/27/2018	< 2.5	< 0.88	< 0.74	< 1.2	< 0.59	< 0.43	< 0.49	< 0.76	< 0.27	< 0.82	< 0.60	< 0.55	< 0.47	< 1.0	NA
POET-37-POST	1/30/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.48	< 0.74	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA
POET-37-POST	2/25/2019	< 2.4	< 0.85	< 0.72	< 1.2	< 0.57	< 0.42	< 0.47	< 0.73	< 0.26	< 0.80	< 0.58	< 0.54	< 0.46	< 0.99	NA

Notes:

Detections are boldfaced

< = Compound not detected at method detection limit

D = Dilution required for sample analysis

J = The compound was positively identified; however, the associated numerical value is an estimated concentration only

UB = Compound considered non-detect at the listed value due to associated blank contamination

UJ = The compound was not detected above the reported sample method detection limit; however, the reported limit is approximate and may or may not represent the actual method detection limit

DUP = Duplicate sample result

NA = Not available

PFOA = Perfluorooctanoic acid (C8)

PFOS = Perfluorooctanesulfonic acid (C8)

PFBS = Perfluorobutanesulfonic acid (C4)

PFHpA = Perfluoroheptanoic acid (C7)

PFHxS = Perfluorohexanesulfonic acid (C6)

PFNA = Perfluorononanoic acid (C9)

PFDA = Perfluorodecanoic acid (C10)

PFDaA = Perfluorododecanoic acid (C12)

PFHxA = Perfluorohexanoic acid (C6)



**TOWN OF PESHTIGO FINAL POET SYSTEM WATER SAMPLE RESULTS - OCTOBER 1, 2018 THROUGH MARCH 31, 2019**

**NOTE: FINAL DATA IS PRESENTED BELOW. DATA VALIDATION ON RESULTS IS COMPLETE.**

**Notes continued:**

PFTeA = Perfluorotetradecanoic acid (C14)

PFTriA = Perfluorotridecanoic acid (C13)

PFUnA = Perfluoroundecanoic acid (C11)

EtFOSAA = Ethylperfluorooctane sulfonamido acetate (C10)

MeFOSAA = Methylperfluorooctane sulfonamido acetate (C9)

Units are in ng/L (nanogram per liter)