

Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : MADISON KIPP CORPORATION
 Contact Address : 708 Heartland Trail, Suite 3000
 Madison, WI 53717
 Facility Contact : Andrew Stehn, Project Engineer
 Phone Number : 608-826-3665
 Reporting Period : 01/01/2020 - 03/31/2020
 Form Due Date : 04/21/2020
 Permit Number : **0046566**

Date Received:	
DOC:	437830
FIN:	7960
FID:	113125320
Region:	South Central Region
Permit Drafter:	Trevor J Moen
Reviewer:	Christopher A Dietrich
Office:	Milwaukee

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
001	40	Benzene	03/02/2020	GRAB	<0.25	ug/L	Monthly Avg	50(0)	0.25	1	N	405132750
001	54	BETX, Total	03/02/2020	GRAB	<1.5	ug/L	Monthly Avg	750(0)			N	405132750
001	393	PAHs	03/02/2020	GRAB	<0.17	ug/L	Monthly Avg	0.10(0)			N	405132750
001	44	Benzo(a)pyrene	03/02/2020	GRAB	<0.0099	ug/L	Monthly Avg	0.10(0)	0.0099	0.050	N	405132750
001	307	Naphthalene	03/02/2020	GRAB	<0.017	ug/L	Monthly Avg	70(0)	0.017	0.086	N	405132750
001	80	Bromoform	03/02/2020	GRAB	<4.0	ug/L	Monthly Avg	120(0)	4.0	13.2	N	405132750
001	93	Carbon tetrachloride	03/02/2020	GRAB	<0.17	ug/L		*****	0.17	1.0	N	405132750
001	118	Chloroform	03/02/2020	GRAB	<1.3	ug/L	Monthly Avg	120(0)	1.3	5.0	N	405132750
001	174	Dichlorobromo- methane (bromo-	03/02/2020	GRAB	<0.36	ug/L	Monthly Avg	120(0)	0.36	1.2	N	405132750
001	570	1,2-Dichloro- ethane	03/02/2020	GRAB	<0.28	ug/L	Monthly Avg	180(0)	0.28	1.0	N	405132750
001	558	1,1-Dichloro- ethylene	03/02/2020	GRAB	<0.24	ug/L	Monthly Avg	50(0)	0.24	1.0	N	405132750
001	82	Methyl bromide	03/02/2020	GRAB	<0.97	ug/L	Monthly Avg	120(0)	0.97	5.0	N	405132750
001	120	Chloromethane	03/02/2020	GRAB	<2.2	ug/L	Monthly Avg	120(0)	2.2	7.3	N	405132750
001	565	1,1,2,2-Tetrachloro- ethane	03/02/2020	GRAB	<0.28	ug/L	Monthly Avg	50(0)	0.28	1.0	N	405132750
001	490	Tetrachloroethylene	03/02/2020	GRAB	12.5	ug/L	Monthly Avg	50(0)	0.33	1.1	N	405132750
001	563	1,1,2-Trichloro- ethane	03/02/2020	GRAB	<0.55	ug/L	Monthly Avg	50(0)	0.55	5.0	N	405132750
001	561	1,1,1-Trichloro- ethane	03/02/2020	GRAB	<0.24	ug/L	Monthly Avg	50(0)	0.24	1.0	N	405132750
001	508	Trichloro- ethylene	03/02/2020	GRAB	3.1	ug/L	Monthly Avg	50(0)	0.26	1.0	N	405132750
001	517	Vinyl chloride	03/02/2020	GRAB	<0.17	ug/L	Monthly Avg	10(0)	0.17	1.0	N	405132750

Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

Permanganate: Absent (Parameter visually monitored by TRC for neutralization and photo documentation can be provided upon request).

No BTEX or PAH parameters were reported above the laboratory LOD. The parameter for each group with highest detection limit was reported.

The GETS was shutdown for a portion of time between March 1 and 2, 2020 and March 6 and 10, 2020 due to scheduled power outages for facility electrical maintenance work.

Laboratory Quality Control Comments

Submitted by astehn on 04/06/2020 1:14:04 PM