

# Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : MADISON KIPP CORPORATION  
 Contact Address : 708 Heartland Trail, Suite 3000  
 Madison, WI 53717  
 Facility Contact : Andrew Stehn, Project Engineer  
 Phone Number : 608-826-3665  
 Reporting Period : 10/01/2020 - 12/31/2020  
 Form Due Date : 01/21/2021  
 Permit Number : **0046566**

Date Received:	
DOC:	458024
FIN:	7960
FID:	113125320
Region:	South Central Region
Permit Drafter:	Trevor J Moen
Reviewer:	Christopher A Dietrich
Office:	Milwaukee

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
001	40	Benzene	12/10/2020	GRAB	<0.25	ug/L	Monthly Avg	50(0)	0.25	1.0	N	405132750
001	54	BETX, Total	12/10/2020	GRAB	<1.5	ug/L	Monthly Avg	750(0)			N	405132750
001	393	PAHs	12/10/2020	GRAB	<0.016	ug/L	Monthly Avg	0.10(0)			N	405132750
001	44	Benzo(a)pyrene	12/10/2020	GRAB	<0.0098	ug/L	Monthly Avg	0.10(0)	0.0098	0.049	N	405132750
001	307	Naphthalene	12/10/2020	GRAB	<0.017	ug/L	Monthly Avg	70(0)	0.017	0.086	N	405132750
001	80	Bromoform	12/10/2020	GRAB	<4.0	ug/L	Monthly Avg	120(0)	4.0	13.2	N	405132750
001	93	Carbon tetrachloride	12/10/2020	GRAB	<1.1	ug/L		*****	1.1	3.6	N	405132750
001	118	Chloroform	12/10/2020	GRAB	<1.3	ug/L	Monthly Avg	120(0)	1.3	5.0	N	405132750
001	174	Dichlorobromo- methane (bromo-	12/10/2020	GRAB	<0.36	ug/L	Monthly Avg	120(0)	0.36	1.2	N	405132750
001	570	1,2-Dichloro- ethane	12/10/2020	GRAB	<0.28	ug/L	Monthly Avg	180(0)	0.28	1.0	N	405132750
001	558	1,1-Dichloro- ethylene	12/10/2020	GRAB	<0.24	ug/L	Monthly Avg	50(0)	0.24	1.0	N	405132750
001	82	Methyl bromide	12/10/2020	GRAB	<0.97	ug/L	Monthly Avg	120(0)	0.97	5.0	N	405132750
001	120	Chloromethane	12/10/2020	GRAB	<2.2	ug/L	Monthly Avg	120(0)	2.2	7.3	N	405132750
001	565	1,1,2,2-Tetrachloro- ethane	12/10/2020	GRAB	<0.28	ug/L	Monthly Avg	50(0)	0.28	1.0	N	405132750
001	490	Tetrachloroethylene	12/10/2020	GRAB	9.0	ug/L	Monthly Avg	50(0)	0.33	1.1	N	405132750
001	563	1,1,2-Trichloro- ethane	12/10/2020	GRAB	<0.55	ug/L	Monthly Avg	50(0)	0.55	5.0	N	405132750
001	561	1,1,1-Trichloro- ethane	12/10/2020	GRAB	<0.24	ug/L	Monthly Avg	50(0)	0.24	1.0	N	405132750
001	508	Trichloro- ethylene	12/10/2020	GRAB	1.5	ug/L	Monthly Avg	50(0)	0.26	1.0	N	405132750
001	517	Vinyl chloride	12/10/2020	GRAB	<0.17	ug/L	Monthly Avg	10(0)	0.17	1.0	N	405132750

## Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

### General Remarks

Permanganate: Absent (Parameter visually monitored by TRC for neutralization and photo documentation can be provided upon request).

No BTEX or PAH parameters were reported above the laboratory LOD. The parameter for each group with the highest detection limit was reported.

### Laboratory Quality Control Comments

Submitted by astehn on 01/18/2021 3:05:32 PM