

Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : MADISON KIPP CORPORATION
 Contact Address : 708 Heartland Trail, Suite 3000
 Madison, WI 53717
 Facility Contact : Andrew Stehn, Project Engineer
 Phone Number : 608-826-3665
 Reporting Period : 04/01/2021 - 06/30/2021
 Form Due Date : 07/21/2021
 Permit Number : **0046566**

Date Received:	
DOC:	471414
FIN:	7960
FID:	113125320
Region:	South Central Region
Permit Drafter:	Drafter not set
Reviewer:	David J Haas
Office:	Green Bay

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
001	40	Benzene	06/02/2021	GRAB	<0.30	ug/L	Monthly Avg	50(0)	0.30	1.0	N	405132750
001	54	BETX, Total	06/02/2021	GRAB	<1.0	ug/L	Monthly Avg	750(0)			N	405132750
001	393	PAHs	06/02/2021	GRAB	0.052	ug/L	Monthly Avg	0.10(0)			N	405132750
001	44	Benzo(a)pyrene	06/02/2021	GRAB	<0.0097	ug/L	Monthly Avg	0.10(0)	0.0097	0.048	N	405132750
001	307	Naphthalene	06/02/2021	GRAB	<0.017	ug/L	Monthly Avg	70(0)	0.017	0.084	N	405132750
001	80	Bromoform	06/02/2021	GRAB	<3.8	ug/L	Monthly Avg	120(0)	3.8	5.0	N	405132750
001	93	Carbon tetrachloride	06/02/2021	GRAB	<0.37	ug/L		*****	0.37	1.0	N	405132750
001	118	Chloroform	06/02/2021	GRAB	<1.2	ug/L	Monthly Avg	120(0)	1.2	5.0	N	405132750
001	174	Dichlorobromo- methane (bromo-	06/02/2021	GRAB	<0.42	ug/L	Monthly Avg	120(0)	0.42	1.0	N	405132750
001	570	1,2-Dichloro- ethane	06/02/2021	GRAB	<0.29	ug/L	Monthly Avg	180(0)	0.29	1.0	N	405132750
001	558	1,1-Dichloro- ethylene	06/02/2021	GRAB	<0.58	ug/L	Monthly Avg	50(0)	0.58	1.0	N	405132750
001	82	Methyl bromide	06/02/2021	GRAB	<1.2	ug/L	Monthly Avg	120(0)	1.2	5.0	N	405132750
001	120	Chloromethane	06/02/2021	GRAB	<1.6	ug/L	Monthly Avg	120(0)	1.6	5.0	N	405132750
001	565	1,1,2,2-Tetrachloro- ethane	06/02/2021	GRAB	<0.38	ug/L	Monthly Avg	50(0)	0.38	1.0	N	405132750
001	490	Tetrachloroethylene	06/02/2021	GRAB	8.2	ug/L	Monthly Avg	50(0)	0.41	1.0	N	405132750
001	563	1,1,2-Trichloro- ethane	06/02/2021	GRAB	<0.34	ug/L	Monthly Avg	50(0)	0.34	5.0	N	405132750
001	561	1,1,1-Trichloro- ethane	06/02/2021	GRAB	<0.30	ug/L	Monthly Avg	50(0)	0.30	1.0	N	405132750
001	508	Trichloro- ethylene	06/02/2021	GRAB	1.7	ug/L	Monthly Avg	50(0)	0.32	1.0	N	405132750
001	517	Vinyl chloride	06/02/2021	GRAB	<0.17	ug/L	Monthly Avg	10(0)	0.17	1.0	N	405132750

Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

No BTEX parameters were reported above the laboratory LOD. The parameter with the highest detection limit was reported.

Multiple Group 10 PAH parameters were detected above the LOD and the noted concentration was calculated using the Toxicity Equivalent Factor as outlined in Appendix C of the WPDES permit.

Laboratory Quality Control Comments

Submitted by astehn on 07/13/2021 10:19:41 PM