

# Wastewater Discharge Monitoring Long Report

For DNR Use Only

Facility Name: MADISON KIPP CORPORATION  
 Contact Address: 708 Heartland Trail, Suite 3000  
 Madison, WI 53717  
 Facility Contact: Andrew Stehn, Project Engineer  
 Phone Number: 608-826-3665  
 Reporting Period: 04/01/2021 - 04/30/2021  
 Form Due Date: 05/21/2021  
 Permit Number: 0046566

Date Received:	
DOC:	470548
FIN:	7960
FID:	113125320
Region:	South Central Region
Permit Drafter:	Drafter not set
Reviewer:	David J Haas
Office:	Green Bay

	Sample Point	001	001
	Description	Surface Water Discharge	Surface Water Discharge
	Parameter	211	457
	Description	Flow Rate	Suspended Solids, Total
	Units	gpd	mg/L
	Sample Type	ESTIMATED	GRAB
	Frequency	DAILY	PER OCCURANCE
Sample Results	Day 1	57600	
	2	57600	
	3	57600	
	4	57600	
	5	57600	
	6	57600	
	7	57600	
	8	57600	
	9	57600	
	10	57600	
	11	57600	
	12	57600	
	13	57600	
	14	57600	
	15	57600	
	16	57600	
	17	57600	
	18	57600	
	19	57600	
	20	57600	
	21	57600	
	22	57600	
	23	35160	
	24	0	
	25	0	
	26	0	
	27	0	
	28	0	
	29	34827	<0.95
	30	57600	
	31		

	<b>Sample Point</b>	001		001	
	<b>Description</b>	Surface Water Discharge		Surface Water Discharge	
	<b>Parameter</b>	211		457	
	<b>Description</b>	Flow Rate		Suspended Solids, Total	
	<b>Units</b>	gpd		mg/L	
<b>Summary Values</b>	<b>Monthly Avg</b>	46492.9		0	
	<b>Daily Max</b>	57600		<0.95	
	<b>Daily Min</b>	0		<0.95	
<b>Limit(s) in Effect</b>	<b>Daily Max</b>			40	0
<b>QA/QC Information</b>	<b>LOD</b>			0.95	
	<b>LOQ</b>			2	
	<b>QC Exceedance</b>	N		N	
	<b>Lab Certification</b>			405132750	

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

The GETS was shutdown for a period of time between April 23, to April 28, 2021 for maintenance and cleaning of the air stripper system. A TSS samples was collected following the system cleaning and restart.

Laboratory Quality Control Comments

Submitted by astehn on 05/21/2021 3:26:50 PM