



Post Office Box 8043
Madison, WI 53708-8043

**Madison-Kipp
Corporation**

201 Waubesa Street
Madison, WI 53704-5728

December 2, 2016

Alan Hopfensperfer
Wisconsin Department of Natural Resources
South Central Region
3911 Fish Hatchery Rd.
Fitchburg, WI 53711

Subject: Discharge Monitoring Report - Groundwater Extraction and Treatment System,
Madison Kipp Corporation, 201 Waubesa Street, Madison, Wisconsin

Dear Mr. Hopfensperfer,

The Groundwater Extraction and Treatment System (GETS) ran for the month of November, with the exception of maintenance activities. This letter summarizes the activities completed in November 2016 as part of the GETS at the Madison Kipp Corporation (MKC) site under the Wisconsin Pollution Discharge Elimination System (WPDES) Permit WI-0046566-6. Compliance samples were collected on November 7, 2016 per the WPDES permit, including visual monitoring for sodium permanganate neutralization. The compliance sample results were below the WPDES discharge limits. The Discharge Monitoring Report is included as Attachment A and laboratory reports are included as Attachment B.

During the month of November, the GETS was shut down for half of a day to complete routine maintenance to the air stripper and for approximately three days while troubleshooting an issue with one of the transfer pumps. We continue to investigate the pump and expect to have the system running at full capacity in early December. If you have any questions or need additional information, please contact me at asatkoski@madison-kipp.com or (608) 242-5200.

Alina Satkoski

Madison Kipp Corporation

Attachment A Discharge Monitoring Report Form

Attachment B Laboratory Reports

Copies:

Andrew Stehn - TRC (electronic)

Mike Schmoller - WDNR (electronic)

Wendy Weihemuller - WDNR (electronic)

George Parrino - Madison Department of Health (electronic)

FOOTNOTES:

- (1) Total BETX is the sum of the benzene, ethylbenzene, toluene and xylene concentrations. If all compounds were below their corresponding laboratory detection limits, then the highest detection limit of the BTEX compounds was noted.
- (2) PAH group of 10 (Polynuclear Aromatic Hydrocarbons) include the sum of the following individual compounds: benzo(a)anthracene, benzo(b)fluoranthene, benzo(g,h,i)perylene, benzo(k)fluoranthene, chrysene, dibenzo(a,h)anthracene, fluoranthene, indeno(1,2,3-cd)pyrene, phenanthrene, and pyrene. If all compounds were below their corresponding laboratory detection limits, then the highest detection limit of the PAH group compounds was noted.
- (3) Madison Kipp/Arcadis/TRC will conduct visual monitoring for this compound.
- (4) No effluent limit is established, refer to section 4 of the permit.
- (5) Compound was found in the blank and in the sample.
- (6) Estimated value. Analyte detected at a level less than the reporting limit and greater than or equal to the detection limit.
- (7) Matrix Spike and/or Matrix Spike Duplicate Recovery is outside acceptance limits.

DIRECTIONS:

- ☞ For "Outfall # and Description" enter the number of the outfall you are reporting (001 or 002, etc.)
- ☞ Monitoring for a given parameter depends on if the discharge is to surface water or groundwater.
- ☞ The value entered must be the highest value of all samples analyzed for that day.
- ☞ Print additional DMRs as necessary for monthly reporting.

RETURN REPORT BY: **February 15, of the year following completion of monitoring**

RETURN TO: **ATTN: Nicholas Bertolas**
Department of Natural Resources
3911 Fish Hatchery Rd.
Fitchburg, WI 53711

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment, (40 CFR 122.5). I also certify that the values being submitted are the actual values found in the samples; no values have been modified or changed in any manner. Wherever I believe a value being reported is inaccurate, I have added an explanation indicating the reasons why the value is inaccurate.

Alina Jett

12-2-2016

Signature of Person Completing Form

Date

Alina Jett

12-2-2016

Signature of Principal Exec. or Authorized Agent

Date

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Chicago

2417 Bond Street

University Park, IL 60484

Tel: (708)534-5200

TestAmerica Job ID: 500-119736-1

Client Project/Site: MadisonKipp - GETS/SVE

For:

Madison-Kipp Corporation

201 Waubesa Street

Madison, Wisconsin 53704

Attn: Alina Satkoski



Authorized for release by:

11/10/2016 5:05:28 PM

Sandie Fredrick, Project Manager II

(920)261-1660

sandie.fredrick@testamericainc.com

LINKS

Review your project
results through

TotalAccess

Have a Question?



Visit us at:

www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15



Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	5
Sample Summary	6
Client Sample Results	7
Definitions	10
QC Association	11
Surrogate Summary	12
QC Sample Results	13
Chronicle	16
Certification Summary	17
Chain of Custody	18
Receipt Checklists	21

Case Narrative

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Job ID: 500-119736-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-119736-1

Comments

No additional comments.

Receipt

The samples were received on 11/8/2016 10:25 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 9.6° C.

Receipt Exceptions

The following sample(s) was received at the laboratory outside the required temperature criteria: 9.6, on ice.

GC/MS VOA

Method(s) 624: The following sample was diluted to bring the concentration of target analytes within the calibration range: Influent (500-119736-1). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

General Chemistry

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Detection Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Client Sample ID: Influent

Lab Sample ID: 500-119736-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene - DL	1600		50	19	ug/L	50		624	Total/NA
HEM (Oil & Grease)	2.4	J	5.6	1.5	mg/L	1		1664B	Total/NA
Chloride	120		5.0	1.9	mg/L	25		300.0	Total/NA
Total Suspended Solids	5.0		5.0	2.5	mg/L	1		SM 2540D	Total/NA

Client Sample ID: Effluent

Lab Sample ID: 500-119736-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	22		1.0	0.41	ug/L	1		624	Total/NA
Tetrachloroethene	35		1.0	0.37	ug/L	1		624	Total/NA
Toluene	0.93		0.50	0.15	ug/L	1		624	Total/NA
Trichloroethene	8.8		0.50	0.16	ug/L	1		624	Total/NA
Chloride	120		5.0	1.9	mg/L	25		300.0	Total/NA
Total Suspended Solids	3.0	J	5.0	2.5	mg/L	1		SM 2540D	Total/NA

Client Sample ID: Trip Blank

Lab Sample ID: 500-119736-3

No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Method	Method Description	Protocol	Laboratory
624	Volatile Organic Compounds (GC/MS)	40CFR136A	TAL CHI
1664B	HEM and SGT-HEM	1664B	TAL CHI
300.0	Anions, Ion Chromatography	MCAWW	TAL CHI
SM 2540D	Solids, Total Suspended (TSS)	SM	TAL CHI

Protocol References:

1664B = 1664B

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

MCAWW = "Methods For Chemical Analysis Of Water And Wastes", EPA-600/4-79-020, March 1983 And Subsequent Revisions.

SM = "Standard Methods For The Examination Of Water And Wastewater",

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

Sample Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-119736-1	Influent	Water	11/07/16 07:25	11/08/16 10:25
500-119736-2	Effluent	Water	11/07/16 07:30	11/08/16 10:25
500-119736-3	Trip Blank	Water	11/07/16 00:00	11/08/16 10:25

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Client Sample ID: Influent

Date Collected: 11/07/16 07:25

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-1

Matrix: Water

Method: 624 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.73		2.5	0.73	ug/L			11/09/16 19:01	5
Bromoform	<2.2		5.0	2.2	ug/L			11/09/16 19:01	5
Carbon tetrachloride	<1.9		5.0	1.9	ug/L			11/09/16 19:01	5
Chloroform	<1.9		5.0	1.9	ug/L			11/09/16 19:01	5
cis-1,2-Dichloroethene	<2.0		5.0	2.0	ug/L			11/09/16 19:01	5
Dichlorobromomethane	<1.9		5.0	1.9	ug/L			11/09/16 19:01	5
1,2-Dichloroethane	<2.0		5.0	2.0	ug/L			11/09/16 19:01	5
1,1-Dichloroethene	<2.0		5.0	2.0	ug/L			11/09/16 19:01	5
Ethylbenzene	<0.92		2.5	0.92	ug/L			11/09/16 19:01	5
Methyl bromide	<3.2		10	3.2	ug/L			11/09/16 19:01	5
Methyl chloride	<1.6		5.0	1.6	ug/L			11/09/16 19:01	5
Methyl tert-butyl ether	<2.0		5.0	2.0	ug/L			11/09/16 19:01	5
1,1,2,2-Tetrachloroethane	<2.0		5.0	2.0	ug/L			11/09/16 19:01	5
Toluene	<0.76		2.5	0.76	ug/L			11/09/16 19:01	5
trans-1,2-Dichloroethene	<1.7		5.0	1.7	ug/L			11/09/16 19:01	5
1,1,1-Trichloroethane	<1.9		5.0	1.9	ug/L			11/09/16 19:01	5
1,1,2-Trichloroethane	<1.8		5.0	1.8	ug/L			11/09/16 19:01	5
Trichloroethene	<0.82		2.5	0.82	ug/L			11/09/16 19:01	5
Vinyl chloride	<1.0		2.5	1.0	ug/L			11/09/16 19:01	5
Xylenes, Total	<2.0		5.0	2.0	ug/L			11/09/16 19:01	5

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	101		71 - 120		11/09/16 19:01	5
1,2-Dichloroethane-d4 (Surr)	96		71 - 127		11/09/16 19:01	5
Toluene-d8 (Surr)	94		75 - 120		11/09/16 19:01	5

Method: 624 - Volatile Organic Compounds (GC/MS) - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tetrachloroethene	1600		50	19	ug/L			11/09/16 19:27	50

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		71 - 120		11/09/16 19:27	50
1,2-Dichloroethane-d4 (Surr)	95		71 - 127		11/09/16 19:27	50
Toluene-d8 (Surr)	94		75 - 120		11/09/16 19:27	50

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HEM (Oil & Grease)	2.4	J	5.6	1.5	mg/L		11/08/16 17:13	11/08/16 19:40	1
Chloride	120		5.0	1.9	mg/L			11/10/16 04:41	25
Total Suspended Solids	5.0		5.0	2.5	mg/L			11/08/16 13:43	1

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Client Sample ID: Effluent

Date Collected: 11/07/16 07:30

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-2

Matrix: Water

Method: 624 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			11/09/16 19:54	1
Bromoform	<0.45		1.0	0.45	ug/L			11/09/16 19:54	1
Carbon tetrachloride	<0.38		1.0	0.38	ug/L			11/09/16 19:54	1
Chloroform	<0.37		1.0	0.37	ug/L			11/09/16 19:54	1
cis-1,2-Dichloroethene	22		1.0	0.41	ug/L			11/09/16 19:54	1
Dichlorobromomethane	<0.37		1.0	0.37	ug/L			11/09/16 19:54	1
1,2-Dichloroethane	<0.39		1.0	0.39	ug/L			11/09/16 19:54	1
1,1-Dichloroethene	<0.39		1.0	0.39	ug/L			11/09/16 19:54	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			11/09/16 19:54	1
Methyl bromide	<0.65		2.0	0.65	ug/L			11/09/16 19:54	1
Methyl chloride	<0.32		1.0	0.32	ug/L			11/09/16 19:54	1
Methyl tert-butyl ether	<0.39		1.0	0.39	ug/L			11/09/16 19:54	1
1,1,1,2-Tetrachloroethane	<0.40		1.0	0.40	ug/L			11/09/16 19:54	1
Tetrachloroethene	35		1.0	0.37	ug/L			11/09/16 19:54	1
Toluene	0.93		0.50	0.15	ug/L			11/09/16 19:54	1
trans-1,2-Dichloroethene	<0.35		1.0	0.35	ug/L			11/09/16 19:54	1
1,1,1-Trichloroethane	<0.38		1.0	0.38	ug/L			11/09/16 19:54	1
1,1,2-Trichloroethane	<0.35		1.0	0.35	ug/L			11/09/16 19:54	1
Trichloroethene	8.8		0.50	0.16	ug/L			11/09/16 19:54	1
Vinyl chloride	<0.20		0.50	0.20	ug/L			11/09/16 19:54	1
Xylenes, Total	<0.40		1.0	0.40	ug/L			11/09/16 19:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	102		71 - 120		11/09/16 19:54	1
1,2-Dichloroethane-d4 (Surr)	95		71 - 127		11/09/16 19:54	1
Toluene-d8 (Surr)	98		75 - 120		11/09/16 19:54	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HEM (Oil & Grease)	<1.4		5.5	1.4	mg/L		11/08/16 17:18	11/08/16 19:45	1
Chloride	120		5.0	1.9	mg/L			11/10/16 04:54	25
Total Suspended Solids	3.0 J		5.0	2.5	mg/L			11/08/16 13:45	1

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-119736-3

Date Collected: 11/07/16 00:00

Matrix: Water

Date Received: 11/08/16 10:25

Method: 624 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			11/09/16 18:34	1
Bromoform	<0.45		1.0	0.45	ug/L			11/09/16 18:34	1
Carbon tetrachloride	<0.38		1.0	0.38	ug/L			11/09/16 18:34	1
Chloroform	<0.37		1.0	0.37	ug/L			11/09/16 18:34	1
cis-1,2-Dichloroethene	<0.41		1.0	0.41	ug/L			11/09/16 18:34	1
Dichlorobromomethane	<0.37		1.0	0.37	ug/L			11/09/16 18:34	1
1,2-Dichloroethane	<0.39		1.0	0.39	ug/L			11/09/16 18:34	1
1,1-Dichloroethene	<0.39		1.0	0.39	ug/L			11/09/16 18:34	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			11/09/16 18:34	1
Methyl bromide	<0.65		2.0	0.65	ug/L			11/09/16 18:34	1
Methyl chloride	<0.32		1.0	0.32	ug/L			11/09/16 18:34	1
Methyl tert-butyl ether	<0.39		1.0	0.39	ug/L			11/09/16 18:34	1
1,1,2,2-Tetrachloroethane	<0.40		1.0	0.40	ug/L			11/09/16 18:34	1
Tetrachloroethene	<0.37		1.0	0.37	ug/L			11/09/16 18:34	1
Toluene	<0.15		0.50	0.15	ug/L			11/09/16 18:34	1
trans-1,2-Dichloroethene	<0.35		1.0	0.35	ug/L			11/09/16 18:34	1
1,1,1-Trichloroethane	<0.38		1.0	0.38	ug/L			11/09/16 18:34	1
1,1,2-Trichloroethane	<0.35		1.0	0.35	ug/L			11/09/16 18:34	1
Trichloroethene	<0.16		0.50	0.16	ug/L			11/09/16 18:34	1
Vinyl chloride	<0.20		0.50	0.20	ug/L			11/09/16 18:34	1
Xylenes, Total	<0.40		1.0	0.40	ug/L			11/09/16 18:34	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		71 - 120					11/09/16 18:34	1
1,2-Dichloroethane-d4 (Surr)	95		71 - 127					11/09/16 18:34	1
Toluene-d8 (Surr)	96		75 - 120					11/09/16 18:34	1

Definitions/Glossary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Qualifiers

General Chemistry

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

QC Association Summary

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

GC/MS VOA

Analysis Batch: 359899

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	624	
500-119736-1 - DL	Influent	Total/NA	Water	624	
500-119736-2	Effluent	Total/NA	Water	624	
500-119736-3	Trip Blank	Total/NA	Water	624	
MB 500-359899/7	Method Blank	Total/NA	Water	624	
LCS 500-359899/5	Lab Control Sample	Total/NA	Water	624	

General Chemistry

Analysis Batch: 359795

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	SM 2540D	
500-119736-2	Effluent	Total/NA	Water	SM 2540D	
MB 500-359795/1	Method Blank	Total/NA	Water	SM 2540D	
LCS 500-359795/2	Lab Control Sample	Total/NA	Water	SM 2540D	

Prep Batch: 359805

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	1664B	
500-119736-2	Effluent	Total/NA	Water	1664B	
MB 500-359805/1-A	Method Blank	Total/NA	Water	1664B	
LCS 500-359805/2-A	Lab Control Sample	Total/NA	Water	1664B	

Analysis Batch: 359808

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	1664B	359805
500-119736-2	Effluent	Total/NA	Water	1664B	359805
MB 500-359805/1-A	Method Blank	Total/NA	Water	1664B	359805
LCS 500-359805/2-A	Lab Control Sample	Total/NA	Water	1664B	359805

Analysis Batch: 360207

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	300.0	
500-119736-2	Effluent	Total/NA	Water	300.0	
MB 500-360207/23	Method Blank	Total/NA	Water	300.0	
LCS 500-360207/34	Lab Control Sample	Total/NA	Water	300.0	

Surrogate Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Method: 624 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB (71-120)	12DCE (71-127)	TOL (75-120)
500-119736-1	Influent	101	96	94
500-119736-1 - DL	Influent	99	95	94
500-119736-2	Effluent	102	95	98
500-119736-3	Trip Blank	99	95	96
LCS 500-359899/5	Lab Control Sample	99	94	97
MB 500-359899/7	Method Blank	104	95	97

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

12DCE = 1,2-Dichloroethane-d4 (Surr)

TOL = Toluene-d8 (Surr)

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Method: 624 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 500-359899/7
Matrix: Water
Analysis Batch: 359899

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			11/09/16 10:31	1
Bromoform	<0.45		1.0	0.45	ug/L			11/09/16 10:31	1
Carbon tetrachloride	<0.38		1.0	0.38	ug/L			11/09/16 10:31	1
Chloroform	<0.37		1.0	0.37	ug/L			11/09/16 10:31	1
cis-1,2-Dichloroethene	<0.41		1.0	0.41	ug/L			11/09/16 10:31	1
Dichlorobromomethane	<0.37		1.0	0.37	ug/L			11/09/16 10:31	1
1,2-Dichloroethane	<0.39		1.0	0.39	ug/L			11/09/16 10:31	1
1,1-Dichloroethene	<0.39		1.0	0.39	ug/L			11/09/16 10:31	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			11/09/16 10:31	1
Methyl bromide	<0.65		2.0	0.65	ug/L			11/09/16 10:31	1
Methyl chloride	<0.32		1.0	0.32	ug/L			11/09/16 10:31	1
Methyl tert-butyl ether	<0.39		1.0	0.39	ug/L			11/09/16 10:31	1
1,1,2,2-Tetrachloroethane	<0.40		1.0	0.40	ug/L			11/09/16 10:31	1
Tetrachloroethene	<0.37		1.0	0.37	ug/L			11/09/16 10:31	1
Toluene	<0.15		0.50	0.15	ug/L			11/09/16 10:31	1
trans-1,2-Dichloroethene	<0.35		1.0	0.35	ug/L			11/09/16 10:31	1
1,1,1-Trichloroethane	<0.38		1.0	0.38	ug/L			11/09/16 10:31	1
1,1,2-Trichloroethane	<0.35		1.0	0.35	ug/L			11/09/16 10:31	1
Trichloroethene	<0.16		0.50	0.16	ug/L			11/09/16 10:31	1
Vinyl chloride	<0.20		0.50	0.20	ug/L			11/09/16 10:31	1
Xylenes, Total	<0.40		1.0	0.40	ug/L			11/09/16 10:31	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	104		71 - 120		11/09/16 10:31	1
1,2-Dichloroethane-d4 (Surr)	95		71 - 127		11/09/16 10:31	1
Toluene-d8 (Surr)	97		75 - 120		11/09/16 10:31	1

Lab Sample ID: LCS 500-359899/5
Matrix: Water
Analysis Batch: 359899

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	50.0	43.4		ug/L		87	37 - 151
Bromoform	50.0	43.1		ug/L		86	45 - 169
Carbon tetrachloride	50.0	45.0		ug/L		90	70 - 140
Chloroform	50.0	45.3		ug/L		91	51 - 138
cis-1,2-Dichloroethene	50.0	48.0		ug/L		96	70 - 130
Dichlorobromomethane	50.0	40.4		ug/L		81	35 - 155
1,2-Dichloroethane	50.0	42.1		ug/L		84	49 - 155
1,1-Dichloroethene	50.0	50.6		ug/L		101	10 - 234
Ethylbenzene	50.0	45.2		ug/L		90	37 - 162
Methyl bromide	50.0	29.1		ug/L		58	10 - 242
Methyl chloride	50.0	41.2		ug/L		82	10 - 273
m&p-Xylene	50.0	43.6		ug/L		87	
o-Xylene	50.0	41.9		ug/L		84	
1,1,2,2-Tetrachloroethane	50.0	47.6		ug/L		95	46 - 157
Tetrachloroethene	50.0	46.4		ug/L		93	64 - 148
Toluene	50.0	43.4		ug/L		87	47 - 150

TestAmerica Chicago

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Method: 624 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 500-359899/5
Matrix: Water
Analysis Batch: 359899

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
trans-1,2-Dichloroethene	50.0	48.1		ug/L		96	54 - 156
1,1,1-Trichloroethane	50.0	46.8		ug/L		94	52 - 162
1,1,2-Trichloroethane	50.0	46.1		ug/L		92	52 - 150
Trichloroethene	50.0	49.8		ug/L		100	71 - 157
Vinyl chloride	50.0	35.1		ug/L		70	10 - 251

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	99		71 - 120
1,2-Dichloroethane-d4 (Surr)	94		71 - 127
Toluene-d8 (Surr)	97		75 - 120

Method: 1664B - HEM and SGT-HEM

Lab Sample ID: MB 500-359805/1-A
Matrix: Water
Analysis Batch: 359808

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 359805

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HEM (Oil & Grease)	<1.3		5.0	1.3	mg/L		11/08/16 15:37	11/08/16 18:08	1

Lab Sample ID: LCS 500-359805/2-A
Matrix: Water
Analysis Batch: 359808

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 359805

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
HEM (Oil & Grease)	40.0	36.20		mg/L		91	78 - 114

Method: 300.0 - Anions, Ion Chromatography

Lab Sample ID: MB 500-360207/23
Matrix: Water
Analysis Batch: 360207

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.076		0.20	0.076	mg/L			11/10/16 03:00	1

Lab Sample ID: LCS 500-360207/34
Matrix: Water
Analysis Batch: 360207

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Chloride	3.00	2.95		mg/L		98	90 - 110

TestAmerica Chicago

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Method: SM 2540D - Solids, Total Suspended (TSS)

Lab Sample ID: MB 500-359795/1
 Matrix: Water
 Analysis Batch: 359795

Client Sample ID: Method Blank
 Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Suspended Solids	<2.5		5.0	2.5	mg/L			11/08/16 13:20	1

Lab Sample ID: LCS 500-359795/2
 Matrix: Water
 Analysis Batch: 359795

Client Sample ID: Lab Control Sample
 Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Total Suspended Solids	200	194		mg/L		97	80 - 120

Lab Chronicle

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Client Sample ID: Influent

Date Collected: 11/07/16 07:25

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624		5	359899	11/09/16 19:01	PMF	TAL CHI
Total/NA	Analysis	624	DL	50	359899	11/09/16 19:27	PMF	TAL CHI
Total/NA	Prep	1664B			359805	11/08/16 17:13	ADK	TAL CHI
Total/NA	Analysis	1664B		1	359808	11/08/16 19:40	ADK	TAL CHI
Total/NA	Analysis	300.0		25	360207	11/10/16 04:41	CCK	TAL CHI
Total/NA	Analysis	SM 2540D		1	359795		SMO	TAL CHI
					(Start)	11/08/16 13:43		
					(End)	11/08/16 13:45		

Client Sample ID: Effluent

Date Collected: 11/07/16 07:30

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624		1	359899	11/09/16 19:54	PMF	TAL CHI
Total/NA	Prep	1664B			359805	11/08/16 17:18	ADK	TAL CHI
Total/NA	Analysis	1664B		1	359808	11/08/16 19:45	ADK	TAL CHI
Total/NA	Analysis	300.0		25	360207	11/10/16 04:54	CCK	TAL CHI
Total/NA	Analysis	SM 2540D		1	359795		SMO	TAL CHI
					(Start)	11/08/16 13:45		
					(End)	11/08/16 13:46		

Client Sample ID: Trip Blank

Date Collected: 11/07/16 00:00

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624		1	359899	11/09/16 18:34	PMF	TAL CHI

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

Certification Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-1

Laboratory: TestAmerica Chicago

The certifications listed below are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Wisconsin	State Program	5	999580010	08-31-17

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING


2417 Bond Street, University Park, IL 60484
 Phone: 708.534.5200 Fax: 708.534.5211

Report To (optional)
 Contact: Alina Sattoski + Andy Stehn
 Company: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Bill To (optional)
 Contact: Accounts Payable
 Company: MCC
 Address: 201 WAUBESA ST.
 Address: MADISON, WI
 Phone: _____
 Fax: _____
 PO#/Reference# 106985

Chain of Custody Record

Lab Job #: 500-19736
 Chain of Custody Number: _____
 Page 1 of 1
 Temperature °C of Cooler: 9.6

Client		Client Project #		Preservative		Parameter		Matrix		Preservative Key 1. HCL, Cool to 4°  500-119736 COC	
Project Name		Lab Project #		Matrix		Matrix		Matrix			
Project Location/State		Lab Project #		Matrix		Matrix		Matrix			
mcc										Comments for VOC + PAH see attached analyte list	
GETS / SVE											
MADISON, WI											
Alina Sattoski		Sardie Fredrick									
Lap ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix	VOC	PAH	BOD / TSS	Chloride	Oil + Grease
1		Influent	11/7/16	725	9	N	X	X	X	X	
2		Effluent	11/7/16	730	9	W	X	X	X	X	
3		Trip Blank	-	-	2	W	X				

Turnaround Time Required (Business Days)
 ___ 1 Day 2 Days ___ 5 Days ___ 7 Days ___ 10 Days ___ 15 Days ___ Other
 Requested Due Date _____

Sample Disposal
 Return to Client Disposal by Lab Archive for ___ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>Alina Sattoski</u> Company: <u>mcc</u> Date: <u>11/7/16</u> Time: <u>7:00</u>	Received By: <u>Devin Sanyal</u> Company: <u>THH</u> Date: <u>11/08/16</u> Time: <u>10:25</u>	Lab Courier: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____	Shipped: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____	Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments: _____

Lab Comments: _____

TAL-4124-500 (12/09)

500-119736

Parameter	Method
VOCs	
Bromoform	624
Carbon Tetrachloride	624
Dichlorobromomethane	624
1,2-Dichloroethane	624
1,1-Dichloroethylene	624
Methyl Bromide	624
Methyl Chloride	624
1,1,1,2-Tetrachloroethane	624
Tetrachloroethylene	624
1,1,2-Trichloroethane	624
1,1,1-Trichloroethane	624
Trichloroethylene	624
Vinyl Chloride	624
Cis-1,2-Dichloroethene	624
Trans-1,2-Dichloroethene	624
TSS	
Suspended Solids, Total	2540D
BTEX	
Benzene	624
Toluene	
Ethylbenzene	
Xylenes	


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15

(708) 534-5200
ORIGIN ID: JOTA <708> 534-5200
ALINA SATKOSKI
MADISON-KIPP CORPORATION
201 WAUBESA STREET
MADISON, WI 53704
UNITED STATES US

SHIP DATE: 24OCT16
ACTWGT: 50.00 LB MAN
CAD: 33264/CAFE3009

TO **SAMPLE LOGIN**
TESTAMERICA LABS
2417 BOND ST
UNIVERSITY PARK IL 60466
(708) 634-5200
REF: **5500-43456**

RMA: ||| ||| |||



FedEx
Express
E
J11101607260107

FedEx
TRK# 6514 8428 3600
0221

TUE - 08 NOV 10:30A
PRIORITY OVERNIGHT

79 JOTA

60466
IL-US ORD



*1800369-11/07-544-J3/CBB1/L4E8



500-119736 Waybill

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Login Sample Receipt Checklist

Client: Madison-Kipp Corporation

Job Number: 500-119736-1

Login Number: 119736

List Source: TestAmerica Chicago

List Number: 1

Creator: Sanchez, Ariel M

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	False	ON ICE
Cooler Temperature is recorded.	True	9.6
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Chicago

2417 Bond Street

University Park, IL 60484

Tel: (708)534-5200

TestAmerica Job ID: 500-119736-2

Client Project/Site: MadisonKipp - GETS/SVE

For:

Madison-Kipp Corporation

201 Waubesa Street

Madison, Wisconsin 53704

Attn: Alina Satkoski



Authorized for release by:

11/14/2016 3:14:08 PM

Sandie Fredrick, Project Manager II

(920)261-1660

sandie.fredrick@testamericainc.com

LINKS

Review your project
results through

TotalAccess

Have a Question?



Visit us at:

www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15



Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	5
Sample Summary	6
Client Sample Results	7
Definitions	9
QC Association	10
Surrogate Summary	11
QC Sample Results	12
Chronicle	14
Certification Summary	15
Chain of Custody	16
Receipt Checklists	21

Case Narrative

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Job ID: 500-119736-2

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-119736-2

Comments

No additional comments.

Receipt

The samples were received on 11/8/2016 10:25 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 9.6° C.

Receipt Exceptions

The following sample(s) was received at the laboratory outside the required temperature criteria: 9.6, On ice.

GC/MS Semi VOA

Method(s) 625 SIM: The continuing calibration verification (CCV) associated with batch 490-385438 recovered above the upper control limit for Benzo(a)pyrene and Benzo(k)fluoranthene. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The following samples are impacted: Influent (500-119736-1) and Effluent (500-119736-2).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

General Chemistry

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Organic Prep

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Detection Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Client Sample ID: Influent

Lab Sample ID: 500-119736-1

No Detections.

Client Sample ID: Effluent

Lab Sample ID: 500-119736-2

No Detections.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Method	Method Description	Protocol	Laboratory
625 SIM	Semivolatile Organic Compounds GC/MS (SIM)	40CFR136A	TAL NSH
SM 5210B	BOD, 5-Day	SM	TAL CHI

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

SM = "Standard Methods For The Examination Of Water And Wastewater",

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

TAL NSH = TestAmerica Nashville, 2960 Foster Creighton Drive, Nashville, TN 37204, TEL (615)726-0177

Sample Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-119736-1	Influent	Water	11/07/16 07:25	11/08/16 10:25
500-119736-2	Effluent	Water	11/07/16 07:30	11/08/16 10:25

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Client Sample ID: Influent

Date Collected: 11/07/16 07:25

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-1

Matrix: Water

Method: 625 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzo[a]anthracene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:18	1
Benzo[a]pyrene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:18	1
Benzo[b]fluoranthene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:18	1
Benzo[g,h,i]perylene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:18	1
Benzo[k]fluoranthene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:18	1
Chrysene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:18	1
Dibenz(a,h)anthracene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:18	1
Fluoranthene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:18	1
Indeno[1,2,3-cd]pyrene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:18	1
Naphthalene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:18	1
Phenanthrene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/11/16 14:04	1
Pyrene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:18	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5	67		27 - 120	11/09/16 15:32	11/09/16 23:18	1
Terphenyl-d14	58		13 - 120	11/09/16 15:32	11/09/16 23:18	1
2-Fluorobiphenyl (Surr)	60		10 - 120	11/09/16 15:32	11/09/16 23:18	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Biochemical Oxygen Demand	<2.0		2.0	2.0	mg/L			11/08/16 18:30	1

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Client Sample ID: Effluent

Date Collected: 11/07/16 07:30

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-2

Matrix: Water

Method: 625 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzo[a]anthracene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:37	1
Benzo[a]pyrene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:37	1
Benzo[b]fluoranthene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:37	1
Benzo[g,h,i]perylene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:37	1
Benzo[k]fluoranthene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:37	1
Chrysene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:37	1
Dibenz(a,h)anthracene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:37	1
Fluoranthene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:37	1
Indeno[1,2,3-cd]pyrene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 23:37	1
Naphthalene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:37	1
Phenanthrene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/11/16 14:23	1
Pyrene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 23:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5	46		27 - 120	11/09/16 15:32	11/09/16 23:37	1
Terphenyl-d14	54		13 - 120	11/09/16 15:32	11/09/16 23:37	1
2-Fluorobiphenyl (Surr)	43		10 - 120	11/09/16 15:32	11/09/16 23:37	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Biochemical Oxygen Demand	<2.0		2.0	2.0	mg/L			11/08/16 18:34	1

Definitions/Glossary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

QC Association Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

GC/MS Semi VOA

Prep Batch: 385336

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	625	
500-119736-2	Effluent	Total/NA	Water	625	
MB 490-385336/1-A	Method Blank	Total/NA	Water	625	
LCS 490-385336/2-A	Lab Control Sample	Total/NA	Water	625	
LCSD 490-385336/3-A	Lab Control Sample Dup	Total/NA	Water	625	

Analysis Batch: 385438

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	625 SIM	385336
500-119736-2	Effluent	Total/NA	Water	625 SIM	385336
MB 490-385336/1-A	Method Blank	Total/NA	Water	625 SIM	385336
LCS 490-385336/2-A	Lab Control Sample	Total/NA	Water	625 SIM	385336
LCSD 490-385336/3-A	Lab Control Sample Dup	Total/NA	Water	625 SIM	385336

Analysis Batch: 385976

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	625 SIM	385336
500-119736-2	Effluent	Total/NA	Water	625 SIM	385336

General Chemistry

Analysis Batch: 359787

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-119736-1	Influent	Total/NA	Water	SM 5210B	
500-119736-2	Effluent	Total/NA	Water	SM 5210B	
USB 500-359787/1	Method Blank	Total/NA	Water	SM 5210B	
LCS 500-359787/2	Lab Control Sample	Total/NA	Water	SM 5210B	

Surrogate Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Method: 625 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	NBZ	TPH	FBP
		(27-120)	(13-120)	(10-120)
500-119736-1	Influent	67	58	60
500-119736-2	Effluent	46	54	43
LCS 490-385336/2-A	Lab Control Sample	88	77	63
LCSD 490-385336/3-A	Lab Control Sample Dup	78	74	66
MB 490-385336/1-A	Method Blank	65	66	57

Surrogate Legend

NBZ = Nitrobenzene-d5

TPH = Terphenyl-d14

FBP = 2-Fluorobiphenyl (Surr)

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Method: 625 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 490-385336/1-A
Matrix: Water
Analysis Batch: 385438

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 385336

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzo[a]anthracene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 21:42	1
Benzo[a]pyrene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 21:42	1
Benzo[b]fluoranthene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 21:42	1
Benzo[g,h,i]perylene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1
Benzo[k]fluoranthene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1
Chrysene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1
Dibenz(a,h)anthracene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 21:42	1
Fluoranthene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1
Indeno[1,2,3-cd]pyrene	<0.025		0.050	0.025	ug/L		11/09/16 15:32	11/09/16 21:42	1
Naphthalene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1
Phenanthrene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1
Pyrene	<0.050		0.10	0.050	ug/L		11/09/16 15:32	11/09/16 21:42	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
Nitrobenzene-d5	65		27 - 120	11/09/16 15:32	11/09/16 21:42	1
Terphenyl-d14	66		13 - 120	11/09/16 15:32	11/09/16 21:42	1
2-Fluorobiphenyl (Surr)	57		10 - 120	11/09/16 15:32	11/09/16 21:42	1

Lab Sample ID: LCS 490-385336/2-A
Matrix: Water
Analysis Batch: 385438

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 385336

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Benzo[a]anthracene	4.00	2.49		ug/L		62	33 - 143
Benzo[a]pyrene	4.00	2.81		ug/L		70	17 - 163
Benzo[b]fluoranthene	4.00	2.54		ug/L		63	24 - 159
Benzo[g,h,i]perylene	4.00	2.51		ug/L		63	10 - 219
Benzo[k]fluoranthene	4.00	2.97		ug/L		74	11 - 162
Chrysene	4.00	2.93		ug/L		73	17 - 168
Dibenz(a,h)anthracene	4.00	2.41		ug/L		60	10 - 227
Fluoranthene	4.00	2.64		ug/L		66	26 - 137
Indeno[1,2,3-cd]pyrene	4.00	2.36		ug/L		59	10 - 171
Naphthalene	4.00	2.46		ug/L		62	21 - 133
Phenanthrene	4.00	2.20		ug/L		55	54 - 120
Pyrene	4.00	2.82		ug/L		70	52 - 115

Surrogate	LCS %Recovery	LCS Qualifier	Limits
Nitrobenzene-d5	88		27 - 120
Terphenyl-d14	77		13 - 120
2-Fluorobiphenyl (Surr)	63		10 - 120

Lab Sample ID: LCSD 490-385336/3-A
Matrix: Water
Analysis Batch: 385438

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 385336

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
Benzo[a]anthracene	4.00	2.37		ug/L		59	33 - 143	5	30

TestAmerica Chicago

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Method: 625 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCSD 490-385336/3-A
Matrix: Water
Analysis Batch: 385438

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 385336

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Benzo[a]pyrene	4.00	2.66		ug/L		67	17 - 163	5	30
Benzo[b]fluoranthene	4.00	2.43		ug/L		61	24 - 159	4	30
Benzo[g,h,i]perylene	4.00	2.36		ug/L		59	10 - 219	6	30
Benzo[k]fluoranthene	4.00	2.79		ug/L		70	11 - 162	6	30
Chrysene	4.00	2.85		ug/L		71	17 - 168	3	30
Dibenz(a,h)anthracene	4.00	2.23		ug/L		56	10 - 227	8	30
Fluoranthene	4.00	2.57		ug/L		64	26 - 137	3	30
Indeno[1,2,3-cd]pyrene	4.00	2.22		ug/L		56	10 - 171	6	30
Naphthalene	4.00	2.58		ug/L		64	21 - 133	4	30
Phenanthrene	4.00	2.20		ug/L		55	54 - 120	0	30
Pyrene	4.00	2.72		ug/L		68	52 - 115	4	30

Surrogate	LCSD %Recovery	LCSD Qualifier	LCSD Limits
Nitrobenzene-d5	78		27 - 120
Terphenyl-d14	74		13 - 120
2-Fluorobiphenyl (Surr)	66		10 - 120

Method: SM 5210B - BOD, 5-Day

Lab Sample ID: USB 500-359787/1
Matrix: Water
Analysis Batch: 359787

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	USB Result	USB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Biochemical Oxygen Demand	<2.0		2.0	2.0	mg/L			11/08/16 18:01	1

Lab Sample ID: LCS 500-359787/2
Matrix: Water
Analysis Batch: 359787

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Biochemical Oxygen Demand	198	201		mg/L		102	85 - 115

Lab Chronicle

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Client Sample ID: Influent

Date Collected: 11/07/16 07:25

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	625			385336	11/09/16 15:32	MRM	TAL NSH
Total/NA	Analysis	625 SIM		1	385438	11/09/16 23:18	LEG	TAL NSH
Total/NA	Prep	625			385336	11/09/16 15:32	MRM	TAL NSH
Total/NA	Analysis	625 SIM		1	385976	11/11/16 14:04	LEG	TAL NSH
Total/NA	Analysis	SM 5210B		1	359787		MAN	TAL CHI
					(Start)	11/08/16 18:30		
					(End)	11/08/16 18:34		

Client Sample ID: Effluent

Date Collected: 11/07/16 07:30

Date Received: 11/08/16 10:25

Lab Sample ID: 500-119736-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	625			385336	11/09/16 15:32	MRM	TAL NSH
Total/NA	Analysis	625 SIM		1	385438	11/09/16 23:37	LEG	TAL NSH
Total/NA	Prep	625			385336	11/09/16 15:32	MRM	TAL NSH
Total/NA	Analysis	625 SIM		1	385976	11/11/16 14:23	LEG	TAL NSH
Total/NA	Analysis	SM 5210B		1	359787		MAN	TAL CHI
					(Start)	11/08/16 18:34		
					(End)	11/08/16 18:37		

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

TAL NSH = TestAmerica Nashville, 2960 Foster Creighton Drive, Nashville, TN 37204, TEL (615)726-0177

Certification Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-119736-2

Laboratory: TestAmerica Chicago

The certifications listed below are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Wisconsin	State Program	5	999580010	08-31-17

Laboratory: TestAmerica Nashville

The certifications listed below are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Wisconsin	State Program	5	998020430	08-31-17

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING


2417 Bond Street, University Park, IL 60484
Phone: 708.534.5200 Fax: 708.534.5211

Report To (optional)
Contact: Alina Sattoski +
Company: Andy Stehn
Address: _____
Phone: _____
E-Mail: _____

Bill To (optional)
Contact: Accounts Payable
Company: MCC
Address: 201 WAUBESA ST.
Address: MADISON, WI
Phone: _____
Fax: _____
PO#/Reference# 106985

Chain of Custody Record

Lab Job #: 500-19736
Chain of Custody Number: _____
Page 1 of 1
Temperature °C of Cooler: 9.6

Client		Client Project #		Preservative		Parameter		Matrix		 Preservative Key 1. HCL, Cool to 4° 2. HCL, Cool to 4° 3. HCL, Cool to 4° 4. HCL, Cool to 4° 500-119736 COC	
Project Name		Lab Project #		Sampling		Matrix		VOC PAA BOD/TSY Chloride Oil + Grease			
Lap ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix	Matrix				
mcc		GETS/SVE		MADISON, WI		Sardie Fredrick				Comments for VOC + PAA + see attached analyte list	
1		Influent	11/7/16	725	9	W	X	X	X		
2		Effluent	11/7/16	730	9	W	X	X	X		
3		Trip Blank	-	-	2	W	X				

Turnaround Time Required (Business Days)
 ___ 1 Day ___ 2 Days ___ 5 Days ___ 7 Days ___ 10 Days ___ 15 Days ___ Other
 Requested Due Date _____

Sample Disposal
 Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>Alina Sattoski</u>	Company: <u>mcc</u>	Date: <u>11/7/16</u>	Time: <u>7:00</u>	Received By: <u>Devin Sanyal</u>	Company: <u>THH</u>	Date: <u>11/08/16</u>	Time: <u>10:25</u>	Lab Courier: _____
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____	Shipped: _____
Relinquished By: _____	Company: _____	Date: _____	Time: _____	Received By: _____	Company: _____	Date: _____	Time: _____	Hand Delivered: _____

Matrix Key WW - Wastewater SE - Sediment W - Water SO - Soil S - Soil L - Leachate SL - Sludge WI - Wipe MS - Miscellaneous DW - Drinking Water OL - Oil O - Other A - Air	Client Comments	Lab Comments
--	-----------------	--------------

TAL-4124-500 (12/09)

500-119736

Parameter	Method
VOCs	
Bromoform	624
Carbon Tetrachloride	624
Dichlorobromomethane	624
1,2-Dichloroethane	624
1,1-Dichloroethylene	624
Methyl Bromide	624
Methyl Chloride	624
1,1,1,2-Tetrachloroethane	624
Tetrachloroethylene	624
1,1,2-Trichloroethane	624
1,1,1-Trichloroethane	624
Trichloroethylene	624
Vinyl Chloride	624
Cis-1,2-Dichloroethene	624
Trans-1,2-Dichloroethene	624
TSS	
Suspended Solids, Total	2540D
BTEX	
Benzene	624
Toluene	
Ethylbenzene	
Xylenes	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15


(708) 534-5200
ORIGIN ID: JOTA <708> 534-5200
ALINA SATKOSKI
MADISON-KIPP CORPORATION
201 WAUBESA STREET
MADISON, WI 53704
UNITED STATES US

SHIP DATE: 24OCT16
ACTWGT: 50.00 LB MAN
CAD: 33264/CAFE3009

TO **SAMPLE LOGIN**
TESTAMERICA LABS
2417 BOND ST

UNIVERSITY PARK IL 60466
(708) 634-5200
REF: **5500-43456**

RMA: ||| ||| |||




FedEx
TRK# 6514 8428 3600
0221

TUE - 08 NOV 10:30A
PRIORITY OVERNIGHT

79 JOTA

60466
IL-US ORD



*1800369-11/07-544-J3/CBB1/L4E8



500-119736 Waybill

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

COOLER RECEIPT FORM



500-119736 Chain of Custody

Cooler Received/Opened On 11/9/2016 @0900

Time Samples Removed From Cooler 1140 Time Samples Placed In Storage 1145 (2 Hour Window)

1. Tracking # 9310 (last 4 digits, FedEx) Courier: Fedex

IR Gun ID 31470368 pH Strip Lot HC642547 Chlorine Strip Lot 061316w

2. Temperature of rep. sample or temp blank when opened: 1-3 Degrees Celsius

3. If Item #2 temperature is 0°C or less, was the representative sample or temp blank frozen? YES NO NA

4. Were custody seals on outside of cooler? YES...NO...NA

If yes, how many and where: 2 front/back

5. Were the seals intact, signed, and dated correctly? YES...NO...NA

6. Were custody papers inside cooler? YES...NO...NA

I certify that I opened the cooler and answered questions 1-6 (initial) J

7. Were custody seals on containers: YES NO and Intact YES...NO...NA

Were these signed and dated correctly? YES...NO...NA

8. Packing mat'l used? Bubblewrap Plastic bag Peanuts Vermiculite Foam Insert Paper Other None

9. Cooling process: Ice Ice-pack Ice (direct contact) Dry ice Other None

10. Did all containers arrive in good condition (unbroken)? YES...NO...NA

11. Were all container labels complete (#, date, signed, pres., etc)? YES...NO...NA

12. Did all container labels and tags agree with custody papers? YES...NO...NA

13a. Were VOA vials received? YES...NO...NA

b. Was there any observable headspace present in any VOA vial? YES...NO...NA

14. Was there a Trip Blank in this cooler? YES...NO...NA If multiple coolers, sequence # _____

I certify that I unloaded the cooler and answered questions 7-14 (initial) HG

15a. On pres'd bottles, did pH test strips suggest preservation reached the correct pH level? YES...NO...NA

b. Did the bottle labels indicate that the correct preservatives were used YES...NO...NA

16. Was residual chlorine present? YES...NO...NA

I certify that I checked for chlorine and pH as per SOP and answered questions 15-16 (initial) HG

17. Were custody papers properly filled out (ink, signed, etc)? YES...NO...NA

18. Did you sign the custody papers in the appropriate place? YES...NO...NA

19. Were correct containers used for the analysis requested? YES...NO...NA

20. Was sufficient amount of sample sent in each container? YES...NO...NA

I certify that I entered this project into LIMS and answered questions 17-20 (initial) HG

I certify that I attached a label with the unique LIMS number to each container (initial) HG

21. Were there Non-Conformance issues at login? YES...NO Was a NCM generated? YES...NO..# _____

TestAmerica Chicago

2417 Bond Street
 University Park, IL 60484
 Phone (708) 534-5200 Fax (708) 534-5211

Chain of Custody Record

Loc: 500
119736



Client Information (Sub Contract Lab)

Client Contact: Shipping/Receiving
 Company: TestAmerica Laboratories, Inc
 Address: 2960 Foster Creighton Drive,
 City: Nashville
 State, Zip: TN, 37204
 Phone: 615-726-0177(Tel) 615-726-3404(Fax)
 Email: MadisonKipp - GETS/SVE
 Project Name: MadisonKipp - GETS/SVE
 Site: SSO#W#

Sampler: Fredrick, Sandie J
 E-Mail: sandie.fredrick@testamericainc.com
 Accreditations Required (See note): State Program - Wisconsin

Wisconsin

Job #: 500-119736-2

Page 1 of 1

Due Date Requested: 11/11/2016

TAT Requested (days):

Analysis Requested

Preservation Codes:

Project #: 50009145
 SSO#W#

Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Analysis Requested
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	625_SIM/625_Prep_LVI (MOD) Single compound

- A - HCL
- B - NaOH
- C - Zn Acetate
- D - Nitric Acid
- E - NaHSO4
- F - MeOH
- G - Amnolite
- H - Ascorbic Acid
- I - Ice
- J - DI Water
- K - EDTA
- L - EDA
- M - Hexane
- N - None
- O - AsHClO2
- P - Na2OAS
- Q - Na2SO3
- R - Na2S2O3
- S - H2SO4
- T - TSP Dodecylhydrate
- U - Acetone
- V - MCAA
- W - PH 4-5
- Z - other (Specify)

Sample Identification - Client ID (Lab ID)

Sample ID	Sample Date	Sample Time	Sample Type (G=grab, B=In-Tank, Ash)	Matrix (W=Water, S=solid, O=Organic, A=Asphalt)
Influent (500-119736-1)	11/7/16	07:25	Central	Water
Effluent (500-119736-2)	11/7/16	07:30	Central	Water

Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Analysis Requested	Total Number of containers
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	625_SIM/625_Prep_LVI (MOD) Single compound	2

Special Instructions/Note:

Note: Since laboratory accreditations are subject to change, TestAmerica Laboratories, Inc. places the ownership of method, analysis & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/mark being analyzed, the samples must be shipped back to the TestAmerica laboratory or other institutions will be provided. Any changes to accreditation status should be brought to TestAmerica Laboratories, Inc. attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to TestAmerica Laboratories, Inc.

Possible Hazard Identification

Unconfirmed Deliverable Requested: I, II, III, IV, Other (specify)

Primary Deliverable Rank: 2

Special Instructions/QC Requirements:

Empty Kit Relinquished by:

Date:

Time:

Method of Shipment:

Relinquished by: *[Signature]*

Date/Time: 11/08/16

Time: 0900

Company: TAN

Company: TAN

Received by: *[Signature]*

Date/Time: 11/9/16

Time: 0900

Company: TAN

Company: TAN

Custody Seals Intact: Yes No

Custody Seal No.:

Cooler Temperature(s) °C and Other Remarks:

Login Sample Receipt Checklist

Client: Madison-Kipp Corporation

Job Number: 500-119736-2

Login Number: 119736

List Source: TestAmerica Chicago

List Number: 1

Creator: Sanchez, Ariel M

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	False	ON ICE
Cooler Temperature is recorded.	True	9.6
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	



Login Sample Receipt Checklist

Client: Madison-Kipp Corporation

Job Number: 500-119736-2

Login Number: 119736
List Number: 2
Creator: Gundi, Hozar K

List Source: TestAmerica Nashville
List Creation: 11/09/16 11:29 AM

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

