



August 3, 2017

Emily James
Wisconsin Department of Natural Resources
South Central Region
3911 Fish Hatchery Rd.
Fitchburg, WI 53711

Subject: Discharge Monitoring Report - Groundwater Extraction and Treatment System,
Madison-Kipp Corporation, 201 Waubesa Street, Madison, Wisconsin

Dear Ms. James,

The Groundwater Extraction and Treatment System (GETS) ran for the month of July with the exception of maintenance activities. This letter summarizes the activities completed in July 2017 as part of the GETS at the Madison-Kipp Corporation (MKC) site under the Wisconsin Pollution Discharge Elimination System (WPDES) Permit WI-0046566-6. Compliance samples were collected for volatile organic compounds (VOCs) and visual monitoring for sodium permanganate on July 11, 2017. The compliance sample results were below the WPDES discharge limits. The Discharge Monitoring Report is included as Attachment A and laboratory reports are included as Attachment B.

The GETS flow rate was operated at 40 gallons per minute (gpm) between July 1 and July 6, 2017 to avoid water extraction into the vapor phase activated carbon vessels while repairs to the soil vapor extraction (SVE) were completed. The GETS shut down multiple times throughout the month due to system faults related to air bubbles in the peroxide feed line. We continue to troubleshoot this issue. If you have any questions or need additional information, please contact me at asatkoski@madison-kipp.com or (608) 242-5200.

Alina Satkoski

A handwritten signature in blue ink that reads "Alina Satkoski".

Madison-Kipp Corporation

Attachment A Discharge Monitoring Report Form

Attachment B Laboratory Reports

Copies:

Andrew Stehn - TRC (electronic)

Mike Schmoller - WDNR (electronic)

Wendy Weihemuller - WDNR (electronic)

George Parrino - Madison Department of Health (electronic)

FOOTNOTES:

- (1) Total BTEX is the sum of the benzene, ethylbenzene, toluene and xylene concentrations. If all compounds were below their corresponding laboratory detection limits, then the highest detection limit of the BTEX compounds was noted.
- (2) PAH group of 10 (Polynuclear Aromatic Hydrocarbons) include the sum of the following individual compounds: benzo(a)anthracene, benzo(b)fluoranthene, benzo(g,h,i)perylene, benzo(k)fluoranthene, chrysene, dibenzo(a,h)anthracene, fluoranthene, indeno(1,2,3-cd)pyrene, phenanthrene, and pyrene. If all compounds were below their corresponding laboratory detection limits, then the highest detection limit of the PAH group compounds was noted.
- (3) Madison-Kipp/TRC will conduct visual monitoring for this compound.
- (4) No effluent limit is established, refer to section 4 of the permit.
- (5) Compound was found in the blank and in the sample.
- (6) Estimated value. Analyte detected at a level less than the reporting limit and greater than or equal to the detection limit.
- (7) Matrix Spike and/or Matrix Spike Duplicate Recovery is outside acceptance limits.
- (8) Between July 1 and July 6, the GETS extraction well was operated at 40 gpm.

DIRECTIONS:

- ☞ For "Outfall # and Description" enter the number of the outfall you are reporting (001 or 002, etc.) and the source of wastewater, (petroleum contact, tank bottom water, scrap and waste storage area oily water, or secondary containment). Copy and use a new form for each outfall.
- ☞ Monitoring for a given parameter depends on if the discharge is to surface water or groundwater, and petroleum category.
- ☞ The value entered must be the highest value of all samples analyzed for that day.
- ☞ For each quarter, indicate the month monitoring occurred next to "Month"
- ☞ Include as separate attachments to this form the annual reports for (a) waste oil and solids removed, and (b) tank bottom water disposal.

RETURN REPORT BY: **February 15, of the year following completion of monitoring**

RETURN TO: **ATTN: Nicholas Bertolas**
Department of Natural Resources
3911 Fish Hatchery Rd.
Fitchburg, WI 53711

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment, (40 CFR 122.5). I also certify that the values being submitted are the actual values found in the samples; no values have been modified or changed in any manner. Wherever I believe a value being reported is inaccurate, I have added an explanation indicating the reasons why the value is inaccurate.

Aina Lattest

8-3-2017

Signature of Person Completing Form

Date

Aina Lattest

8-3-2017

Signature of Principal Exec. or Authorized Agent

Date

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Chicago

2417 Bond Street

University Park, IL 60484

Tel: (708)534-5200

TestAmerica Job ID: 500-130879-1

Client Project/Site: MadisonKipp - GETS/SVE

For:

Madison-Kipp Corporation

201 Waubesa Street

Madison, Wisconsin 53704

Attn: Alina Satkoski



Authorized for release by:

7/14/2017 1:04:12 PM

Eric Lang, Manager of Project Management

(708)534-5200

eric.lang@testamericainc.com

Designee for

Sandie Fredrick, Project Manager II

(920)261-1660

sandie.fredrick@testamericainc.com

LINKS

Review your project
results through

TotalAccess

Have a Question?



Visit us at:

www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15



Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	5
Sample Summary	6
Client Sample Results	7
Definitions	10
QC Association	11
Surrogate Summary	12
QC Sample Results	13
Chronicle	15
Certification Summary	16
Chain of Custody	17
Receipt Checklists	19

Case Narrative

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Job ID: 500-130879-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-130879-1

Comments

No additional comments.

Receipt

The samples were received on 7/12/2017 2:58 PM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 5.6° C.

GC/MS VOA

Method(s) 624: The following sample was diluted to bring the concentration of target analytes within the calibration range: Influent (500-130879-1). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.



Detection Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Client Sample ID: Influent

Lab Sample ID: 500-130879-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	49		5.0	2.0	ug/L	5		624	Total/NA
Trichloroethene	110		2.5	0.82	ug/L	5		624	Total/NA
Tetrachloroethene - DL	1700		50	19	ug/L	50		624	Total/NA

Client Sample ID: Effluent

Lab Sample ID: 500-130879-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	22		1.0	0.41	ug/L	1		624	Total/NA
Tetrachloroethene	34		1.0	0.37	ug/L	1		624	Total/NA
Trichloroethene	9.7		0.50	0.16	ug/L	1		624	Total/NA

Client Sample ID: Trip Blank

Lab Sample ID: 500-130879-3

No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Chicago

Method Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Method	Method Description	Protocol	Laboratory
624	Volatile Organic Compounds (GC/MS)	40CFR136A	TAL CHI

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Sample Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-130879-1	Influent	Water	07/11/17 09:30	07/12/17 14:58
500-130879-2	Effluent	Water	07/11/17 09:35	07/12/17 14:58
500-130879-3	Trip Blank	Water	07/11/17 00:00	07/12/17 14:58

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Client Sample ID: Infiltrant

Lab Sample ID: 500-130879-1

Date Collected: 07/11/17 09:30

Matrix: Water

Date Received: 07/12/17 14:58

Method: 624 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.73		2.5	0.73	ug/L			07/13/17 11:33	5
Bromoform	<2.2		5.0	2.2	ug/L			07/13/17 11:33	5
Carbon tetrachloride	<1.9		5.0	1.9	ug/L			07/13/17 11:33	5
Chloroform	<1.9		10	1.9	ug/L			07/13/17 11:33	5
cis-1,2-Dichloroethene	49		5.0	2.0	ug/L			07/13/17 11:33	5
Dichlorobromomethane	<1.9		5.0	1.9	ug/L			07/13/17 11:33	5
1,2-Dichloroethane	<2.0		5.0	2.0	ug/L			07/13/17 11:33	5
1,1-Dichloroethene	<2.0		5.0	2.0	ug/L			07/13/17 11:33	5
Ethylbenzene	<0.92		2.5	0.92	ug/L			07/13/17 11:33	5
Methyl bromide	<3.2		10	3.2	ug/L			07/13/17 11:33	5
Methyl chloride	<1.6		5.0	1.6	ug/L			07/13/17 11:33	5
Methyl tert-butyl ether	<2.0		5.0	2.0	ug/L			07/13/17 11:33	5
1,1,1,2-Tetrachloroethane	<2.0		5.0	2.0	ug/L			07/13/17 11:33	5
Toluene	<0.76		2.5	0.76	ug/L			07/13/17 11:33	5
trans-1,2-Dichloroethene	<1.7		5.0	1.7	ug/L			07/13/17 11:33	5
1,1,1-Trichloroethane	<1.9		5.0	1.9	ug/L			07/13/17 11:33	5
1,1,2-Trichloroethane	<1.8		5.0	1.8	ug/L			07/13/17 11:33	5
Trichloroethene	110		2.5	0.82	ug/L			07/13/17 11:33	5
Vinyl chloride	<1.0		2.5	1.0	ug/L			07/13/17 11:33	5
Xylenes, Total	<2.0		5.0	2.0	ug/L			07/13/17 11:33	5

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	84		71 - 120		07/13/17 11:33	5
1,2-Dichloroethane-d4 (Surr)	85		71 - 127		07/13/17 11:33	5
Toluene-d8 (Surr)	91		75 - 120		07/13/17 11:33	5

Method: 624 - Volatile Organic Compounds (GC/MS) - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tetrachloroethene	1700		50	19	ug/L			07/13/17 11:59	50

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	84		71 - 120		07/13/17 11:59	50
1,2-Dichloroethane-d4 (Surr)	87		71 - 127		07/13/17 11:59	50
Toluene-d8 (Surr)	90		75 - 120		07/13/17 11:59	50

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Client Sample ID: Effluent

Lab Sample ID: 500-130879-2

Date Collected: 07/11/17 09:35

Matrix: Water

Date Received: 07/12/17 14:58

Method: 624 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			07/13/17 12:25	1
Bromoform	<0.45		1.0	0.45	ug/L			07/13/17 12:25	1
Carbon tetrachloride	<0.38		1.0	0.38	ug/L			07/13/17 12:25	1
Chloroform	<0.37		2.0	0.37	ug/L			07/13/17 12:25	1
cis-1,2-Dichloroethene	22		1.0	0.41	ug/L			07/13/17 12:25	1
Dichlorobromomethane	<0.37		1.0	0.37	ug/L			07/13/17 12:25	1
1,2-Dichloroethane	<0.39		1.0	0.39	ug/L			07/13/17 12:25	1
1,1-Dichloroethene	<0.39		1.0	0.39	ug/L			07/13/17 12:25	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			07/13/17 12:25	1
Methyl bromide	<0.65		2.0	0.65	ug/L			07/13/17 12:25	1
Methyl chloride	<0.32		1.0	0.32	ug/L			07/13/17 12:25	1
Methyl tert-butyl ether	<0.39		1.0	0.39	ug/L			07/13/17 12:25	1
1,1,2,2-Tetrachloroethane	<0.40		1.0	0.40	ug/L			07/13/17 12:25	1
Tetrachloroethene	34		1.0	0.37	ug/L			07/13/17 12:25	1
Toluene	<0.15		0.50	0.15	ug/L			07/13/17 12:25	1
trans-1,2-Dichloroethene	<0.35		1.0	0.35	ug/L			07/13/17 12:25	1
1,1,1-Trichloroethane	<0.38		1.0	0.38	ug/L			07/13/17 12:25	1
1,1,2-Trichloroethane	<0.35		1.0	0.35	ug/L			07/13/17 12:25	1
Trichloroethene	9.7		0.50	0.16	ug/L			07/13/17 12:25	1
Vinyl chloride	<0.20		0.50	0.20	ug/L			07/13/17 12:25	1
Xylenes, Total	<0.40		1.0	0.40	ug/L			07/13/17 12:25	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	83		71 - 120		07/13/17 12:25	1
1,2-Dichloroethane-d4 (Surr)	83		71 - 127		07/13/17 12:25	1
Toluene-d8 (Surr)	92		75 - 120		07/13/17 12:25	1

Client Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Client Sample ID: Trip Blank

Lab Sample ID: 500-130879-3

Date Collected: 07/11/17 00:00

Matrix: Water

Date Received: 07/12/17 14:58

Method: 624 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			07/13/17 11:06	1
Bromoform	<0.45		1.0	0.45	ug/L			07/13/17 11:06	1
Carbon tetrachloride	<0.38		1.0	0.38	ug/L			07/13/17 11:06	1
Chloroform	<0.37		2.0	0.37	ug/L			07/13/17 11:06	1
cis-1,2-Dichloroethene	<0.41		1.0	0.41	ug/L			07/13/17 11:06	1
Dichlorobromomethane	<0.37		1.0	0.37	ug/L			07/13/17 11:06	1
1,2-Dichloroethane	<0.39		1.0	0.39	ug/L			07/13/17 11:06	1
1,1-Dichloroethene	<0.39		1.0	0.39	ug/L			07/13/17 11:06	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			07/13/17 11:06	1
Methyl bromide	<0.65		2.0	0.65	ug/L			07/13/17 11:06	1
Methyl chloride	<0.32		1.0	0.32	ug/L			07/13/17 11:06	1
Methyl tert-butyl ether	<0.39		1.0	0.39	ug/L			07/13/17 11:06	1
1,1,2,2-Tetrachloroethane	<0.40		1.0	0.40	ug/L			07/13/17 11:06	1
Tetrachloroethene	<0.37		1.0	0.37	ug/L			07/13/17 11:06	1
Toluene	<0.15		0.50	0.15	ug/L			07/13/17 11:06	1
trans-1,2-Dichloroethene	<0.35		1.0	0.35	ug/L			07/13/17 11:06	1
1,1,1-Trichloroethane	<0.38		1.0	0.38	ug/L			07/13/17 11:06	1
1,1,2-Trichloroethane	<0.35		1.0	0.35	ug/L			07/13/17 11:06	1
Trichloroethene	<0.16		0.50	0.16	ug/L			07/13/17 11:06	1
Vinyl chloride	<0.20		0.50	0.20	ug/L			07/13/17 11:06	1
Xylenes, Total	<0.40		1.0	0.40	ug/L			07/13/17 11:06	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	83		71 - 120		07/13/17 11:06	1
1,2-Dichloroethane-d4 (Surr)	85		71 - 127		07/13/17 11:06	1
Toluene-d8 (Surr)	91		75 - 120		07/13/17 11:06	1

Definitions/Glossary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

QC Association Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

GC/MS VOA

Analysis Batch: 392891

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-130879-1	Influent	Total/NA	Water	624	
500-130879-1 - DL	Influent	Total/NA	Water	624	
500-130879-2	Effluent	Total/NA	Water	624	
500-130879-3	Trip Blank	Total/NA	Water	624	
MB 500-392891/8	Method Blank	Total/NA	Water	624	
LCS 500-392891/5	Lab Control Sample	Total/NA	Water	624	

Surrogate Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Method: 624 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB (71-120)	12DCE (71-127)	TOL (75-120)
500-130879-1	Influent	84	85	91
500-130879-1 - DL	Influent	84	87	90
500-130879-2	Effluent	83	83	92
500-130879-3	Trip Blank	83	85	91
LCS 500-392891/5	Lab Control Sample	80	81	92
MB 500-392891/8	Method Blank	84	82	92

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

12DCE = 1,2-Dichloroethane-d4 (Surr)

TOL = Toluene-d8 (Surr)

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Method: 624 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 500-392891/8
Matrix: Water
Analysis Batch: 392891

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.15		0.50	0.15	ug/L			07/13/17 10:14	1
Bromoform	<0.45		1.0	0.45	ug/L			07/13/17 10:14	1
Carbon tetrachloride	<0.38		1.0	0.38	ug/L			07/13/17 10:14	1
Chloroform	<0.37		2.0	0.37	ug/L			07/13/17 10:14	1
cis-1,2-Dichloroethene	<0.41		1.0	0.41	ug/L			07/13/17 10:14	1
Dichlorobromomethane	<0.37		1.0	0.37	ug/L			07/13/17 10:14	1
1,2-Dichloroethane	<0.39		1.0	0.39	ug/L			07/13/17 10:14	1
1,1-Dichloroethene	<0.39		1.0	0.39	ug/L			07/13/17 10:14	1
Ethylbenzene	<0.18		0.50	0.18	ug/L			07/13/17 10:14	1
Methyl bromide	<0.65		2.0	0.65	ug/L			07/13/17 10:14	1
Methyl chloride	<0.32		1.0	0.32	ug/L			07/13/17 10:14	1
Methyl tert-butyl ether	<0.39		1.0	0.39	ug/L			07/13/17 10:14	1
1,1,2,2-Tetrachloroethane	<0.40		1.0	0.40	ug/L			07/13/17 10:14	1
Tetrachloroethene	<0.37		1.0	0.37	ug/L			07/13/17 10:14	1
Toluene	<0.15		0.50	0.15	ug/L			07/13/17 10:14	1
trans-1,2-Dichloroethene	<0.35		1.0	0.35	ug/L			07/13/17 10:14	1
1,1,1-Trichloroethane	<0.38		1.0	0.38	ug/L			07/13/17 10:14	1
1,1,2-Trichloroethane	<0.35		1.0	0.35	ug/L			07/13/17 10:14	1
Trichloroethene	<0.16		0.50	0.16	ug/L			07/13/17 10:14	1
Vinyl chloride	<0.20		0.50	0.20	ug/L			07/13/17 10:14	1
Xylenes, Total	<0.40		1.0	0.40	ug/L			07/13/17 10:14	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	84		71 - 120		07/13/17 10:14	1
1,2-Dichloroethane-d4 (Surr)	82		71 - 127		07/13/17 10:14	1
Toluene-d8 (Surr)	92		75 - 120		07/13/17 10:14	1

Lab Sample ID: LCS 500-392891/5
Matrix: Water
Analysis Batch: 392891

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	50.0	48.0		ug/L		96	37 - 151
Bromoform	50.0	50.4		ug/L		101	45 - 169
Carbon tetrachloride	50.0	48.3		ug/L		97	70 - 140
Chloroform	50.0	47.5		ug/L		95	51 - 138
cis-1,2-Dichloroethene	50.0	52.4		ug/L		105	70 - 130
Dichlorobromomethane	50.0	45.0		ug/L		90	35 - 155
1,2-Dichloroethane	50.0	44.7		ug/L		89	49 - 155
1,1-Dichloroethene	50.0	59.5		ug/L		119	10 - 234
Ethylbenzene	50.0	53.6		ug/L		107	37 - 162
Methyl bromide	50.0	56.3		ug/L		113	10 - 242
Methyl chloride	50.0	69.9		ug/L		140	10 - 273
m&p-Xylene	50.0	46.9		ug/L		94	
o-Xylene	50.0	47.2		ug/L		94	
1,1,2,2-Tetrachloroethane	50.0	45.2		ug/L		90	46 - 157
Tetrachloroethene	50.0	56.9		ug/L		114	64 - 148
Toluene	50.0	48.1		ug/L		96	47 - 150

TestAmerica Chicago

QC Sample Results

Client: Madison-Kipp Corporation
 Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Method: 624 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 500-392891/5
 Matrix: Water
 Analysis Batch: 392891

Client Sample ID: Lab Control Sample
 Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
trans-1,2-Dichloroethene	50.0	57.0		ug/L		114	54 - 156
1,1,1-Trichloroethane	50.0	50.9		ug/L		102	52 - 162
1,1,2-Trichloroethane	50.0	49.7		ug/L		99	52 - 150
Trichloroethene	50.0	57.3		ug/L		115	71 - 157
Vinyl chloride	50.0	45.4		ug/L		91	10 - 251

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	80		71 - 120
1,2-Dichloroethane-d4 (Surr)	81		71 - 127
Toluene-d8 (Surr)	92		75 - 120

Lab Chronicle

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Client Sample ID: Influent

Date Collected: 07/11/17 09:30

Date Received: 07/12/17 14:58

Lab Sample ID: 500-130879-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624		5	392891	07/13/17 11:33	PMF	TAL CHI
Total/NA	Analysis	624	DL	50	392891	07/13/17 11:59	PMF	TAL CHI

Client Sample ID: Effluent

Date Collected: 07/11/17 09:35

Date Received: 07/12/17 14:58

Lab Sample ID: 500-130879-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624		1	392891	07/13/17 12:25	PMF	TAL CHI

Client Sample ID: Trip Blank

Date Collected: 07/11/17 00:00

Date Received: 07/12/17 14:58

Lab Sample ID: 500-130879-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624		1	392891	07/13/17 11:06	PMF	TAL CHI

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

Accreditation/Certification Summary

Client: Madison-Kipp Corporation
Project/Site: MadisonKipp - GETS/SVE

TestAmerica Job ID: 500-130879-1

Laboratory: TestAmerica Chicago

The accreditations/certifications listed below are applicable to this report.

Authority	Program	EPA Region	Identification Number	Expiration Date
Wisconsin	State Program	5	999580010	08-31-17 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

TestAmerica

THE LEADER IN ENVIRONMENTAL

2417 Bond Street, University Park, IL
Phone: 708.534.5200 Fax: 708.534.5200



500-130879 COC

Report To (optional)
Contact: Alina Satkosti/
Company: Andy Stehn
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To (optional)
Contact: Accounts Payable
Company: mkc
Address: ap@madison-kipp-
cdm
Address: _____
Phone: _____
Fax: _____
PO#/Reference#: 106985

Chain of Custody Record

Lab Job #: 500-130879
Chain of Custody Number: _____
Page 1 of 1
Temperature °C of Cooler: 5.6

Client		Client Project #		Preservative		Parameter		Comments	
mkc								Preservative Key 1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. NaHSO4 7. Cool to 4° 8. None 9. Other	
Project Name		Lab Project #		Sampling		Matrix		Comments	
GETS									
Project Location/State		Lab Project #		Date		Time		Comments	
Madison, WI									
Sampler		Lab PM		# of Containers		Matrix		Comments	
Alina Satkosti		Sandie Fredrick							
Lab ID	MS/MSD	Sample ID	Date	Time	# of Containers	Matrix			
1		Influent	7/11/17	930	3 W	X			See attached
2		Effluent	7/11/17	935	3 W	X			analyte list
3		Trip Blank	-	-	1 W	X			for VOC.

Turnaround Time Required (Business Days): 1 Day 2 Days 5 Days 7 Days 10 Days 15 Days Other
Requested Due Date: _____

Sample Disposal: Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <u>Alina Satkosti</u> Company: <u>mkc</u> Date: <u>7/11/17</u> Time: <u>14:00</u>	Received By: <u>[Signature]</u> Company: <u>TA</u> Date: <u>7-12-17</u> Time: <u>0930</u>	Lab Courier: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____	Shipped: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____	Hand Delivered: _____

- Matrix Key
- WW - Wastewater
 - W - Water
 - S - Soil
 - SL - Sludge
 - MS - Miscellaneous
 - OL - Oil
 - A - Air
 - SE - Sediment
 - SO - Soil
 - L - Leachate
 - WI - Wipe
 - DW - Drinking Water
 - O - Other

Client Comments: _____

Lab Comments: _____

ORIGIN ID: JOTA (708) 534-5200
ALINA SATKOSKI
MADISON-KIPP CORPORATION
201 WAUBESA STREET

SHIP DATE: 09JUN17
ACTWT: 20.00 LB MAN
CAD: 33264/CAFE3011

MADISON, WI 53704
UNITED STATES US


TO **SAMPLE LOGIN**
TESTAMERICA LABS
2417 BOND ST

UNIVERSITY PARK IL 60466

(708) 534-5200

REF: S500-54230 AN

RMA: ||| ||| |||



FedEx
Express



540CL/AS02/727F



500-130879 Waybill

FedEx


TRK# 6514 8435 6940
0221

WED - 12 JUL 10:30A
PRIORITY OVERNIGHT

79 JOTA

60466
IL-US **ORD**

PRI 1216101001 NY
435
8/14/17



0221 07/11 546J1/COC2/53C1

28qt.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Login Sample Receipt Checklist

Client: Madison-Kipp Corporation

Job Number: 500-130879-1

Login Number: 130879

List Source: TestAmerica Chicago

List Number: 1

Creator: James, Jeff A

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	5.6
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	