## WI DNR Public Record Provision of the Energy Policy Act of 2005

## **Summary Information for Releases**

Number of Confirmed UST Releases:60Release reporting Period Dates10/1/20To: 9/30/21

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	30	50	1	3	1	3	3	10	6	20	0	0	5	17	14	47
Piping	13	22	2	15	0	0	1	8	2	15	0	0	1	8	7	54
Dispenser	15	25	3	20	0	0	4	27	0	0	0	0	1	7	7	47
STP	2	3	0	0	0	0	1	50	1	50	0	0	0	0	0	0
Delivery Problem	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Totals	60	100	6	10	1	2	9	15	9	15	0	0	7	12	28	47

## Summary Information For Release Sources And Causes

# = number, % = percent of total number

Note: Release, source and cause information is based on [state: describe universe of tanks]. Source and cause data were collected using [state: describe data-gathering technique(s)].

[**State:** Provide information here on how the public can obtain site-specific UST information on compliance and releases.]