Wel 6

# WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

1. County Ozaukee — Town ☒ Village ☐ City ☐ Cedarburg (Check one and give name)

2. Location SE, SE ¼ of Sec. 28 Town 10 N Range 21 E
Name of street and number of premise or Section, Town and Range numbers

3. Owner ☒ or Agent ☐ Armin E. Nierode
Name of individual, partnership or firm

4. Mail Address 713 W. Walnut Cedarburg
Complete address required

RECEIVED

5. From well to nearest: Building 10 ft; sewer 40 ft; drain 40 ft; septic tank 60 ft; dry well or filter bed 70 ft; abandoned well ____ ft.

JUN 12 1961

6. Well is intended to supply water for: New Home

SANITARY ENGINEERING

**7. DRILLHOLE:**

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|---|---|---|
| 10" | 0' | 15' | | | |
| 6¼ | 0 | 71 | | | |

**8. CASING AND LINER PIPE OR CURBING:**

| Dia. (in.) | Kind and Weight | From (ft) | To (ft) |
|---|---|---|---|
| 6¼ | Steel 23 lbs Per ft | 0' | 71' |
| | | | |
| | | | |

**9. GROUT:**

| Kind | From (ft.) | To (ft.) |
|---|---|---|
| Drilling Mud | 0' | 15' |
| | | |

**10. FORMATIONS:**

| Kind | From (ft.) | To (ft) |
|---|---|---|
| Top Soil Fill | 0 | 5 |
| Sandy Red Clay | 5 | 15 |
| Stoney Gravel | 15 | 18 |
| Blue Clay + Gravel | 18 | 25 |
| Sandy Red Clay + Gravel | 25 | 38 |
| Gravel (coarse) | 38 | 50 |
| Gravel (fine) | 50 | 65 |
| Gravel (Pea) | 65 | 71 |
| | | |

Construction of the well was completed on: May 2 1961

The well is terminated 8 inches ☒ above, below ☐ the permanent ground surface.

Was the well disinfected upon completion? Yes X No ____

Was the well sealed watertight upon completion? Yes X No ____

**11. MISCELLANEOUS DATA:**

Yield test: 5 Hrs. at 12 GPM.

Depth from surface to water-level: 42 ft.

Water-level when pumping: 46 ft.

Water sample was sent to the state laboratory at: Madison (City) on May 31 1961

Signature Donald Poom
Registered Well Driller

R#2 Box 42 Cedarburg Wis
Complete Mail Address

Please do not write in space below

Rec'd JUN 1 1961 No. 17830

Ans'd SAFE—BACTERIOLOGICALLY

Interpretation

| | 10 ml | 10 ml | 10 ml | 10 ml | 10 ml |
|---|---|---|---|---|---|
| Gas—24 hrs. | | | | | |
| 48 hrs. | | | | | |
| Confirm | | | | | |
| B. Coli | 0 | | | | |

Examiner

OZ 6193