Wel. 6-30M(6-50)

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

1. County Ozaukee — Town ☒ Village ☐ City ☐ Cedarburg (Check one and give name)

2. Location Kurtz Sub Pinemeur Road 3/4 East of HY 57
Name of street and number of premise or Section, Town and ~~Range numbers~~

3. Owner ☒ or Agent ☐ John Tommas (SWSW34 T10N-21E)
Name of individual, partnership or firm

4. Mail Address Cedarburg Wis RF 2
Complete address required

RECEIVED JAN 1 1958 ENVIRONMENTAL SANITATION

5. From well to nearest: Building 15 ft; sewer ____ ft; drain ____ ft; septic tank 40 ft; dry well or filter bed 75 ft; abandoned well ____ ft.

6. Well is intended to supply water for: New Home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
6	Top	184			

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	Black Standard	Top	174
6	Clatan Smarkshal		

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay grouting		

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Red Clay	Top	15
Sandy Blue clay	15	30
Blue clay	30	58
Stoney Blue clay	58	62
Blue clay	62	165
Hard pan	165	174
Rock	174	184 Total Deep

Construction of the well was completed on:

May 29 1952

The well is terminated 8 inches ☒ above, below ☐ the permanent ground surface.

Was the well disinfected upon completion?

Yes X No ____

Was the well sealed watertight upon completion?

Yes X No ____

11. MISCELLANEOUS DATA:

Yield test: 5 Hrs. at 18 GPM.

Depth from surface to water-level: 36 ft.

Water-level when pumping: 51 ft.

Water sample was sent to the state laboratory at:

Madison (City) on ____ 19____

Signature Elie Perron & Son's — Registered Well Driller

Cedarburg Wis RF 2 — Complete Mail Address

Please do not write in space below

Rec'd ____ No. ____

Ans'd ____

Interpretation ____

OZ6523

	10 ml	10 ml	10 ml	10 ml	10 ml
Gas—24 hrs.					
48 hrs.					
Confirm					
B. Coli					

Examiner ____