

Pfeiffer, Jane K - DNR

From: Pfeiffer, Jane K - DNR
Sent: Tuesday, August 30, 2022 9:49 AM
To: Robert Reineke
Cc: Pratap Singh
Subject: RE: CWC- West Block (02-41-587376) VMS Commissioning Info Request

Follow Up Flag: Follow up
Flag Status: Completed

Hi Robert – Thank you for speaking this morning with me concerning your below email. Please reach out if you have any further questions.

Best, Jane

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

Jane Pfeiffer

Phone: (414) 435-8021

jane.pfeiffer@wisconsin.gov

From: Robert Reineke <rreineke@ksinghengineering.com>
Sent: Friday, August 26, 2022 3:49 PM
To: Pfeiffer, Jane K - DNR <jane.pfeiffer@wisconsin.gov>
Cc: Pratap Singh <psingh@ksinghengineering.com>
Subject: RE: CWC- West Block (02-41-587376) VMS Commissioning Info Request

**CAUTION: This email originated from outside the organization.
Do not click links or open attachments unless you recognize the sender and know the content is safe.**

Jane,

We are preparing to perform a 2nd round of commissioning at the Community Within the Corridor West Block in early September. To avoid damaging hardwood floors installed following the first round of commissioning, we are proposing to modify the commissioning plan for the location of subslab vacuum measurements. We are proposing to relocate the subslab sampling locations to concrete floor locations in accordance with the locations shown on the attached figure. We would appreciate WDNR consent for these modified locations for this round of commissioning.

Robert Reineke, PE

Principal Engineer | rreineke@ksinghengineering.com

262.821.1171, ext. 111 (p) | 262.424.5191 (cell)

www.ksinghengineering.com

From: Pfeiffer, Jane K - DNR <jane.pfeiffer@wisconsin.gov>
Sent: Thursday, August 4, 2022 9:34 AM
To: Robert Reineke <rreineke@ksinghengineering.com>
Cc: Pratap Singh <psingh@ksinghengineering.com>
Subject: RE: CWC- West Block (02-41-587376) VMS Commissioning Info Request

Good Morning Robert,

Thank you for email. Please continue to keep me updated.

Best, Jane

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

Jane Pfeiffer

Phone: (414) 435-8021

jane.pfeiffer@wisconsin.gov

From: Robert Reineke <rreineke@ksinghengineering.com>
Sent: Wednesday, August 3, 2022 4:06 PM
To: Pfeiffer, Jane K - DNR <jane.pfeiffer@wisconsin.gov>
Cc: Pratap Singh <psingh@ksinghengineering.com>
Subject: RE: CWC- West Block (02-41-587376) VMS Commissioning Info Request

**CAUTION: This email originated from outside the organization.
Do not click links or open attachments unless you recognize the sender and know the content is safe.**

Jane,

Please find attached additional air sampling results for the anomalous PCE reading at location IA-8A-01B which was performed on July 27, 2022. Additional sampling was performed at location IA-8A-01B and the apartments on the either side of the PCE reading.

No VALs were exceeded for PCE this time around. PCE in indoor air was detected ranging from 0.54 ug/m³ to 0.68 ug/m³, well below the VAL of 42 ug/m³. TCE was not detected in any of the three samples.

A second round of commissioning is scheduled for later in August. We will be preparing a report summarizing this round of indoor air sampling and the commissioning testing when we receive the results.

Please let me know if you have any questions. Thanks.

Robert T. Reineke, P.E.

Principal Engineer | rreineke@ksinghengineering.com

262. 821.1171 ext. 111 (p) | 262.424.5191 (cell)

www.ksinghengineering.com

KSingh | Engineers
Scientists
Consultants



From: Pfeiffer, Jane K - DNR <jane.pfeiffer@wisconsin.gov>

Sent: Monday, July 11, 2022 1:11 PM

To: Robert Reineke <rreineke@ksinghengineering.com>

Subject: RE: CWC- West Block (02-41-587376) VMS Commissioning Info Request

I think I found a map showing the fan locations – Please confirm that the “exterior fan locations” shown on the attached figure are correct and that these are the locations where the exhaust samples were collected.

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

Jane Pfeiffer

Phone: (414) 435-8021

jane.pfeiffer@wisconsin.gov

From: Pfeiffer, Jane K - DNR

Sent: Monday, July 11, 2022 11:54 AM

To: Robert Reineke <rreineke@ksinghengineering.com>

Subject: CWC- West Block (02-41-587376) VMS Commissioning Info Request

Hi Robert,

Can you please provide me with an update on the first round of commissioning for Buildings 4 and 5 for the above-referenced site? Has the commissioning occurred yet and, if so, when will the results be submitted to the DNR? Additionally, please present a figure that displays the locations of all of the fans (i.e., the exhaust sample locations) on the rooftops of Buildings 6, 7, 8A, and 8B.

Thank you, Jane

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

Jane K. Pfeiffer

Hydrogeologist - Remediation & Redevelopment Program

Wisconsin Department of Natural Resources

Phone: (414) 435-8021

jane.pfeiffer@wisconsin.gov

Total Control Panel

[Login](#)

To: rreineke@ksinghengineering.com

Message Score: 1

High (60): **Pass**

From: prvs=184b29fd8=jane.pfeiffer@wisconsin.gov

My Spam Blocking Level: Low

Medium (75): **Pass**

Low (90): **Pass**

[Block](#) this sender

[Block](#) wisconsin.gov

This message was delivered because the content filter score did not exceed your filter level.

Total Control Panel

[Login](#)

To: rreineke@ksinghengineering.com

Message Score: 1

High (60): **Pass**

From: prvs=2080167f3=jane.pfeiffer@wisconsin.gov

My Spam Blocking Level: Low


Medium (75): **Pass**

Low (90): **Pass**


[Block](#) this sender

[Block](#) wisconsin.gov

This message was delivered because the content filter score did not exceed your filter level.



SCALE IN FEET
0 50'



LEGEND

- Previous Boring and Temporary Well Locations
- Known Elevator Shaft
- Planned Underground Plumbing
- ▭ Underground Tunnel
- ▨ Basement Area(s)
- Extraction Point Location
- 3" sch. 40 PVC pipe (may be modified)
- ⊙ Exterior Fan Location
- Zone of Influence
- ⊞ Approximate WI Residential VRSL Exceedance Extents
- ⊞ Approximate WI Small Commercial VRSL Exceedance Extents
- Sub-slab Vapor Pin (SVP-xx)
- Proposed 2nd Round of Subslab Vacuum Measurements

NOTES:

1. MINIMUM OF 3.5" SLAB PENETRATION
2. 10-15 "GALL" SOIL REMOVED BENEATH SLAB TO ACT AS SUCTION PIT
3. SEE TABLE FOR RADII FOOTAGE
4. 3" SCH. 40 PVC
5. BALL VALVES FOR EACH EXTRACTION POINT TO REGULATE FLOW
6. MANOMETER AND VELOCITY PORTS FOR EACH EXTRACTION POINT TO MEASURE FLOW AND NEGATIVE PRESSURE
7. MANOMETER POINT AT EACH FAN INLET FOR NEGATIVE PRESSURE
8. EXHAUST VENTING 2 FT ABOVE ROOF AND/OR 12 FT FROM WINDOWS
9. MIN 1.5% SLOPE TOWARD EXTRACTION POINTS
10. ELECTRICAL DISCONNECT AND OWN CIRCUIT FOR EACH FAN
11. 2" EXHAUST PIPING FOR HS FANS, 3" FOR GP501C
12. SEAL ALL CRACKS IN FLOORS
13. PLANS UNDERWAY TO REVISE WD-SV TO SC-1 UNDERLAIN BY 50-MIL SUB-MEMBRANE.

PROJECT TITLE: SITE INVESTIGATION REPORT
3212 W. CENTER ST., 2727 N. 32ND ST., 2758 N. 33RD ST.
COMMUNITY WITHIN THE CORRIDOR - WEST BLOCK
MILWAUKEE, WI 53210
PROJECT NUMBER: 40443

CLIENT:
COMMUNITY WITHIN THE CORRIDOR LIMITED
PARTNERSHIP

REVISIONS	DATE	DESCRIPTION

DRAWN BY: JPB DATE: 06/02/2022
CHECKED BY: RTR DATE: 06/02/2022

SHEET TITLE
Sub-slab Depressurization
Location and Results

FIGURE 1