



**Overview**

There are three regulations that apply to Reciprocating Internal Combustion Engines (RICE), depending on the type of engine and the date of construction: the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary RICE, New Source Performance Standards (NSPS) for Stationary Compression Ignition (CI) Engines, and NSPS for Stationary Spark Ignition (SI) Engines.

Some engines will be subject to both the NESHAP and one of the NSPS rules. Older engines will be subject only to the NESHAP. If an engine is a dual fuel engine, i.e. one that burns both natural gas and diesel, then, for the purposes of these rules, the engine is considered CI if 2% or more of the energy is obtained from burning diesel in the engine on an annual average. Refer to the NESHAP and CI NSPS factsheets for more information on these rules.

This factsheet explains what you must do to comply with the NSPS for Stationary SI (natural gas, landfill gas, gasoline, propane, etc.) RICE.

**NSPS for Stationary Spark Ignition Engines (Subpart JJJJ)—At a Glance**

- Applies to new, modified and reconstructed SI engines.
- For the NSPS for SI engines, your RICE is a new source if:
  - it was ordered after June 12, 2006 and manufactured on or after:
    - July 1, 2007 if  $\geq 500$  hp (except lean burn  $500 \leq \text{hp} < 1,350$ );
    - January 1, 2008 if  $< 500$  hp; or
    - January 1, 2009 (if emergency)  $> 25$  hp; OR
  - if it was modified/reconstructed after June 12, 2006.
- Focus is on criteria pollutants (VOC, NO<sub>x</sub>, PM, CO, SO<sub>2</sub>).

**Applicability**

The NSPS applies to new and reconstructed SI engines. New engines at area sources of hazardous air pollutants can comply with the NESHAP by meeting the NSPS requirements. An area source of HAPs is any facility that has the potential to emit less than 10 tons of any single hazardous air pollutant and less than 25 tons of total hazardous air pollutants.

**What Requirements Apply?—Emission Limitations**

Both emissions limits and fuel standards may apply to new engines under this rule. Tables 1 and 2 describes the emission limitations that apply based on engine type, fuel, size (power), and/or model year.

<b>Table 1 - NSPS for Smaller SI Non-Emergency Engines 25&lt;hp&lt;100</b>			
<b>Maximum Engine Power</b>	<b>Manufacture Date</b>	<b>Emission Requirement in g/kW-hr* (g/hp-hr**)</b>	
		<b>HC+NO<sub>x</sub> ***</b>	<b>CO****</b>
25<hp<100	July 1, 2008	3.8 (2.8)	6.5 (4.8)
	July 1, 2008 (severe duty)	3.8 (2.8)	200.0 (149.2)

\* g/kW-hr = grams per kilowatt-hour  
 \*\* g/hp-hr = grams per horsepower-hour  
 \*\*\* HC+NO<sub>x</sub> = hydrocarbons + nitrogen oxide  
 \*\*\*\* CO = carbon monoxide

**Table 2**  
**NSPS for Larger SI Non-Emergency Engines  $\geq 100$  hp (except gasoline and rich burn LPG) and**  
**SI Landfill/Digester Gas Engines and Emergency SI engines  $> 25$  hp**

Engine Type and Fuel	Maximum Engine Power	Manufacture Date	Emissions Standards					
			g/hp-hr			*ppmvd@ 15% O <sub>2</sub>		
			NO <sub>x</sub>	CO	VOC	NO <sub>x</sub>	CO	VOC
Non-emergency SI Natural Gas, and Non-emergency SI Lean Burn LPG	100 $\leq$ hp<500	07/01/2008	2.0	4.0	1.0	160	540	86
		01/01/2011	1.0	2.0	0.7	82	270	60
Non-emergency SI Lean Burn, Natural Gas and LPG	500 $\leq$ hp<1350	01/01/2008	2.0	4.0	1.0	160	540	86
		07/01/2010	1.0	2.0	0.7	82	270	60
Non-emergency	hp $\geq$ 500	07/01/2007	2.0	4.0	1.0	160	540	86
SI Natural Gas and Non-Emergency SI Lean Burn LPG (except lean burn 500 $\leq$ hp<1350)	hp $\geq$ 500	07/01/2010	1.0	2.0	0.7	82	270	60
Landfill Digester Gas (except lean burn 500 $\leq$ hp<1350)	hp<500	07/01/2008	3.0	5.0	1.0	220	610	80
		01/01/2010	2.0	5.0	1.0	150	610	80
	hp $\geq$ 500	07/01/2007	3.0	5.0	1.0	200	610	80
		07/01/2010	2.0	5.0	1.0	150	610	80
Landfill/Digester Gas Lean Burn	500 $\leq$ hp<1350	01/01/2008	3.0	5.0	1.0	220	610	80
		07/01/2010	2.0	5.0	1.0	150	610	80
Emergency	25<hp<130	01/01/2009	10	387	N/A	N/A	N/A	N/A
	hp $\geq$ 130	01/01/2009	2.0	4.0	1.0	160	540	86

\*ppmvd @ 15% O<sub>2</sub> = parts per million, volumetric dry at 15 percent oxygen

### Compliance Demonstration Requirements

- Engines  $\leq 25$  hp or gasoline or rich burn LPG engines  $> 25$  hp, the compliance demonstration is to use a certified engine.
- Engines  $> 25$  hp using fuels other than gasoline and that are not rich burn LPG engines  $> 25$  hp, the compliance demonstration is using a certified engine or conducting an initial performance test (depending on engine size, periodic testing may be required).

- Owners/operators must keep maintenance records for all engines subject to this NSPS, and a maintenance plan is required for non-certified engines, including certified engines that are being operated in a non-certified manner. Owners/operators of certified engines who do not follow the manufacturer's emission-related operation and maintenance procedures are considered to be operating non-certified engines, and thus are subject to performance testing.
- Owners/operators of certified engines < 100 hp that are operating in a non-certified manner are not required to conduct performance tests; however, owners/operators are required to maintain and operate the engines in a manner consistent with good practices to minimize emissions.
- Owner/operators of certified engines  $\geq 100$  hp  $\leq 500$  that are operating in a non-certified manner must conduct performance tests within the first year of engine operation.
- Owners/operators operating certified engines > 500 hp in a non-certified manner must conduct performance tests within the first year of operation and every 8,760 hours of operation or 3 years thereafter, whichever comes first.

### Recordkeeping and Reporting Requirements

- Owner/operators of all engines are required to maintain records of proper maintenance and non-certified engines must have a maintenance plan.
- Initial notification is required for engines > 500 hp that are non-certified.
- Owners/operators of emergency engines are required to keep records of their hours of operation, e.g. must have a non-resettable hour meter.
- Owners/operators who are required to conduct performance testing on engines must report the results within 60 days of each performance test.

All notifications and performance test reports must be filed electronically to USEPA through the Electronic Reporting Tool: <https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>.

### For Additional Information on the SI NSPS

USEPA's Stationary Engine web page: <https://www.epa.gov/stationary-engines>

Other USEPA resources—

- providing plain language summaries of RICE NESHAP & NSPS: <https://www.epa.gov/stationary-engines/compliance-requirements-stationary-engines>
- sample Initial Notification and Notification of Compliance Status forms, webinars, other guidance documents: <https://www.epa.gov/stationary-engines/guidance-and-tools-implementing-stationary-engine-requirements>

**EPA Combustion Portal** – provides calculators for CI RICE NESHAP, summary of NSPS, and other resources for combustion units: <http://www.combustionportal.org/>

### Definitions

**Certified engine** - an engine manufacturer has received a certification on the emissions standards, e.g. an EPA Certificate of Conformity, for an engine manufactured in model year 2007 or later with a displacement of < 30 liters/cylinder.

**Emergency engine (for NSPS purposes, different than that for NESHAP)** - Operation limited to:

- Unlimited use for emergencies;
- 100 hours/year for maintenance/testing; and
- 50 hours/year of the 100 hours/year allocation can be used for non-emergency situations (if no financial agreement with any entity, including but not limited to a utility).

**Non-road engine** - An engine that is not used in a motor vehicle but is portable - Under the definition of non-road engine in 40 CFR 1068.30, an engine is portable if it does not stay and is not intended to stay at a single location for more than 12 consecutive months or a shorter period of time for an engine located at a seasonal source. Portable (non-road) engines are not stationary engines for purposes of this rule. A facility may consult with its EPA regional office or request a site-specific applicability determination if it is uncertain whether an engine meets the criteria for a non-road or stationary engine. To view determinations already issued by EPA visit <http://cfpub.epa.gov/adi/>.

**Stationary engine** – an engine not used in a motor vehicle and not a non-road engine.

### For Additional Questions Contact:

Michelle Farley  
Air Management Engineer  
Wisconsin Department of Natural Resources  
920-662-5495  
[michelle.farley@wisconsin.gov](mailto:michelle.farley@wisconsin.gov)

***DISCLAIMER** – This document is intended solely as guidance and does not contain any mandatory requirements except where requirements found in statute or administrative rule are referenced. This guidance does not establish or affect legal rights or obligations and is not finally determinative of any of the issues addressed. This guidance does not create any rights enforceable by any party in litigation with the State of Wisconsin or the Department of Natural Resources. Any regulatory decisions made by the Department of Natural Resources in any matter addressed by this guidance will be made by applying the governing statutes and administrative rules to the relevant facts.*

*The Wisconsin Department of Natural Resources provides equal opportunity in employment, programs, services and functions under an Affirmative Action Plan. If you have any questions, please write to Equal Opportunity Office, Department of Interior, Washington, DC 20240. This publication is available in alternative format (large print, Braille, audio tape, etc.) upon request. Please contact the Bureau of Air Management, phone 608-266-7718, for more information.*



Wisconsin Department of Natural Resources  
Bureau of Air Management  
Box 7921- AM/7  
Madison, WI 53707  
PHONE 608-266-7718 • FAX 608-267-0560  
**Publication AM-513 2019**